

Reliability Analysis for IRP Planning Reserve Margin (PRM)

July 19, 2022



Together, Building
a Better California



PG&E Reliability Analysis for IRP

Draft PRM Results and Key Takeaways

PG&E PRM vs. Energy Division (ED) PRM to achieve a 0.1 Loss of Load Expectation (LOLE)

	PG&E's Draft Results	ED's Draft Results	Delta
<i>PRM</i>	13%	14%	1%

- 1. PG&E supports ED's proposed PRM methodology changes:**
 - a) PRM based on gross peak. Behind-the-Meter Photovoltaic (BTM PV) treated as a resource
 - b) PRM based on perfect capacity modeling
- 2. *PG&E's PRM results largely aligned with ED's***
 - a) For 2030 IRP benchmarking, ED's 1% higher PRM would result in ~600 MW of incremental CAISO perfect capacity need*
- 3. Resource accreditation will be critical in ensuring an appropriate reliability framework**



PG&E Reliability Analysis for IRP

PG&E's Strategic Energy & Risk Valuation Model (SERVM) Model

- ED's 2020 Reference System Plan (RSP) SERVM model used as a starting point
- RSP SERVM model modified with the following major updates:
 - *Resource Portfolio matches 2022 Preferred System Plan (PSP), inclusive of North/South split*
 - *Load, Solar and Wind profiles*
 - Added recent year (2018, 2019, 2020, 2021) weather data
 - Calibrated load duration curve to 2021 Integrated Energy Policy Report (IEPR) or the Interagency Working Group (IAWG) High-Electrification forecast
 - Calibrated solar and wind profiles using historical production data
 - *CAISO Imports*
 - Net-imports limited to 4,000 MW during Months 6-9, hours ending (HE) 17-22 & ramp down constraint between Maximum Import Capability (MIC) and 4,000 MW limit
 - Approximates rest of Western Electricity Coordinating Council (WECC) regions at 0.1 LOLE
 - Net import allocation to North and South calibrated to 2020
 - *Storage forced and planned outages & constraints adjusted to match ED's 2021 PSP Update*
 - Storage outage rate assumptions: 5% average outage rate to all storage categories (batteries, both paired and stand-alone, BTM batteries).
 - Pumped storage calibrated to historical – outages embedded.
 - Battery discharge constraint (non-binding during unserved energy events): 90% discharge cap to batteries, both paired and stand-alone (but not pumped storage hydro)
- Updated hydro de-rates, and increased operating reserve requirement from 4.5% to 6% (regional requirement and based on managed load)



PG&E Reliability Analysis for IRP

PSP Scenarios Analyzed

In addition to analyzing aPRM requirement using the 2021 IEPR AAEE Scenario 3 – AAFS Scenario 3 Forecast, PG&E’s study included scenario analysis for different load forecasts

Year	#	Forecast and Study Year Scenarios	PRM Calculation	Resource Accreditation for PRM
2030	1	2021 IEPR Additional Achievable Energy Efficiency (AAEE) Scenario 3 – Additional Achievable Fuel Substitution (AAFS) Scenario 3	x	x
	2	2021 Inter-Agency Working Group (IAWG) High Electrification	x	
	3	2021 IEPR AAEE Scenario 3 – AAFS Scenario 3 & High EV	x	
2035	4	2021 IEPR AAEE Scenario 3 – AAFS Scenario 3	x	x

$$PRM = \frac{\text{Perfect Capacity Needed to Achieve a 0.1 LOLE}}{\text{Gross Peak (sales-load modifiers+BTM PV)}} - 1$$



PG&E Reliability Analysis for IRP

PG&E and ED Comparison – ED Results Estimated

In 2030, using the IEPR load forecast, ED's draft PRM would result in ~580 MW of incremental perfect capacity at the CAISO-level

2030 PRM Estimation for 2021 IEPR AAEE Scenario 3 – AAFS Scenario 3

	PG&E's Draft Results	ED's Draft Results	Delta
Perfect Capacity Needed to Achieve a 0.1 LOLE (MW)	65,499	66,079	580
CAISO Gross Peak	57,964	57,964	
PRM	13%	14%	1%

$$PRM = \frac{65,499}{57,964} - 1 = 13\%$$

$$PRM = \frac{66,079}{57,964} - 1 = 14\%$$



PG&E Reliability Analysis for IRP

Loss of Load Expectation (LOLE) Results

The PSP portfolio includes sufficient capacity to achieve a 0.1 LOLE across different load forecast scenarios

PG&E Draft PSP LOLE Results

	PSP w/2021 IEPR AAEE Scenario 3 – AAFS Scenario 3		PSP w/IAWG High Electrification	
Metric	2030	2035	2030	2035
<i>Found LOLE</i>	0.02	0.003	0.02	0.07
<i>Thermal Capacity Removed to Achieve 0.1 LOLE</i>	(~2,700)	(~4,200)	(~2,100)	(~950)

Appendix



Together, Building
a Better California



PG&E Reliability Analysis for IRP

Key Modeling Assumptions

ED's 1% higher PRM is largely driven by a more conservative operating reserve requirement and the weather years modeled

	ED PSP Model	PG&E Model	More Conservative PRM Assumption
Supply Resources	PSP Portfolio	<ul style="list-style-type: none"> ○ PSP Portfolio ○ Capacity split North and South based on PSP ratio 	N/A
Weather Years	1998-2020	1998-2021	CPUC
Net-Import Constraints	Net-imports limited to 4,000 MW during Months 6-9, hours ending 17-22 & ramp down constraint between MIC and 4,000 MW limit	<ul style="list-style-type: none"> ○ Net-imports limited to 4,000 MW during Months 6-9, hours ending 17-22 & ramp down constraint between MIC and 4,000 MW limit ○ Net-import allocation split between North & South based on the 2020 historical data 	N/A
Load Forecast	IEPR 2021 Scenario 3 – AAFS Scenario 3	<ol style="list-style-type: none"> 1. IEPR 2021 Scenario 3 – AAFS Scenario 3 + High EV 2. IAWG High Electrification 3. IEPR 2021 IEPR Scenario 3 – AAFS Scenario 3 	N/A
Forced Outages	NERC GADS Outage Database	Calibrated to August 2020 Resource Outage Rate	N/A
Operating Reserves Requirement	6% on Gross Load – Regional Requirement	~5.5% on Gross Load to replicate 6% on Managed Load – Regional Requirement	CPUC
Renewable and Hydro Profiles	N/A	2020 RSP profiles calibrated to historical CAISO data	N/A
Storage Assumptions and Constraints	<ul style="list-style-type: none"> ○ 5% average outage rate to all storage categories (batteries, both paired and stand-alone, BTM batteries, PSH). ○ Battery discharge constraint (non-binding during unserved energy events): 90% discharge cap to batteries, both paired and stand-alone (but not PSH) 	<ul style="list-style-type: none"> ○ 5% average outage rate to all storage categories (batteries, both paired and stand-alone, BTM batteries). ○ PSH calibrated to historical – outages embedded. ○ 90% discharge cap to batteries, both paired and stand-alone (but not PSH, non-binding during reliability events) 	N/A



Reliability Analysis for IRP PRM

SERVM Stochastic Framework to Capture Uncertainty

- The LOLE for a given study year is based on a weighted average of the LOLE from all associated simulated 8760 scenarios
- *The weather years modeled, and the underlying load forecast for the weather years will have the greatest impact on the LOLE results and subsequent PRM*
- *PG&E organized its reliability study to ensure an appropriate PRM was informed by different potential load forecasts and study years*

SERVM Iterations for a single study year

