

2023 Proposed PSP and 2024-25 TPP Supplemental Analysis

October 20, 2023



California Public
Utilities Commission

Background

Contents


- 2023 PSP & 2024-25 TPP Analysis: RESOLVE Sensitivity Results
 - Cost Sensitivities
 - Demand Sensitivities
 - Resource Availability Sensitivities
 - Long Lead-Time Sensitivities
 - Detailed RESOLVE Results
 - Detailed Results
- Imports and Exports

2023 PSP & 2024-25 TPP Analysis: RESOLVE Sensitivity Results

Overview of Included RESOLVE Sensitivities

| Sensitivity Grouping | Description of Sensitivity | Sensitivity Cases New cases contained in this deck Cases Released with the PSP/TPP Ruling Materials |
|--------------------------------------|--|--|
| 25 MMT Least-Cost | All sensitivities are compared to the 25 MMT Least-Cost case | |
| Cost | One or more resources have higher or lower costs than modeled in 25 MMT Least-Cost | <ol style="list-style-type: none"> 1) High Battery 2) High Solar 3) High Land-Based Wind 4) High Solar PV, Battery 5) Low Offshore Wind 6) Low Offshore Wind & High Land-Based Wind, Solar PV, Storage 7) High Geothermal & Biomass 8) High Gas Fixed O&M |
| Demand | Annual load forecast varies from 25 MMT Least-Cost | <ol style="list-style-type: none"> 1) High Electrification 2) 2021 ATE (Additional Transportation Electrification) |
| Resource Availability | Availability of resources (gas, imports, BTM PV) varies from availability in 25 MMT Least-Cost | <ol style="list-style-type: none"> 1) Moderate Gas Retirement 2) High Gas Retirement 3) No Imports for Reliability After 2028 4) Low BTM PV |
| Long Lead-Time: Offshore Wind | Different competing resource costs and availability constraints are added | <ol style="list-style-type: none"> 1) Reduced land-based clean resource availability 2) Significantly reduced land-based competing resource availability 3) Low offshore wind cost & reduced land-based clean resource availability 4) Low offshore wind cost & significantly reduced land-based clean resource availability 5) High land-based wind (resource and transmission) costs 6) High land-based wind, solar, and storage costs (resource and transmission costs) 7) Low offshore wind cost and high land-based wind, solar, and storage costs (resource and transmission costs) |

Summary of Build Across all Sensitivities



Cost Sensitivities

Cost sensitivities explore how resource choices are/are not robust to changes in resource cost trajectories







Cost Sensitivities

- Performing multiple cost sensitivities enables the consideration of different cost futures and their impact on optimal resource portfolio
- While near-term builds are more significantly impacted by current market trends, future costs are more uncertain and are driven by several factors including how supply chain of each technology evolves; therefore, the cost competitiveness between technologies is less predictable
- Cost sensitivities show if resource choices are, or are not, robust to differences in resource costs
- Higher cost sensitivities are considered for a more conservative approach and to evaluate delays in future cost reductions
- A lower cost sensitivity is considered for offshore wind to explore conditions at which offshore wind is economically reasonable in future portfolios

Cost Sensitivities

Cost Comparison for 25 MMT Least-Cost (Core) vs. Sensitivities



Levelized Fixed Cost



Cost Sensitivities Definitions

New Cases

Cases included in PSP/TPP Ruling materials

| | |
|---|--------------------------|
|  | Indicates cost increase |
|  | Indicates cost reduction |

| | Battery | Biomass | Geo-thermal | Solar | In-State Wind | Out-of-State Wind | Offshore Wind | Existing Gas FO&M |
|--|---------|---------|-------------|-------|---------------|-------------------|---------------|-------------------|
| 25 MMT Least-Cost | | | | | | | | |
| High Battery | ▲ | | | | | | | |
| High Solar | | | | ▲ | | | | |
| <u>High Solar PV & Battery</u> | ▲ | | | ▲ | | | | |
| <u>High Land-Based Wind</u> | | | | | ▲ | ▲ | | |
| High Land-Based Wind, Solar PV, Battery | ▲ | | | ▲ | ▲ | ▲ | | |
| <u>Low Offshore Wind</u> | | | | | | | ▼ | |
| Low Offshore Wind & High Land-Based Wind, Solar PV, Storage | ▲ | | | ▲ | ▲ | ▲ | ▼ | |
| <u>High Geothermal & Biomass</u> | | ▲ | ▲ | | | | | |
| High Gas Fixed O&M | | | | | | | | ▲ |


Cost Sensitivities

25 MMT Least-Cost vs Cost Sensitivities: 2039

Compared to the 25 MMT Least Cost Case:

- High battery storage costs reduce 8-hr batteries in the portfolio more than they reduce the 4-hr battery builds and more pumped hydro is selected
- High solar and battery costs result in more geothermal build
- Higher land-based wind costs result in <1 GW wind replaced with 8-hr battery
- With lower offshore wind costs, offshore wind replaces a mix of geothermal, out-of-state wind, solar, and batteries in the portfolio and reduces the total system cost
- High biomass and geothermal costs result in additional wind, solar and 8-hr batteries and no additional geothermal gets selected after 2028
- Higher gas fixed costs increase the system costs substantially but result in <1 GW non-retained gas capacity

Planned & Selected Capacity by Scenario



Cost Sensitivities

25 MMT Least-Cost vs Cost Sensitivities: 2035


- Portfolio composition is largely stable in response to cost changes
 - High geothermal costs reduce geothermal build by 2/3
 - High gas fixed O&M causes very slight increase in gas retirements

NPV of Total Resource Cost

(\$MM in 2022 Dollar Year, 2024-2065)

| | |
|--|--------------|
| 25 MMT Least-Cost | \$925,303 MM |
| 25 MMT High Battery Costs | +\$6,411 MM |
| 25 MMT High Solar PV Costs | +\$5,548 MM |
| 25 MMT High Solar PV & Battery Costs | +\$10,583 MM |
| 25 MMT High Land-Based Wind Costs | +\$1,833 MM |
| 25 MMT High Land-Based Wind, Solar PV & Battery Costs | +\$13,261 MM |
| 25MMT Low Offshore Wind Costs | -\$797 MM |
| 25 MMT Low OSW & High Land-Based Wind, Solar PV, Battery Costs | +\$10,461 MM |
| 25 MMT High Geothermal & Biomass Costs | +\$7,795 MM |
| 25 MMT High Gas Fixed O&M Costs | +\$16,829 MM |

Planned & Selected Capacity by Scenario (GW)



Minor correction made to NPV & 2035 cost for High Geothermal & Biomass Costs case since slides released on 10/6/2023

Negligible increase in annual costs ultimately becomes cost savings by 2039

Key Takeaways

- Resource choices are generally stable in response to differences in resource cost inputs, especially through 2035
 - Cost sensitivities result in minimal portfolio changes, even as portfolio costs increase/decrease
 - This result reflects other factors than cost in the resource selection process, such as resource potential limits, transmission limitations, etc.
 - Offshore wind is an exception, as is shown later in this presentation
- Minor portfolio changes are driven by cost differences as follows:
 - High geothermal costs leads to significant reductions in geothermal build
 - Geothermal is only selected to meet the MTR order requirements
 - Low offshore wind costs drive RESOLVE to include offshore wind build
 - High gas fixed O&M costs leads to marginally less gas retained but higher system costs
 - High solar/battery costs increase geothermal build

Demand Sensitivities

Demand sensitivities explore how resource choices are/are not robust to different demand forecasts

Demand Sensitivities

- Demand forecast is an input to the RESOLVE model
- In this set of sensitivities, loads higher than the 2022 IEPR Planning Scenario are modeled
- Performing multiple demand sensitivities enables the consideration of uncertainties in electrification and system peak levels and informs how resource portfolios change to meet increasing electric loads in the future
- Demand sensitivities explore whether resource portfolios are robust or not in respond to load growth

Demand Sensitivities

Definitions

| Case | 2026 | | 2030 | | 2035 | | 2039 | |
|--|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|
| | Annual Load (TWh) | Peak Demand (GW) | Annual Load (TWh) | Peak Demand (GW) | Annual Load (TWh) | Peak Demand (GW) | Annual Load (TWh) | Peak Demand (GW) |
| 25 MMT Least-Cost | 252 | 54.9 | 280 | 58.3 | 319 | 64.0 | 352 | 68.7 |
| High Electrification (2022 IEPR Local Reliability Load Forecast) | +3 | +0.5 | +12 | +1.9 | +27 | +3.9 | +35 | +3.4 |
| 2021 ATE (Near-Term Adjusted 2021 Additional Transportation Electrification) | 0 | 0 | +1.6 | +0.6 | +14 | +2.6 | +45 | +5.5 |



Red indicates an increase relative to 25 MMT Least-Cost

| Case | Baseline Demand Case | Transportation Scenario | AAEE Scenario | AAFS Scenario | CARB SIP NOx Rules |
|--|----------------------|--|---------------|---------------|--------------------|
| 25 MMT Least-Cost | Mid Case | AATE Scenario 3 | Scenario 3 | Scenario 3 | Excluded |
| High Electrification (2022 IEPR Local Reliability Load Forecast) | Mid Case | Scenario 3 | Scenario 2 | Scenario 4 | Included |
| 2021 ATE (Near-Term Adjusted 2021 Additional Transportation Electrification) | Mid Case | 2024-2027: Scenario 3 2028-2035: Policy | Scenario 3 | Scenario 3 | Included |

Demand Sensitivities

Load Forecasts

- The High Electrification scenario reflects the 2022 IEPR Local Reliability load forecast and has the highest near-term electric loads modeled in this set of sensitivities
- To avoid near-term divergence in demand between load forecasts, the 2021 IEPR ATE Modified Scenario has 2022 IEPR Planning Scenario loads through 2027, increasing to the 2021 ATE afterwards (as modeled in the 2023-2024 TPP analysis). In this set of sensitivities, The 2021 ATE load forecast has the highest loads in the long-run.




Demand Sensitivities

25 MMT Least-Cost vs Demand Sensitivities

- High electrification increases costs substantially by increasing solar, land-based wind, 8-hr battery and geothermal builds
- The modeled High Electrification Scenario reflecting the 2022 IEPR Local Reliability forecast assumes lower energy efficiency and higher electrification levels; therefore, it has much higher resource needs
 - Energy savings from energy efficiency measures are not optimized and are inputs to the model reflecting CEC's latest forecasts

Planned & Selected Capacity by Scenario (GW)



NPV of Total Resource Cost (\$MM in 2022 Dollar Year, 2024-2065)

| | |
|-----------------------------|--------------|
| 25 MMT Least-Cost | \$925,303 MM |
| 25 MMT High Electrification | +\$31,293MM |
| 25 MMT 2021 ATE | +\$16,223MM |

Key Takeaways

- Higher energy demand accompanied by increases in system peak demand increase the need for new resources
- Accelerated buildout of utility solar, out-of-state wind, and 8-hr batteries is needed to meet higher energy demands
- Cases with higher electrification show higher electric system costs meaning that customers would spend more on their electric bills; however, they would spend less on other energy costs (e.g., spending money on EV charging instead of gasoline)
- The net impact of these factors is not quantified here
- While total electric system costs increase with higher electrification, electricity rates may stay constant or even decrease depending on the ability to increase the utilization factor of fixed cost infrastructure (such as generation, distribution, and transmission capacity)

Resource Availability Sensitivities

Resource availability sensitivities explore how robust resource choices are to different resource availability assumptions

Resource Availability Sensitivities

- Resource availability sensitivities explore how changes in resource availability or retirements could impact portfolio selection
- Resource availability risk is not explicitly considered in each RESOLVE portfolio optimization
- Performing multiple resource availability sensitivities enables the consideration of resource availability risks as part of the portfolio development process

Definitions

New Cases
[Cases included in PSP/TPP Ruling materials](#)

| | Gas Capacity Retired by 2030 | Gas Capacity Retired by 2045 | Unspecified Imports Assumed for RA | BTM PV Capacity by 2045 |
|--|------------------------------|------------------------------|------------------------------------|-------------------------|
| 25 MMT Least-Cost | 0 GW | 0 GW | 4 GW | 44 GW |
| <u>Moderate Gas Retirement</u> | 4.2 GW | 4.5 GW | 4 GW | 44 GW |
| <u>High Gas Retirement</u> | 3.1 GW | 12.1 GW | 4 GW | 44 GW |
| No Imports for Reliability after 2028 | 0 GW | 0 GW | 0 GW (after 2028) | 44 GW |
| <u>Low BTM PV</u> | 0 GW | 0 GW | 4 GW | 31 GW |

Red indicates a difference from 25 MMT Least-Cost


Resource Availability Sensitivities

25 MMT Least-Cost vs Resource Availability Sensitivities: 2035

- In cases with higher gas retirement, gas (along with some wind) is replaced with solar and 8-hr battery storage
- No imports for reliability after 2028 also leads to more solar and 8-hr storage build, as well as 0.5 GW new gas
- Low BTM PV results in more utility-scale solar and 4-hour storage, as well as a shift from in-state to out-of-state wind
 - Cost savings shown for BTM PV include reduced customer costs for BTM PV

| NPV of Total Resource Cost (\$MM in 2022 Dollar Year, 2024-2065) | |
|---|--------------|
| 25 MMT Least-Cost | \$925,303 MM |
| 25 MMT Moderate Gas Retirement | +\$3,742MM |
| 25 MMT High Gas Retirement | +\$13,039MM |
| 25 MMT No Imports for Reliability After 2028 | +\$5,469MM |
| 25 MMT Low BTM PV | -\$5,073MM |

Planned & Selected Capacity by Scenario (GW)



Resource Availability Sensitivities

25 MMT Least-Cost vs Resource Availability Sensitivities: 2039


- Trends seen in 2035 are magnified in 2039
 - There is significantly more solar and 8-hr battery storage buildout in gas retirement and no import reliability sensitivities
 - Low BTM PV yields more utility-scale solar build

NPV of Total Resource Cost

(\$MM in 2022 Dollar Year, 2024-2065)

| | |
|--|--------------|
| 25 MMT Least-Cost | \$925,303 MM |
| 25 MMT Moderate Gas Retirement | +\$3,742MM |
| 25 MMT High Gas Retirement | +\$13,039MM |
| 25 MMT No Imports for Reliability After 2028 | +\$5,469MM |
| 25 MMT Low BTM PV | -\$5,073MM |

Planned & Selected Capacity by Scenario (GW)



Key Takeaways

- Gas retirements provide little to no GHG emissions reductions benefits in these portfolios
 - While in-state gas generation goes down, it is replaced with imports (frequently gas plants in neighboring regions)
- Gas retirements increase costs, with higher levels of retirements increasing costs significantly more
- High gas retirement sensitivities and the no imports for reliability sensitivity lead to more solar and 8-hr duration battery storage build over time
- Gas retirement sensitivities were not analyzed to see if they would meet the local reliability requirements in LCR areas where gas generators are retired
 - Replacing firm capacity in local areas may be a challenge for the high gas retirements scenario
 - Long-duration storage may be able to replace some of the local capacity need
- BTM PV is largely replaced with utility-scale solar resources in the Low BTM PV sensitivity
 - Total resource costs are reduced as more expensive customer sited solar is replaced with lower cost utility scale solar

Long Lead-Time Sensitivities

Long-Lead Time sensitivities focus on offshore wind and explore how resource costs and availability impact offshore wind resource selection in the portfolio

Resource Availability and Cost Sensitivities



- Combinations of competing resource costs and resource availability are explored to identify major factors impacting offshore wind selection in the portfolio
- Given the high uncertainties in future costs and resource additions, this set of sensitivities explores situations where offshore wind selection in the portfolio is economically justified

Long Lead-Time Resource Sensitivities: Offshore Wind

Definitions

New Cases

Cases included in PSP/TPP Ruling materials

| | |
|---|--------------------------|
|  | Indicates cost increase |
|  | Indicates cost reduction |

| | Offshore Wind Costs | Land-Based Wind & Transmission Costs | Solar & Battery Costs | Land-Based Wind Resource Build Limits by 2035 | Geothermal, Biomass & Pumped Hydro Resource Build Limits by 2035 |
|---|---|---|---|---|--|
| 25 MMT Least-Cost | | | | 25.6 GW | 9.7 GW |
| <u>Reduced Resource Availability (non-OSW resources)</u> | | | | 7 GW | 3.5 GW |
| <u>Significantly Reduced Resource Availability (non-OSW resources)</u> | | | | 3 GW | 3.5 GW |
| <u>Low OSW Costs & Reduced Resource Availability</u> |  | | | 7 GW | 3.5 GW |
| <u>Low OSW Costs & Significantly Reduced Resource Availability</u> |  | | | 3 GW | 3.5 GW |
| High Land-Based Wind & Transmission Costs | |  | | 25.6 GW | 9.7 GW |
| High Solar, Battery, Land-Based Wind & Transmission Costs | |  |  | 25.6 GW | 9.7 GW |
| Low OSW & High Solar, Battery, Land-Based Wind, Transmission Costs |  |  |  | 25.6 GW | 9.7 GW |

Long Lead-Time Resource Sensitivities: Offshore Wind


25 MMT Least-Cost vs LLT Sensitivities: 2035

- With low offshore wind costs and significantly reduced resource availability (non-OSW resources), up to 4.3 GW offshore wind gets selected by 2035
- Higher competing resource costs alone do not result in offshore wind selection
- Reduced resource availability impacting land-based wind, geothermal, pumped storage and biomass, is resulting in substantially higher solar and 8-hr battery builds and non-retained gas

NPV of Total Resource Cost (\$MM in 2022 Dollar Year, 2024-2065)

| | |
|---|--------------|
| 25 MMT Least-Cost | \$925,303 MM |
| 25 MMT Reduced Resource Availability | +\$17,146 MM |
| 25 MMT Significantly Reduced Resource Availability | +\$24,846 MM |
| 25 MMT Low OSW Costs & Reduced Resource Availability | +\$14,764 MM |
| 25 MMT Low OSW Costs & Significantly Reduced Resource Availability | +\$21,640 MM |
| 25 MMT High Land-Based Wind & Transmission Costs | +\$4,153 MM |
| 25 MMT High Solar, Battery, Land-Based Wind & Transmission Costs | +\$17,433 MM |
| 25 MMT Low OSW & High Solar, Battery, Land-Based Wind, Transmission Costs | +\$14,784 MM |

Planned & Selected Capacity by Scenario (GW)



2035

| | | | | | | | |
|----------|-----------|-----------|-----------|-----------|---------|---------|---------|
| \$54,834 | +\$1,701M | +\$2,325M | +\$1,428M | +\$2,081M | +\$347M | +\$545M | +\$666M |
|----------|-----------|-----------|-----------|-----------|---------|---------|---------|

Annual Costs (\$MM/yr)

Long Lead-Time Resource Sensitivities: Offshore Wind


25 MMT Least-Cost vs LLT Sensitivities: 2045

- With low offshore wind costs and significantly reduced resource availability (non-OSW resources), up to 5.8 GW offshore wind gets selected by 2045
- Except for the case where offshore wind costs are low and other competing resource costs are high, no additional wind gets selected post 2039 through 2045

NPV of Total Resource Cost (\$MM in 2022 Dollar Year, 2024-2065)

| | |
|---|--------------|
| 25 MMT Least-Cost | \$925,303 MM |
| 25 MMT Reduced Resource Availability | +\$17,146 MM |
| 25 MMT Significantly Reduced Resource Availability | +\$24,846 MM |
| 25 MMT Low OSW Costs & Reduced Resource Availability | +\$14,764 MM |
| 25 MMT Low OSW Costs & Significantly Reduced Resource Availability | +\$21,640 MM |
| 25 MMT High Land-Based Wind & Transmission Costs | +\$4,153 MM |
| 25 MMT High Solar, Battery, Land-Based Wind & Transmission Costs | +\$17,433 MM |
| 25 MMT Low OSW & High Solar, Battery, Land-Based Wind, Transmission Costs | +\$14,784 MM |

Planned & Selected Capacity by Scenario (GW)



| | | | | | | | |
|----------|-----------|-----------|-----------|-----------|---------|-----------|-----------|
| \$64,239 | +\$1,498M | +\$2,118M | +\$1,229M | +\$1,722M | +\$247M | +\$2,422M | +\$1,958M |
|----------|-----------|-----------|-----------|-----------|---------|-----------|-----------|

Annual Costs (\$MM/yr)

Long Lead-Time Resource Sensitivities: Offshore Wind


25 MMT Least-Cost vs LLT Sensitivities: 2039

- With low offshore wind costs and significantly reduced resource availability (non-OSW resources), up to 5.8 GW offshore wind gets selected by 2039
- Increased amount of storage, particularly 8-hr duration battery storage, leads to less gas capacity being retained relative to the least-cost portfolio

NPV of Total Resource Cost (\$MM in 2022 Dollar Year, 2024-2065)

| | |
|---|--------------|
| 25 MMT Least-Cost | \$925,303 MM |
| 25 MMT Reduced Resource Availability | +\$17,146 MM |
| 25 MMT Significantly Reduced Resource Availability | +\$24,846 MM |
| 25 MMT Low OSW Costs & Reduced Resource Availability | +\$14,764 MM |
| 25 MMT Low OSW Costs & Significantly Reduced Resource Availability | +\$21,640 MM |
| 25 MMT High Land-Based Wind & Transmission Costs | +\$4,153 MM |
| 25 MMT High Solar, Battery, Land-Based Wind & Transmission Costs | +\$17,433 MM |
| 25 MMT Low OSW & High Solar, Battery, Land-Based Wind, Transmission Costs | +\$14,784 MM |

Planned & Selected Capacity by Scenario (GW)



2039

| | | | | | | | |
|----------|-----------|-----------|-----------|-----------|---------|-----------|-----------|
| \$57,701 | +\$1,701M | +\$2,397M | +\$1,571M | +\$2,180M | +\$514M | +\$1,289M | +\$1,135M |
|----------|-----------|-----------|-----------|-----------|---------|-----------|-----------|

Annual Costs (\$MM/yr)

Key Takeaways

- High cost for competing resources alone does not result in offshore wind economic selection in the portfolio
- By reducing competing resource availability for land-based wind, geothermal, biomass and pumped storage, more solar and storage are selected, and more gas is not retained. However, the impact on the amount of offshore wind selected is minimal
 - The reduced resource availability (non-OSW resources) case does not have any offshore wind selection while the significantly reduced resource availability (non-OSW resources) has about 1.5 GW through 2045.
- Offshore wind selection is most sensitive to offshore wind costs
 - The most impact in the selection of offshore wind is seen when the cost of offshore wind is reduced
 - Even more offshore wind is selected when this is combined with other factors such as cost of competing resources and the availability of the competing resources

Detailed RESOLVE Results

25 MMT Least-Cost

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.2 | 1.6 | 1.6 | 2.1 | 2.1 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | 0.1 | 9.6 | 11.8 | 12.5 | 12.5 | 13.4 | 13.4 | 13.4 | 13.8 |
| Out-of-State Wind | - | - | 2.4 | 3.9 | 4.3 | 4.3 | 4.3 | 5.4 | 6.4 | 9.3 | 9.3 | 10.2 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 7.7 | 9.4 | 9.4 | 14.0 | 15.3 | 15.3 | 15.3 | 25.9 | 29.3 | 58.1 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.1 | 1.6 | 1.6 | 3.1 | 7.8 | 9.6 | 20.8 |
| Pumped Hydro Storage | - | - | - | 2.0 | 2.0 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (3.6) |
| Total | 7.4 | 10.7 | 16.1 | 23.5 | 33.4 | 41.3 | 44.9 | 46.5 | 49.9 | 67.9 | 73.1 | 110.8 |

Detailed RESOLVE Results: Resource Cost Sensitivities

Resource Cost Sensitivity: High Battery Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.2 | 1.5 | 1.5 | 2.1 | 2.1 | 2.9 | 2.9 | 3.9 | 3.9 | 3.9 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | 0.3 | 9.8 | 11.7 | 12.5 | 12.5 | 13.4 | 13.4 | 13.4 | 15.0 |
| Out-of-State Wind | - | - | 2.4 | 3.9 | 4.3 | 4.3 | 4.3 | 5.4 | 6.4 | 8.6 | 8.6 | 14.1 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 7.9 | 9.5 | 9.5 | 14.8 | 15.8 | 15.8 | 15.8 | 24.7 | 27.9 | 46.4 |
| Li-ion Battery (4-hr) | 3.9 | 4.3 | 5.2 | 5.2 | 5.2 | 5.2 | 5.2 | 5.2 | 5.2 | 5.2 | 5.2 | 5.2 |
| Li-ion Battery (8-hr) | - | - | - | - | - | - | 0.9 | 0.9 | 2.4 | 5.4 | 7.3 | 14.0 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.5 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.9 | 0.9 | 0.9 |
| Shed DR | 0.5 | 0.5 | 0.7 | 0.7 | 0.7 | 0.7 | 0.7 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (1.0) |
| Total | 7.4 | 10.7 | 16.3 | 23.7 | 33.7 | 41.8 | 45.2 | 46.6 | 50.0 | 65.2 | 70.3 | 101.5 |

Resource Cost Sensitivity: High Solar PV Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.4 | 1.5 | 1.5 | 2.1 | 2.1 | 2.9 | 2.9 | 3.5 | 3.9 | 3.9 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.0 | 0.0 | 0.0 | 0.0 | 7.9 | 11.9 | 12.3 | 12.3 | 13.2 | 13.2 | 13.2 | 13.8 |
| Out-of-State Wind | - | - | 1.8 | 3.3 | 4.3 | 4.3 | 4.3 | 4.8 | 5.8 | 9.3 | 9.3 | 11.7 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 12.9 | 12.9 | 14.7 | 17.2 | 17.2 | 17.2 | 22.5 | 24.6 | 46.0 |
| Li-ion Battery (4-hr) | 3.5 | 3.9 | 4.7 | 4.7 | 4.7 | 4.7 | 4.7 | 4.7 | 4.7 | 4.7 | 4.7 | 4.7 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.1 | 1.4 | 1.8 | 3.2 | 7.7 | 9.1 | 19.1 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.8 | 0.8 | 1.0 | 1.1 | 1.1 | 1.1 | 1.1 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (2.1) |
| Total | 7.4 | 10.7 | 16.9 | 26.1 | 35.0 | 41.9 | 46.2 | 47.1 | 50.5 | 64.1 | 67.9 | 100.2 |

Resource Cost Sensitivity: High Solar PV & Battery Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.3 | 1.5 | 1.5 | 2.0 | 2.0 | 2.8 | 2.9 | 3.9 | 3.9 | 3.9 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 8.0 | 11.7 | 12.2 | 12.2 | 13.1 | 13.1 | 13.1 | 15.0 |
| Out-of-State Wind | - | - | 2.5 | 4.0 | 4.3 | 4.3 | 4.3 | 5.5 | 6.5 | 9.4 | 9.4 | 17.2 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 12.6 | 12.6 | 14.6 | 16.4 | 16.4 | 16.4 | 21.9 | 24.6 | 36.1 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 |
| Li-ion Battery (8-hr) | - | - | - | - | - | - | 1.2 | 1.2 | 2.5 | 6.0 | 7.9 | 11.7 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.7 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.9 | 0.9 | 0.9 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (0.2) |
| Total | 7.4 | 10.7 | 17.4 | 26.4 | 34.7 | 41.7 | 45.4 | 47.0 | 50.4 | 63.5 | 68.0 | 92.8 |

Resource Cost Sensitivity: High Land-Based Wind Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.2 | 1.6 | 1.6 | 2.1 | 2.1 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.1 | 0.1 | 0.4 | 0.8 | 10.5 | 12.1 | 12.1 | 12.1 | 13.0 | 13.0 | 13.0 | 13.0 |
| Out-of-State Wind | - | - | 2.5 | 4.0 | 4.3 | 4.3 | 4.3 | 5.5 | 6.5 | 8.9 | 8.9 | 9.9 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 7.0 | 8.7 | 8.7 | 13.8 | 15.5 | 15.5 | 15.5 | 25.8 | 29.6 | 55.5 |
| Li-ion Battery (4-hr) | 3.3 | 3.7 | 4.4 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.4 | 2.0 | 2.1 | 3.5 | 8.4 | 10.2 | 22.5 |
| Pumped Hydro Storage | - | - | - | 2.0 | 2.0 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 1.0 | 1.0 | 1.2 | 1.3 | 1.3 | 1.3 | 1.3 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (3.7) |
| Total | 7.4 | 10.8 | 15.8 | 23.3 | 33.4 | 41.5 | 44.9 | 45.9 | 49.3 | 66.6 | 72.2 | 107.7 |

Resource Cost Sensitivity: High Land-Based Wind, Solar PV & Battery Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | - | 1.2 | 1.2 | 1.7 | 1.7 | 2.8 | 2.9 | 3.9 | 3.9 | 3.9 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.0 | 0.0 | 0.3 | 0.3 | 8.0 | 11.6 | 12.0 | 12.0 | 12.9 | 12.9 | 12.9 | 15.0 |
| Out-of-State Wind | - | - | 2.4 | 3.9 | 4.8 | 4.8 | 4.8 | 5.4 | 6.4 | 8.9 | 9.6 | 15.7 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 12.9 | 12.9 | 15.0 | 17.0 | 17.0 | 17.0 | 22.9 | 24.5 | 39.8 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 |
| Li-ion Battery (8-hr) | - | - | - | - | - | - | 0.9 | 0.9 | 2.2 | 5.6 | 7.6 | 12.8 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.6 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.9 | 0.9 | 0.9 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (0.8) |
| Total | 7.4 | 10.8 | 17.6 | 26.9 | 35.4 | 42.2 | 46.0 | 47.4 | 50.6 | 63.5 | 67.8 | 95.8 |

Resource Cost Sensitivity: Low Offshore Wind Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.2 | 1.5 | 1.5 | 2.1 | 2.1 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.0 | 0.0 | 0.0 | 0.3 | 10.2 | 12.5 | 12.5 | 12.5 | 13.4 | 13.4 | 13.4 | 13.6 |
| Out-of-State Wind | - | - | 2.5 | 4.0 | 4.3 | 4.3 | 4.3 | 5.5 | 6.5 | 8.7 | 8.7 | 10.2 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | 2.8 | 2.8 | 2.8 |
| Solar | 3.0 | 6.0 | 7.7 | 9.2 | 9.2 | 13.5 | 15.4 | 15.4 | 15.4 | 22.5 | 26.3 | 51.8 |
| Li-ion Battery (4-hr) | 3.3 | 3.7 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.4 | 1.9 | 2.1 | 3.6 | 6.9 | 8.6 | 20.2 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 1.0 | 1.0 | 1.2 | 1.3 | 1.3 | 1.3 | 1.3 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (3.7) |
| Total | 7.4 | 10.7 | 16.2 | 23.4 | 33.6 | 41.7 | 45.1 | 46.2 | 49.7 | 64.8 | 70.2 | 105.2 |

Resource Cost Sensitivity: Low Offshore Wind & High Land-Based Wind, Solar PV, Battery Costs Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | - | 1.2 | 1.2 | 1.7 | 1.7 | 2.9 | 2.9 | 3.4 | 3.9 | 3.9 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.0 | 0.0 | 0.3 | 0.3 | 7.9 | 11.7 | 12.2 | 12.2 | 13.1 | 13.1 | 13.1 | 13.8 |
| Out-of-State Wind | - | - | 2.0 | 3.5 | 4.8 | 4.8 | 4.8 | 5.0 | 6.0 | 8.6 | 8.6 | 16.4 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | 2.8 | 3.8 | 5.5 |
| Solar | 3.0 | 6.0 | 9.0 | 13.0 | 13.0 | 14.7 | 17.1 | 17.1 | 17.1 | 19.8 | 19.9 | 30.9 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.5 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 |
| Li-ion Battery (8-hr) | - | - | - | - | - | - | 0.7 | 0.7 | 2.2 | 5.0 | 5.5 | 7.6 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.5 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.8 | 0.8 | 0.8 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | - |
| Total | 7.4 | 10.8 | 17.4 | 26.8 | 35.5 | 42.1 | 46.2 | 47.3 | 50.7 | 62.0 | 64.2 | 87.6 |

Resource Cost Sensitivity: High Geothermal & Biomass Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | - | 0.9 | 0.9 | 0.9 | 0.9 | 0.9 | 0.9 | 0.9 | 0.9 | 0.9 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.0 | 0.0 | 0.0 | 0.5 | 10.2 | 12.8 | 12.8 | 12.8 | 13.7 | 13.7 | 13.7 | 13.8 |
| Out-of-State Wind | - | - | 2.5 | 4.0 | 5.0 | 5.0 | 5.0 | 7.0 | 8.0 | 10.7 | 10.7 | 12.0 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 7.7 | 9.8 | 9.8 | 16.2 | 18.5 | 18.5 | 18.5 | 28.7 | 31.9 | 58.5 |
| Li-ion Battery (4-hr) | 3.4 | 3.7 | 4.7 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.4 | 2.5 | 3.0 | 4.6 | 9.9 | 11.9 | 23.6 |
| Pumped Hydro Storage | - | - | - | 2.2 | 2.2 | 2.7 | 2.7 | 2.7 | 2.7 | 2.7 | 2.7 | 2.7 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 1.0 | 1.0 | 1.2 | 1.3 | 1.3 | 1.3 | 1.3 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (3.2) |
| Total | 7.4 | 10.7 | 16.1 | 24.2 | 34.9 | 44.8 | 49.1 | 50.7 | 54.1 | 72.1 | 77.3 | 113.9 |

Resource Cost Sensitivity: High Gas Fixed O&M Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.2 | 1.6 | 1.6 | 2.2 | 2.2 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | 0.3 | 9.9 | 11.6 | 11.6 | 11.6 | 12.5 | 12.5 | 12.5 | 12.5 |
| Out-of-State Wind | - | - | 2.5 | 4.0 | 4.3 | 4.3 | 4.3 | 5.5 | 6.5 | 8.8 | 8.8 | 9.7 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 7.4 | 9.1 | 9.1 | 14.3 | 16.2 | 16.2 | 16.2 | 26.7 | 29.7 | 58.6 |
| Li-ion Battery (4-hr) | 3.7 | 4.2 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.3 | 2.0 | 2.0 | 3.6 | 8.5 | 10.5 | 22.4 |
| Pumped Hydro Storage | - | - | - | 2.0 | 2.0 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.6 | 0.6 | 0.9 | 0.9 | 0.9 | 0.9 | 0.9 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | (0.6) | (0.6) | (0.6) | (0.6) | (0.6) | (0.6) | (0.6) | (0.6) | (0.6) | (0.6) | (0.6) | (5.4) |
| Total | 6.8 | 10.2 | 15.2 | 22.7 | 32.8 | 41.1 | 44.7 | 46.0 | 49.5 | 67.1 | 72.0 | 108.8 |

Detailed RESOLVE Results: Demand Sensitivities

Demand Sensitivities: High Electrification

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.3 | 1.5 | 2.0 | 2.0 | 2.0 | 2.9 | 2.9 | 3.4 | 3.4 | 3.4 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.3 | 0.3 | 0.3 | 0.6 | 10.8 | 12.7 | 12.7 | 12.7 | 13.6 | 13.6 | 13.6 | 13.6 |
| Out-of-State Wind | - | - | 1.8 | 3.3 | 4.3 | 4.3 | 4.3 | 6.2 | 7.2 | 10.2 | 10.4 | 14.6 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 12.5 | 13.3 | 22.3 | 25.6 | 25.6 | 25.6 | 36.9 | 41.8 | 67.4 |
| Li-ion Battery (4-hr) | 4.0 | 4.4 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 2.6 | 5.1 | 5.1 | 7.5 | 12.5 | 14.4 | 26.5 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (3.3) |
| Total | 7.7 | 11.0 | 17.2 | 26.3 | 38.9 | 53.0 | 58.7 | 61.1 | 65.5 | 85.1 | 92.1 | 130.6 |

Demand Sensitivities: 2021 ATE

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.8 | 1.8 | 1.8 | 2.4 | 2.4 | 3.2 | 3.2 | 3.8 | 3.8 | 3.8 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.3 | 0.4 | 0.4 | 0.7 | 8.6 | 11.0 | 11.0 | 11.0 | 11.9 | 11.9 | 11.9 | 12.8 |
| Out-of-State Wind | - | - | 2.5 | 4.0 | 4.3 | 4.3 | 4.3 | 5.8 | 6.8 | 9.7 | 9.7 | 15.7 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 11.4 | 11.4 | 17.4 | 20.0 | 20.0 | 20.5 | 43.4 | 52.1 | 71.7 |
| Li-ion Battery (4-hr) | 4.0 | 4.4 | 4.5 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 1.0 | 3.1 | 3.7 | 5.8 | 15.8 | 18.9 | 26.8 |
| Pumped Hydro Storage | - | - | - | 1.8 | 1.8 | 2.4 | 2.4 | 2.4 | 2.4 | 2.4 | 2.4 | 2.4 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | - |
| Total | 7.7 | 11.1 | 17.7 | 25.8 | 34.1 | 44.6 | 49.3 | 51.9 | 56.4 | 92.5 | 104.4 | 138.7 |

Detailed RESOLVE Results: Resource Availability Sensitivities

Resource Availability Sensitivity: Moderate Gas Retirements

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|-----------------------|------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.0 | 1.4 | 2.2 | 2.4 | 2.4 | 3.2 | 3.2 | 3.3 | 3.3 | 3.3 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 7.5 | 8.4 | 8.4 | 8.4 | 9.3 | 9.3 | 9.3 | 13.4 |
| Out-of-State Wind | - | - | 1.5 | 3.0 | 3.9 | 3.9 | 3.9 | 5.0 | 6.0 | 8.5 | 8.5 | 9.7 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 8.3 | 10.4 | 10.4 | 17.3 | 20.2 | 20.5 | 21.8 | 35.8 | 40.9 | 55.2 |
| Li-ion Battery (4-hr) | 4.1 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 |
| Li-ion Battery (8-hr) | - | 0.4 | 0.4 | 0.4 | 0.4 | 2.8 | 4.6 | 5.0 | 6.9 | 12.5 | 14.4 | 20.5 |
| Pumped Hydro Storage | - | - | - | 1.8 | 2.3 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 |
| Long Duration Storage | - | 0.2 | 0.2 | 0.7 | 0.7 | 0.7 | 0.7 | 0.7 | 0.7 | 0.7 | 0.7 | 0.7 |
| Shed DR | 0.3 | 0.3 | 0.3 | 0.5 | 0.5 | 0.5 | 0.5 | 0.2 | 0.2 | - | - | - |
| Retired Gas Capacity | (2.6) | (2.6) | (3.5) | (4.1) | (4.2) | (4.5) | (4.5) | (4.5) | (4.5) | (4.5) | (4.5) | (4.5) |
| Total | 4.8 | 9.9 | 12.8 | 19.7 | 29.2 | 39.9 | 44.5 | 47.0 | 52.1 | 74.1 | 81.0 | 106.7 |

Resource Availability Sensitivity: High Gas Retirement

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|-----------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.1 | 1.8 | 2.4 | 2.4 | 2.4 | 3.5 | 4.4 | 5.0 | 5.0 | 5.0 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 |
| Out-of-State Wind | - | - | 2.4 | 3.9 | 4.1 | 4.1 | 4.1 | 5.4 | 5.4 | 5.4 | 5.4 | 5.4 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 8.1 | 9.3 | 9.8 | 17.6 | 20.0 | 20.0 | 20.0 | 53.3 | 64.2 | 78.2 |
| Li-ion Battery (4-hr) | 3.8 | 4.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 | 5.1 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 2.7 | 5.4 | 5.4 | 6.7 | 18.3 | 22.2 | 28.2 |
| Pumped Hydro Storage | - | - | - | 1.8 | 2.3 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.9 | 0.9 | 0.9 |
| Shed DR | 0.6 | 0.6 | 0.8 | 0.9 | 0.9 | 0.9 | 0.9 | 0.3 | 0.3 | - | - | - |
| Retired Gas Capacity | - | - | - | - | (3.1) | (4.0) | (4.7) | (4.7) | (4.7) | (10.5) | (12.1) | (12.1) |
| Total | 7.4 | 10.7 | 16.5 | 23.2 | 28.9 | 39.0 | 43.4 | 45.2 | 47.4 | 87.2 | 100.4 | 120.4 |

Resource Availability Sensitivity: No Imports for Reliability After 2028

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Geothermal | - | - | - | 1.4 | 2.3 | 2.3 | 2.3 | 3.2 | 3.2 | 3.3 | 3.3 | 3.3 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 7.5 | 8.4 | 8.4 | 8.4 | 9.3 | 9.3 | 9.3 | 13.2 |
| Out-of-State Wind | - | - | 1.9 | 3.4 | 3.9 | 3.9 | 3.9 | 5.0 | 6.0 | 8.5 | 8.5 | 9.7 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 8.5 | 10.3 | 10.3 | 17.6 | 19.3 | 19.7 | 20.6 | 34.3 | 39.3 | 55.0 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.7 | 6.0 | 6.0 | 6.0 | 6.0 | 6.0 | 6.0 | 6.0 | 6.0 | 6.0 |
| Li-ion Battery (8-hr) | - | - | - | - | 0.0 | 2.1 | 3.9 | 4.4 | 6.4 | 11.8 | 13.7 | 20.8 |
| Pumped Hydro Storage | - | - | - | 1.8 | 2.3 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 | 2.8 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | - |
| Total | 7.4 | 10.7 | 16.6 | 23.9 | 33.8 | 44.7 | 48.2 | 50.7 | 55.6 | 77.0 | 84.0 | 111.8 |

Resource Availability Sensitivity: Low BTM PV

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.8 | 1.6 | 1.6 | 2.1 | 2.1 | 2.2 | 2.2 | 2.8 | 2.8 | 2.8 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.3 | 0.4 | 0.4 | 0.7 | 8.8 | 11.4 | 11.7 | 11.7 | 11.7 | 11.7 | 11.7 | 13.2 |
| Out-of-State Wind | - | - | 2.5 | 4.0 | 4.3 | 4.3 | 4.3 | 7.0 | 9.5 | 10.9 | 10.9 | 10.9 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 13.4 | 13.4 | 17.5 | 20.5 | 20.5 | 20.5 | 33.5 | 36.3 | 65.2 |
| Li-ion Battery (4-hr) | 3.3 | 3.7 | 3.7 | 4.1 | 4.1 | 4.1 | 4.1 | 4.1 | 4.1 | 4.1 | 4.1 | 4.1 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.1 | 1.5 | 2.0 | 3.2 | 7.6 | 9.6 | 20.7 |
| Pumped Hydro Storage | - | - | - | 2.0 | 2.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 | 3.0 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 1.0 | 1.0 | 1.2 | 1.2 | 1.2 | 1.2 | 1.2 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (2.8) |
| Total | 7.6 | 11.1 | 17.6 | 27.6 | 36.0 | 44.3 | 49.0 | 51.3 | 55.0 | 74.2 | 78.9 | 117.6 |

Detailed RESOLVE Results: Long Lead Time Sensitivities

LLT Sensitivity: Reduced Resource Availability

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | - | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| Out-of-State Wind | - | - | 1.3 | 2.8 | 4.3 | 4.3 | 4.3 | 4.3 | 5.0 | 5.0 | 5.0 | 5.0 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 10.2 | 18.8 | 24.7 | 28.2 | 31.7 | 32.3 | 49.0 | 54.3 | 84.3 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.9 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 |
| Li-ion Battery (8-hr) | - | - | - | - | 2.4 | 6.5 | 8.4 | 10.1 | 12.1 | 19.2 | 20.7 | 36.5 |
| Pumped Hydro Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.2 | 0.2 | - | - | - |
| Gas Capacity Not Retained | (0.4) | (0.4) | (1.8) | (3.9) | (3.9) | (4.4) | (4.4) | (4.5) | (4.5) | (4.5) | (4.5) | (7.6) |
| Total | 7.0 | 10.3 | 14.9 | 19.6 | 34.1 | 43.6 | 48.9 | 53.8 | 57.1 | 80.7 | 87.5 | 130.1 |

LLT Sensitivity: Significantly Reduced Resource Availability

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.4 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Out-of-State Wind | - | - | - | 1.5 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| Offshore Wind | - | - | - | - | - | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 | 1.5 |
| Solar | 3.0 | 6.0 | 9.0 | 12.8 | 24.0 | 28.1 | 31.6 | 35.2 | 36.8 | 54.0 | 59.8 | 92.7 |
| Li-ion Battery (4-hr) | 4.3 | 4.6 | 6.3 | 7.9 | 7.9 | 7.9 | 7.9 | 7.9 | 7.9 | 7.9 | 7.9 | 7.9 |
| Li-ion Battery (8-hr) | - | - | - | - | 4.7 | 7.5 | 9.3 | 11.1 | 14.0 | 21.1 | 22.5 | 38.8 |
| Pumped Hydro Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.0 | 0.0 | - | - | - |
| Gas Capacity Not Retained | (0.5) | (0.5) | (2.1) | (4.0) | (5.6) | (5.6) | (5.6) | (5.6) | (5.6) | (5.6) | (5.6) | (7.7) |
| Total | 6.9 | 10.2 | 13.7 | 21.2 | 37.0 | 45.3 | 50.7 | 55.9 | 60.4 | 84.7 | 92.0 | 139.0 |

LLT Sensitivity: Low Offshore Wind Costs & Reduced Resource Availability

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | - | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| Out-of-State Wind | - | - | 1.3 | 2.8 | 4.3 | 4.3 | 4.3 | 4.3 | 5.0 | 5.0 | 5.0 | 5.0 |
| Offshore Wind | - | - | - | - | - | 2.8 | 2.8 | 3.2 | 3.2 | 4.4 | 4.4 | 4.4 |
| Solar | 3.0 | 6.0 | 9.0 | 10.2 | 18.6 | 20.7 | 23.4 | 26.4 | 27.5 | 40.7 | 45.7 | 76.1 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.9 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 |
| Li-ion Battery (8-hr) | - | - | - | - | 2.4 | 4.4 | 6.1 | 7.4 | 9.3 | 15.7 | 17.6 | 32.8 |
| Pumped Hydro Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.2 | 0.2 | - | - | - |
| Gas Capacity Not Retained | (0.4) | (0.4) | (1.8) | (3.9) | (3.9) | (3.9) | (3.9) | (4.2) | (4.2) | (4.2) | (4.2) | (7.6) |
| Total | 7.0 | 10.3 | 14.9 | 19.6 | 34.0 | 40.7 | 45.2 | 49.3 | 53.0 | 73.6 | 80.5 | 122.6 |

LLT Sensitivity: Low Offshore Wind Costs & Significantly Reduced Resource Availability

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.3 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 | 1.8 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | - | - | - | - | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Out-of-State Wind | - | - | - | 1.5 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| Offshore Wind | - | - | - | - | - | 2.8 | 3.3 | 4.3 | 4.3 | 5.8 | 5.8 | 5.8 |
| Solar | 3.0 | 6.0 | 9.0 | 12.9 | 23.9 | 26.0 | 28.2 | 31.2 | 32.4 | 46.2 | 51.3 | 83.8 |
| Li-ion Battery (4-hr) | 4.2 | 4.5 | 6.2 | 7.7 | 7.7 | 7.7 | 7.7 | 7.7 | 7.7 | 7.7 | 7.7 | 7.7 |
| Li-ion Battery (8-hr) | - | - | - | - | 4.8 | 6.5 | 8.1 | 8.5 | 11.5 | 17.4 | 19.3 | 34.9 |
| Pumped Hydro Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.2 | 0.2 | 0.3 | 0.3 | 0.3 | 0.3 | 0.3 | 0.1 | 0.1 | - | - | - |
| Gas Capacity Not Retained | (0.5) | (0.5) | (2.0) | (3.9) | (5.4) | (5.4) | (5.4) | (5.4) | (5.4) | (5.4) | (5.4) | (8.0) |
| Total | 6.9 | 10.3 | 13.8 | 21.3 | 37.2 | 43.7 | 48.0 | 52.2 | 56.4 | 77.6 | 84.6 | 130.1 |

LLT Sensitivity: High Land-Based Wind & Transmission Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.8 | 1.6 | 1.6 | 2.1 | 2.1 | 3.0 | 3.0 | 3.5 | 3.5 | 3.5 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.2 | 0.2 | 0.5 | 0.9 | 10.2 | 12.0 | 12.2 | 12.2 | 13.1 | 13.1 | 13.1 | 13.1 |
| Out-of-State Wind | - | - | 0.5 | 3.6 | 4.3 | 4.3 | 4.3 | 5.1 | 6.1 | 7.4 | 7.4 | 7.4 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 7.7 | 9.1 | 9.1 | 14.0 | 16.3 | 16.3 | 16.3 | 27.1 | 31.4 | 59.8 |
| Li-ion Battery (4-hr) | 3.3 | 3.6 | 4.5 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 |
| Li-ion Battery (8-hr) | - | - | - | - | - | 0.2 | 1.7 | 1.9 | 3.4 | 7.7 | 9.5 | 23.8 |
| Pumped Hydro Storage | - | - | - | 2.0 | 2.0 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 1.0 | 1.0 | 1.2 | 1.3 | 1.3 | 1.3 | 1.3 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (4.7) |
| Total | 7.5 | 10.8 | 15.2 | 23.5 | 33.6 | 41.5 | 45.5 | 46.4 | 49.7 | 66.4 | 72.5 | 110.5 |

LLT Sensitivity: High Solar, Battery, Land-Based Wind & Transmission Costs

Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.8 | 1.4 | 1.4 | 2.0 | 2.0 | 3.4 | 4.2 | 5.4 | 5.4 | 5.4 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.0 | 0.0 | 0.3 | 0.3 | 7.9 | 11.7 | 12.7 | 12.7 | 13.6 | 13.6 | 13.6 | 15.0 |
| Out-of-State Wind | - | - | - | 2.8 | 4.3 | 4.3 | 4.3 | 4.3 | 5.1 | 6.3 | 7.1 | 9.7 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | - | - | - |
| Solar | 3.0 | 6.0 | 9.0 | 13.0 | 13.0 | 14.8 | 15.9 | 15.9 | 15.9 | 21.6 | 23.2 | 45.0 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.4 | 5.5 | 5.5 | 5.5 | 5.5 | 5.5 | 5.5 | 5.5 | 5.5 | 5.5 |
| Li-ion Battery (8-hr) | - | - | - | - | - | - | 0.7 | 0.7 | 1.1 | 5.1 | 6.8 | 16.3 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.5 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 | 3.2 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (2.5) |
| Total | 7.4 | 10.8 | 16.1 | 26.3 | 35.3 | 41.8 | 45.3 | 46.4 | 49.3 | 61.0 | 65.3 | 98.0 |

LLT Sensitivity: Low OSW & High Solar, Battery, Land-Based Wind, Transmission Costs Planned & Selected Capacity (GW)

| Resource Category | 2024 | 2025 | 2026 | 2028 | 2030 | 2032 | 2033 | 2034 | 2035 | 2039 | 2040 | 2045 |
|---------------------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Natural Gas | - | - | - | - | - | - | - | - | - | - | - | - |
| Geothermal | - | - | 0.7 | 1.5 | 1.5 | 2.3 | 2.3 | 3.7 | 3.8 | 4.7 | 4.7 | 4.7 |
| Biomass | - | - | - | - | - | - | - | - | - | - | - | - |
| In-State Wind | 0.0 | 0.0 | 0.3 | 0.3 | 8.0 | 11.7 | 12.6 | 12.6 | 13.5 | 13.5 | 13.5 | 13.8 |
| Out-of-State Wind | - | - | - | 2.5 | 4.0 | 4.0 | 4.0 | 4.0 | 5.0 | 6.3 | 7.1 | 9.6 |
| Offshore Wind | - | - | - | - | - | - | - | - | - | 2.8 | 3.8 | 6.9 |
| Solar | 3.0 | 6.0 | 9.0 | 13.1 | 13.1 | 14.4 | 16.1 | 16.1 | 16.1 | 19.2 | 19.3 | 37.6 |
| Li-ion Battery (4-hr) | 4.1 | 4.4 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 | 5.6 |
| Li-ion Battery (8-hr) | - | - | - | - | - | - | 0.4 | 0.4 | 1.6 | 4.6 | 5.4 | 12.7 |
| Pumped Hydro Storage | - | - | - | 2.1 | 2.1 | 2.3 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 | 3.1 |
| Long Duration Storage | - | - | - | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Shed DR | 0.3 | 0.3 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.3 | 0.3 | - | - | - |
| Gas Capacity Not Retained | - | - | - | - | - | - | - | - | - | - | - | (2.9) |
| Total | 7.4 | 10.8 | 16.1 | 26.2 | 35.4 | 41.3 | 45.1 | 46.2 | 49.4 | 60.3 | 63.0 | 91.6 |



Imports and Exports

Background – import/export to CAISO regions

- Imports and exports have been calculated and analysed for all 6 studies (2026, 2030 and 2035 Core and Least Cost cases).
- Lowering the GHG target to 25MMT for the PSP analysis created a different resource portfolio, which led to changes in import and export patterns.
- The following slides show changes in future import/export patterns to CAISO.



Monthly Import/Export for 2030 and 2035 - Core Cases

- Monthly exports in all months exceeds imports for 2030
- The analysis shows in 2030 CAISO will have mostly net exports
- This pattern changes in 2035 where the analysis shows net imports during months of April through June
- Highest imports happen between months of April to June in year 2030



Monthly Import/Export for 2030 and 2035 - Least Cost Cases

- For all Least Cost cases, monthly exports in all months exceed imports
- The analysis shows that in 2030 and 2035 CAISO will have mostly net exports
- Highest imports happen during months of April to June.



Conclusions

- Monthly import/export results for both Core cases and Least Cost cases show an increase in imports during months of April to June compared to other months of the year. This trend can be seen in all study years.
- Most cases show a net export happening during all months of the year, though very small net export GWh during the spring, almost netting to zero in May and June.
- 2035 Core case shows that during months of April to June, net import is occurring, while in other periods interchange is net negative meaning net export is happening.