

## Introduction

In compliance with the California Public Utilities Commission General Order (G.O.) 165, Liberty Utilities (CalPeco Electric) LLC (“Liberty”) submits its annual G.O. 165 Compliance Maintenance Program Report.

The Compliance Maintenance Program at Liberty is administered by the electric operations group. The required inspections are performed by Liberty inspectors in accordance with G.O. 165 requirements, and any necessary follow-up maintenance work to correct deficiencies is completed by line crews.

This report contains the results of Liberty’s inspection, patrol, and maintenance of electric distribution facilities covering the period from January 1, 2021 through December 31, 2021.

## Summary of the 2021 G.O. 165 Report

Type of Inspection	Due	Outstanding
Patrols	662	0
OH Detailed Inspection	0	0
UG Detailed Inspection	59.8	0
Wood Pole Intrusive	3597	0

### Section 1 – Detailed Inspections:

In 2020, Liberty performed detailed circuit inspections of its entire overhead electrical distribution system in accordance with the requirements of G.O. 165. Because of this, only underground detailed inspections were completed in 2021.

#### A. Outstanding Inspections:

None.

### Section 2 – Patrols:

In 2021, Liberty patrolled all its overhead circuits in accordance with the requirements of G.O. 165 for a total of 662 miles.

#### A. Outstanding Patrols:

None.

### Definitions of Units Reported:

Patrol units are defined as line miles of overhead line inspected.

For overhead and underground detailed inspections, the units are line miles. Liberty complies with timelines for overhead and the more stringent underground (where submersible equipment is involved) schedules.

Lastly, wood pole intrusive units are defined as number of poles inspected.