

PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3298



September 13, 2021

EA2021-907

Melvin Stark
Principle Manager, T&D Compliance Integration
Southern California Edison Company
1 Innovation Way
Pomona, CA 91786

Subject: Audit of Southern California Edison's San Jacinto-Meniffee District

Mr. Stark:

On behalf of the Electric Safety and Reliability Branch of the California Public Utilities Commission (CPUC), Calvin Choi and Joceline Pereira of my staff conducted an electric distribution audit of Southern California Edison's (SCE) San Jacinto-Meniffee District from July 12, 2021 to July 16, 2021. The audit included a review of SCE's records and field inspections of SCE's facilities.

During the audit, my staff identified violations of one or more General Orders (GOs). A copy of the audit findings itemizing the violations is enclosed. Please advise me no later than October 13, 2021, by electronic or hard copy, of all corrective measures taken by SCE to remedy and prevent such violations.

If you have any questions concerning this audit, you can contact Calvin Choi at (213) 266-4730 or Calvin.Choi@cpuc.ca.gov.

Sincerely,

A handwritten signature in blue ink that reads "Fadi Daye".

Fadi Daye, P.E.
Program and Project Supervisor
Electric Safety and Reliability Branch
Safety and Enforcement Division
California Public Utilities Commission

Enclosures: Audit Findings

Cc: Lee Palmer, Director, Safety and Enforcement Division, CPUC
Nika Kjensli, Program Manager, ESRB, SED, CPUC
Calvin Choi, Utilities Engineer, ESRB, SED, CPUC

AUDIT FINDINGS

I. Records Review

During the audit, my staff reviewed the following records:

- Overhead and underground detailed inspections records.
- Completed and pending corrective action work orders.
- Safety hazard notifications.
- Pole loading calculations records.
- Intrusive testing records.
- Vegetation management records.
- SCE's documented inspection program.

II. Records Review – Violations List

My staff observed the following violations during the records review portion of the audit:

GO 95, Rule 31.2, Inspection of Lines, states in part:

Lines shall be inspected frequently and thoroughly for the purpose of ensuring that they are in good condition so as to conform with these rules. Lines temporarily out of service shall be inspected and maintained in such condition as not to create a hazard.

GO 165, Standard III-B, Distribution Facilities, Standards for Inspections, states in part:

Each utility subject to this General Order shall conduct inspections of its distribution facilities, as necessary, to ensure reliable, high-quality, and safe operation, but in no case may the period between inspections (measured in years) exceed the time specified in [Table 1](#).

SCE's records indicated that from 2016 to 2020, SCE failed to complete 4,686 overhead detailed inspections by SCE's inspection dates.

GO 128, Rule 17.2, Inspection, states in part:

Systems shall be inspected by the operator frequently and thoroughly for the purpose of insuring that they are in good condition and in conformance so as to conform with these rules.

GO 165, Standard III-B, Distribution Facilities, Standards for Inspections, states in part:

Each utility subject to this General Order shall conduct inspections of its distribution facilities, as necessary, to ensure reliable, high-quality, and safe operation, but in no case may the period between inspections (measured in years) exceed the time specified in [Table 1](#).

SCE's records indicated that from 2016 to 2020, SCE failed to complete 915 underground detailed inspections by SCE's inspection dates.

GO 95, Rule 18, Rule 18-B1, Maintenance Programs, states in part:

Companies shall undertake corrective actions within the time periods stated for each of the priority levels set forth below. Scheduling of corrective actions within the time periods below may be based on additional factors, including the following factors, as appropriate ...

GO 95, Rule 31.1, Design, Construction and Maintenance, states in part:

For all particulars not specified in these rules, design, construction, and maintenance should be done in accordance with accepted good practice for the given local conditions known at the time by those responsible for the design, construction, or maintenance of communication or supply lines and equipment.

SCE's records indicated that from 2016 to 2021, SCE completed 1,375 work orders past their due date for corrective action.

GO 128, Rule 17.1, Design, Construction and Maintenance, states in part:

Electrical supply and communication systems shall be designed, constructed, and maintained for their intended use, regard being given to the conditions under which they are to be operated, to enable the furnishing of safe, proper, and adequate service.

SCE's records indicated that from 2016 to 2021, SCE completed 352 underground notifications past SCE's scheduled due date for corrective action.

III. Field Inspections

My staff inspected the following facilities during the field inspection:

| No. | Structure ID | Type of Structure | Location |
|-----|--------------|-------------------|------------|
| 1 | 4293939E | Pole | Winchester |
| 2 | 4294403E | Pole | Winchester |
| 3 | 4294404E | Pole | Winchester |
| 4 | 4294405E | Pole | Winchester |
| 5 | 4294406E | Pole | Winchester |
| 6 | 4294407E | Pole | Winchester |
| 7 | 4294408E | Pole | Winchester |
| 8 | 4294409E | Pole | Winchester |
| 9 | 4294410E | Pole | Winchester |
| 10 | 4294411E | Pole | Winchester |
| 11 | 4294412E | Pole | Winchester |
| 12 | 220750S | Pole | Hemet |
| 13 | 4149991E | Pole | Hemet |
| 14 | 220614E | Pole | Hemet |
| 15 | 20699S | Pole | Hemet |
| 16 | 20700S | Pole | Hemet |
| 17 | 4491843E | Pole | Hemet |
| 18 | 20702S | Pole | Hemet |
| 19 | 220613S | Pole | Hemet |
| 20 | 220612S | Pole | Hemet |
| 21 | 4439389E | Pole | Hemet |
| 22 | 4828352E | Pole | Hemet |
| 23 | 4828253E | Pole | Hemet |
| 24 | 4866709E | Pole | Idyllwild |
| 25 | 4540790E | Pole | Idyllwild |
| 26 | 4866708E | Pole | Idyllwild |
| 27 | 4866707E | Pole | Idyllwild |
| 28 | 4866706E | Pole | Idyllwild |
| 29 | 1775708E | Pole | Idyllwild |
| 30 | 4002911E | Pole | Idyllwild |
| 31 | 2033683E | Pole | Idyllwild |
| 32 | 4002910E | Pole | Idyllwild |
| 33 | 4005203E | Pole | Idyllwild |
| 34 | 4005204E | Pole | Idyllwild |
| 35 | 4655114E | Pole | Idyllwild |
| 36 | 1588232E | Pole | Idyllwild |
| 37 | 4569495E | Pole | Idyllwild |
| 38 | 4569455E | Pole | Idyllwild |
| 39 | 4841274E | Pole | Idyllwild |
| 40 | 2672590E | Pole | Idyllwild |

| | | | |
|----|-----------|------|---------------|
| 41 | 2248319E | Pole | Idyllwild |
| 42 | 4607517E | Pole | Idyllwild |
| 43 | 1588229E | Pole | Idyllwild |
| 44 | 4164817E | Pole | Idyllwild |
| 45 | 4164818E | Pole | Idyllwild |
| 46 | 4164819E | Pole | Idyllwild |
| 47 | 4908906E | Pole | Idyllwild |
| 48 | 4855337E | Pole | Idyllwild |
| 49 | 4855334E | Pole | Idyllwild |
| 50 | 42072589E | Pole | Idyllwild |
| 51 | 4720942E | Pole | Mead Valley |
| 52 | 4513700E | Pole | Mead Valley |
| 53 | 4831604E | Pole | Mead Valley |
| 54 | 236956E | Pole | Mead Valley |
| 55 | 316827S | Pole | Mead Valley |
| 56 | 250153GT | Pole | Mead Valley |
| 57 | 316826S | Pole | Mead Valley |
| 58 | 28109CWT | Pole | Mead Valley |
| 59 | 2150289E | Pole | Mead Valley |
| 60 | 2150290E | Pole | Mead Valley |
| 61 | 4060741E | Pole | Mead Valley |
| 62 | 4060742E | Pole | Mead Valley |
| 63 | 2150291E | Pole | Mead Valley |
| 64 | 2150292E | Pole | Mead Valley |
| 65 | 2277427E | Pole | Mead Valley |
| 66 | 2277426E | Pole | Mead Valley |
| 67 | 2270500E | Pole | Mead Valley |
| 68 | 1623610E | Pole | Moreno Valley |
| 69 | 74334S | Pole | Moreno Valley |
| 70 | 4442017E | Pole | Moreno Valley |
| 71 | 4366801E | Pole | Moreno Valley |
| 72 | 74331S | Pole | Moreno Valley |
| 73 | 311580S | Pole | Moreno Valley |
| 74 | 1964178E | Pole | Moreno Valley |
| 75 | 2013964E | Pole | Moreno Valley |
| 76 | 1964172E | Pole | Moreno Valley |
| 77 | 4591007E | Pole | Moreno Valley |
| 78 | 1964164E | Pole | Moreno Valley |
| 79 | 4799641E | Pole | Woodcrest |
| 80 | 4709162E | Pole | Woodcrest |
| 81 | 2270431E | Pole | Woodcrest |
| 82 | 4709161E | Pole | Woodcrest |
| 83 | 4827735E | Pole | Woodcrest |
| 84 | 4944055E | Pole | Woodcrest |
| 85 | 4473085E | Pole | Woodcrest |

| | | | |
|-----|----------|------|---------------|
| 86 | 2150717E | Pole | Woodcrest |
| 87 | 105564H | Pole | Woodcrest |
| 88 | 209694S | Pole | Lake Matthews |
| 89 | 209695S | Pole | Lake Matthews |
| 90 | 1971421E | Pole | Lake Matthews |
| 91 | 4058827E | Pole | Lake Matthews |
| 92 | 209697S | Pole | Lake Matthews |
| 93 | 4720197E | Pole | Lake Matthews |
| 94 | 215897S | Pole | Perris |
| 95 | 215896S | Pole | Perris |
| 96 | 1964535E | Pole | Perris |
| 97 | 1964534E | Pole | Perris |
| 98 | 1964533E | Pole | Perris |
| 99 | 16717E | Pole | Perris |
| 100 | 4726458E | Pole | Perris |
| 101 | 2307074E | Pole | Perris |
| 102 | 2307075E | Pole | Perris |
| 103 | 4819427E | Pole | Perris |
| 104 | 4819426E | Pole | Perris |
| 105 | 2309844E | Pole | Perris |
| 106 | GT4345 | Pole | Perris |
| 107 | 4781304E | Pole | Perris |
| 108 | 4781303E | Pole | Perris |
| 109 | 4781305E | Pole | Perris |
| 110 | 2173580E | Pole | Perris |
| 111 | 2362044E | Pole | Nuevo |
| 112 | 2362043E | Pole | Nuevo |
| 113 | 2362042E | Pole | Nuevo |
| 114 | 2362041E | Pole | Nuevo |
| 115 | 2362040E | Pole | Nuevo |
| 116 | 3000772E | Pole | Nuevo |
| 117 | 4857816E | Pole | Nuevo |
| 118 | 4857819E | Pole | Nuevo |
| 119 | 77095S | Pole | Nuevo |
| 120 | 4162747E | Pole | San Jacinto |
| 121 | 4162746E | Pole | San Jacinto |
| 122 | 4054685E | Pole | San Jacinto |
| 123 | 4162745E | Pole | San Jacinto |
| 124 | 4162744E | Pole | San Jacinto |
| 125 | 4162743E | Pole | San Jacinto |
| 126 | 4054682E | Pole | San Jacinto |
| 127 | 4054681E | Pole | San Jacinto |
| 128 | 4162742E | Pole | San Jacinto |
| 129 | 4162741E | Pole | San Jacinto |
| 130 | 1990975E | Pole | Homeland |

| | | | |
|-----|----------|-------------------------|---------------|
| 131 | GT104368 | Pole | Homeland |
| 132 | 1990976E | Pole | Homeland |
| 133 | GT104369 | Pole | Homeland |
| 134 | 1990977E | Pole | Homeland |
| 135 | 2547781E | Pole | Homeland |
| 136 | 4507481E | Pole | Homeland |
| 137 | GT104370 | Pole | Homeland |
| 138 | 1990979E | Pole | Homeland |
| 139 | 5301933 | BURD Transformer | Moreno Valley |
| 140 | 5301934 | BURD Transformer | Moreno Valley |
| 141 | 5311965 | Vault | Moreno Valley |
| 142 | 5320920 | BURD Transformer | Moreno Valley |
| 143 | 5311967 | BURD Switch | Moreno Valley |
| 144 | 5419366 | Pad-mounted Transformer | Moreno Valley |
| 145 | P5550696 | Pad-mounted Transformer | Moreno Valley |
| 146 | P5550695 | Splice Box | Moreno Valley |
| 147 | 5388466 | Pad-mounted Transformer | Moreno Valley |
| 148 | P5653915 | Pad-mounted Transformer | Perris |
| 149 | 5653916 | Splice Box | Perris |
| 150 | 5653918 | Pad-mounted Transformer | Perris |
| 151 | P5653962 | Pad-mounted Transformer | Perris |
| 152 | V5629013 | Vault | Perris |
| 153 | P5629022 | Pad-mounted Transformer | Perris |
| 154 | P5629620 | Pad-mounted Switch | Perris |
| 155 | P5626822 | Pad-mounted Switch | Perris |

IV. Field Inspection - Violations List

My staff observed the following violations during the field inspections portion of the audit:

GO 95, Rule 51.6-A, Marking and Guarding, High Voltage Marking of Poles, states in part:

Poles which support line conductors of more than 750 volts shall be marked with high voltage signs. This marking shall consist of a single sign showing the words "HIGH VOLTAGE", or pair of signs showing the words "HIGH" and "VOLTAGE", not more than six (6) inches in height with letters not less than 3 inches in height. A pair of signs may be stacked to a height of no more than 12 inches. Such signs shall be of weather and corrosion-resisting material, solid or with letters cut out therefrom and clearly legible.

The high voltage signs attached to each of the following SCE poles were damaged and/or missing:

- 4294406E
- 4294407E
- 220614E
- 20699S
- 20700S
- 220613S
- 220612S
- 2150291E
- 2150292E
- 4366801E
- 311580S
- 4473085E
- 2150717E
- 105564H
- 2309844E
- 2362043E
- 4162746E
- 4162742E
- 1990975E

GO 95, Rule 56.2, Uses (Guy Wires), states in part:

Guys shall be attached to structures, as nearly as practicable, at the center of load. They shall be maintained taut and of such strength as to meet the safety factors of Rule 44.

SCE down guy wire attached to pole No. 4857816E was not taut.

GO 95, Rule 84.6-B, Ground Wires, states in part:

Ground wires, other than lightning protection wires not attached to equipment or ground wires on grounded structures, shall be covered by metal pipe or suitable covering of wood or metal, or of plastic conduit material as specified in Rule 22.8-A, for a distance above ground sufficient to protect against mechanical injury, but in no case shall such distance be less than 7 feet.

The ground moulding attached to each of the following poles was damaged and/or missing:

- 4491843E
- 220613S
- 220612S
- 4569495E
- 316826S
- 2150289E

- 1623610E
- 2150717E
- 2309844E
- 2362040E
- 1990979E

GO 95, Rule 31.1, Design Construction and Maintenance, states in part:

Electrical supply and communication systems shall be designed, constructed, and maintained for their intended use, regard being given to the conditions under which they are to be operated, to enable the furnishing of safe, proper, and adequate service.

The “eye” of the down guy anchor attached to each of the following poles was buried:

- 4866708E
- 316827S

GO 95, Rule 34 Foreign Attachments, states in part:

Nothing in these rules shall be construed as permitting the unauthorized attachment, to supply, street light or communication poles or structures, of antennas, signs, posters, banners, decorations, wires, lighting fixtures, guys, ropes and any other such equipment foreign to the purposes of overhead electric line construction.

An unauthorized fence was attached to Pole No. 1964534E and 1964533E.

GO 128, Rule 17.1, Design Construction and Maintenance, states in part:

Electrical supply and communication systems shall be designed, constructed, and maintained for their intended use, regard being given to the conditions under which they are to be operated, to enable the furnishing of safe, proper, and adequate service.

- Vault 5311965 was missing a ladder to safely enter the vault.
- Padmounted transformer 5388466 had a small oil leak and an area of significant rust on the enclosure.