



Laura Genao
Managing Director,
State Regulatory Affairs
Laura.Genao@sce.com

November 26, 2019

Leslie Palmer, Director
Safety and Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102

**Re: Amended PSPS Post Event Report Regarding Pro-Active De-Energization Event
October 21 to October 26, 2019**

Dear Director Palmer:

Southern California Edison (SCE) respectfully submits the attached amended report in compliance with PSPS Post Event Reporting requirements regarding its pro-active de-energization event that began October 21, 2019. The amended report has been updated to reflect corrected re-energization dates and customer and circuit information for those circuits in Appendix E. Additionally, minor edits were made on pages 7, 8, and question 8 of "Response to Decision (D.) 19-05-042 Requirements" (p. 16) to reflect this updated information. This amended report has been verified by an Officer of SCE in accordance with Rule 1.11 of the Commission's Rules of Practice and Procedure. In order to assure that clerical errors do not occur in the future, de-energization information will be manually validated line by line to ensure accuracy.

Sincerely,

A handwritten signature in cursive script that reads "Laura Genao / by KB".

Laura Genao
Managing Director
SCE State Regulatory Affairs

cc: Danjel Bout, Safety and Enforcement Division
Anthony Noll, Safety and Enforcement Division
ESRB_CompilanceFilings@cpuc.ca.gov

**Southern California Edison
Public Safety Power Shutoff Protocol (PSPS)
Amended Post-Event Reporting in Compliance with Resolution
ESRB-8 and Decision 19-05-042
October 21 to October 26, 2019**

**Submitted to:
California Public Utilities Commission
Director of the Safety and Enforcement Division
November 26, 2019**

Executive Summary

On October 21, 2019, Southern California Edison (SCE) concluded operations associated with the October 12 to October 21, 2019 Public Safety Power Shutoff (PSPS) event and notified public safety partners and local government agencies regarding an additional incoming weather system forecasting high winds and low relative humidity levels expected to create the potential for use of SCE's PSPS protocol beginning at 3:00 a.m. on Thursday, October 24. During the event, customers in the following eleven counties were identified as under consideration for PSPS activation: Fresno, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, Santa Barbara, Tulare, and Ventura.

The PSPS notification team completed notifications to emergency management agencies (city/county/state), local government agencies, and potentially affected customers in areas under consideration for PSPS. A total of 46 circuits and 31,386 customers were de-energized across portions of Kern, Los Angeles, Orange, Riverside, San Bernardino, and Ventura counties during this PSPS event. Specifically, 39 circuits and 30,521 customers were pro-actively de-energized due to PSPS, and seven circuits and 865 customers were interrupted or de-energized unrelated to PSPS. The latter remained de-energized due to weather conditions or fire activity in the area.

In the separate sections that follow, SCE, in compliance with the directives of Resolution ESRB-8 and Decision (D.) 19-05-042, provides its post-event report regarding the PSPS activation that took place between October 21, 2019 and October 26, 2019.

SCE appreciates that de-energization poses significant challenges and hardships for our customers and our public safety partners who provide vital services to the communities across the State and is committed to continuously improving our processes. We welcome input from our public safety partners on how we can work together to improve communications, enhance current processes, and minimize the impact of de-energization on them and the services they provide.

SCE's Decision to Notify and De-Energize Customers

SCE's decision to notify and de-energize customers using the Public Safety Power Shutoff (PSPS) protocol was made after all the following factors were considered:

- National Weather Service (NWS) Red Flag Warnings for counties that contain SCE circuits in high fire risk areas;
- Ongoing assessments from SCE's in-house meteorologists informed about high resolution weather models and strategically deployed weather stations (e.g. wind speeds, humidity, and temperature);
- The SCE Fire Potential Index (FPI) rating, an internal tool that utilizes both modeled weather and fuel conditions;
- Real-time situational awareness information obtained from field observers positioned locally in high fire risk areas identified as at risk for extreme fire weather conditions;
- Specific concerns from local and state fire authorities, emergency management personnel, and law enforcement regarding public safety issues;
- Expected impact of de-energizing circuits on essential services such as public safety agencies, water pumps, traffic controls, etc.; and
- Other operational considerations to minimize potential wildfire ignitions including current known state of individual circuit conditions.

SCE believes that no other measures were available as reasonable alternatives for maintaining public safety. SCE took the following actions to manage the response:

- Initiating operating restrictions on impacted circuits in affected counties;¹
- Activation of an Incident Management Team (IMT) for directing response operations associated with potential de-energization;
- Notifications to Public Safety Partners, local government officials (city and county), state executives, critical infrastructure providers, and potentially affected customers;
- Patrolling of affected circuits, including pre-patrols and post-patrols; and
- Field observations of affected circuits during the Period of Concern.²

Additional details leading to the decision to provide notifications and proactively de-energize can also be found in the event narrative below.

¹Specific operating restrictions SCE may employ during a Public Safety Power Shutoff can be found in the 2019 SCE Wildfire Mitigation Plan approved by the CPUC on May 30, 2019.

²Period of Concern is the time period circuits on the monitored circuit list are subject to potential implementation of the Public Safety Power Shutoff as determined by SCE. Live field observations may be performed during this timeframe.

Event Summary October 21, 2019 to October 26, 2019

On Monday, October 21, 2019, SCE’s Situational Awareness Center notified the PSPS Incident Management Team (IMT) and the Business Resiliency Duty Manager of forecasts indicating local winds with high gusts, hot temperatures, and very dry conditions resulting in an Elevated Fire Weather Threat (EFWT) beginning on Thursday, October 24, 2019 at 3:00 a.m. in Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, and Ventura counties. The PSPS IMT concluded operations associated with the previous October 12 to October 21, 2019 PSPS event at 10:30 a.m. and notified public safety partners and local government agencies regarding the additional incoming weather system beginning at 3:00 a.m. on Thursday, October 24, because forecasted high winds and low relative humidity levels were again expected to create the potential for SCE’s PSPS protocol. No customer notifications were made on October 21 related to the incoming weather system because no circuits were expected to meet criteria (wind speeds and FPI meeting or exceeding established thresholds) for consideration of PSPS within the next two days. Operating restrictions, however, remained in place for portions of Inyo, Kern, Los Angeles, Mono, Riverside, San Bernardino, and Santa Barbara, and Ventura counties.

On Monday, October 21, the NWS issued multiple Advisories, Watches, and Warnings, with high winds and low relative humidity levels expected to persist through Friday, October 25. Winds were winds between 15 and 35 mph with gusts of 60 mph were expected, with relative humidity levels forecast to range between two and nine percent. These conditions resulted in 78 circuits identified for monitoring for potential use of PSPS with 108,079 potentially affected customers (including 466 critical care customers) identified in Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties. The initial identified period of concern for these circuits was between 3:00 a.m. on Thursday, October 24 and 6:00 p.m. on Friday, October 25.

Type	Location	Start Date	Start Time	End Date	End Time
Wind Advisory	Santa Barbara Co.	10/21/19	3:00 a.m.	10/21/19	9:00 a.m.
Wind Advisory	Los Angeles Co. Ventura Co.	10/22/19	12:00 a.m.	10/22/19	12:00 p.m.
Fire Weather Watch	Los Angeles Co. Orange Co. Ventura Co.	10/24/19	3:00 a.m.	10/25/19	10:00 p.m.

By the end of Monday, October 21, SCE had provided updated notifications to Public Safety Partners and local government agencies in the affected jurisdictions.³ No customer notifications were made on October 21 related to the incoming weather system because no circuits were expected to meet criteria (wind speeds and FPI meeting or exceeding established thresholds) for consideration of PSPS within the next two days. Appendix A contains the Period of Concern reports for each day of the event and visually represents when each circuit was expected to meet PSPS criteria.

³ Comprehensive notification reports for Public Safety Partners and local government agencies are maintained in the Everbridge Notification system and dates of initial contact are listed in Appendix D.

On Tuesday, October 22, updated forecast analysis continued to indicate moderate fire weather with high winds and low relative humidity levels expected to persist through Friday, October 25, including winds between 30-50 mph with gusts of up to 60 mph. The NWS issued multiple Advisories, Watches, and Warnings, which are summarized in the table below:

Type	Location	Start Date	Start Time	End Date	End Time
Heat Advisory	Orange Co.	10/22/19	10:00 a.m.	10/22/19	5:00 p.m.
Heat Advisory	Los Angeles Co. Ventura Co.	10/22/19	10:00 a.m.	10/22/19	5:00 p.m.
Fire Weather Watch	Kern Co. Tulare Co.	10/24/19	5:00 a.m.	10/25/19	10:00 p.m.
High Wind Watch	Los Angeles Co. Ventura Co.	10/24/19	1:00 a.m.	10/25/19	12:00 p.m.
Red Flag Warning	Orange Co. Riverside Co. San Bernardino Co.	10/24/19	5:00 a.m.	10/25/19	5:00 p.m.
Red Flag Warning	Los Angeles Co. Ventura Co.	10/24/19	1:00 a.m.	10/25/19	10:00 p.m.

By the end of the day Tuesday, October 22, 133,318 potentially affected customers (including 578 critical care customers) on 135 circuits across portions of Kern, Los Angeles, Orange, Riverside, San Bernardino, and Ventura counties had been notified that they were under consideration for PSPS with a Period of Concern from 12:00 a.m. on Thursday, October 24 through 6:00 p.m. on Friday, October 25. Operating restrictions remained in place for portions of Inyo, Kern, Los Angeles, Mono, Riverside, San Bernardino, Santa Barbara, Tulare and Ventura counties. SCE notified Public Safety Partners, local government agencies, state executives, and potentially affected customers in Kern, Los Angeles, Orange, Riverside, San Bernardino, and Ventura counties that beginning on Thursday, October 24, SCE could activate its PSPS protocols and begin de-energization.

On Wednesday, October 23, updated forecasts indicated temperatures in the 90s, humidity levels between two to nine percent, and peak wind gusts between 45 and 65 mph were expected throughout SCE territory beginning Thursday, October 24. The NWS issued additional Advisories, Watches, and Warnings (summarized in the table below), which cited the potential for rapid spread of wildfire and extreme fire behavior that would lead to a threat to life and property if an ignition were to occur.

Type	Location	Start Date	Start Time	End Date	End Time
Heat Advisory	Los Angeles Co. Ventura Co. Santa Barbara Co.	10/24/19	10:00 a.m.	10/25/19	5:00 p.m.
Wind Advisory	Los Angeles Co. Ventura Co.	10/24/19	5:00 a.m.	10/25/19	3:00 p.m.
High Wind Warning	Los Angeles Co. Orange Co. San Bernardino Co.	10/24/19	1:00 a.m.	10/25/19	12:00 p.m.
Red Flag Warning	Riverside Co. San Bernardino Co.	10/24/19	9:00 a.m.	10/25/19	8:00 p.m.
Red Flag Warning	Kern Co. Tulare Co.	10/24/19	5:00 a.m.	10/25/19	10:00 p.m.

By 9:00 a.m. on Wednesday, October 23, there were 191 circuits and 308,046 potentially affected customers (including 1,181 critical care) across portions of Kern, Los Angeles, Orange, Riverside, San Bernardino, and Ventura counties under consideration for PSPS with a Period of Concern from 12:00 a.m. on Thursday, October 24 to 12:00 a.m. on Saturday, October 26.

SCE personnel closely monitored real-time weather data and given the FPI and wind speeds of over 40 mph recorded on a weather station near the area of the Castro Circuit in Ventura County, which created a potential public safety concern, the PSPS IMT Incident Commander (IC) initiated de-energization protocol. At 11:47 p.m., the Castro Circuit and McKeveitt Circuit, were pro-actively de-energized affecting 2,669 customers in Ventura County. SCE provided all required notifications to Public Safety Partners, local government agencies, state executives, and affected customers regarding the de-energization of the Castro and McKeveitt Circuits.

On Thursday, October 24, real-time weather data indicated wind speeds approaching and breaching thresholds in a portion of Kern County, and between 2:41 a.m. and 2:43 a.m., five circuits⁴ were pro-actively de-energized affecting 5,286 customers.

Between 5:33 a.m. and 5:38 a.m. on Thursday, October 24, three circuits in San Bernardino County, affecting 116 customers, were de-energized due to fire activity in the area. After conditions improved and appropriate patrols were conducted, all 116 customers were restored by 5:20 p.m. on Friday, October 25.

Pro-active de-energizations continued throughout the early morning hours, and as of 9:00 a.m. on Thursday, October 24, 19 circuits and 18,912 customers across Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties had been pro-actively de-energized for PSPS. Updated

⁴ A summary of de-energization information, including affected customer counts and re-energization times, is included in Appendix E of this report.

forecast analysis continued to indicate high winds, low relative humidity levels and high temperatures, and NWS Advisories, Watches, and Warnings remained in place for portions of Kern, Los Angeles, Orange, Riverside, San Bernardino, Tulare, and Ventura counties. Operating restrictions were initiated for Orange County and remained in place for portions of Inyo, Kern, Los Angeles, Mono, Riverside, San Bernardino, Santa Barbara, Tulare and Ventura counties. A total of 18 additional circuits were pro-actively de-energized between 9:00 a.m. and 9:15 p.m. on Thursday, October 24.

An Electrical Services Incident Management Team (ESIMT) was activated alongside PSPS IMT and reported to the EOC at 6:00 a.m. on Thursday, October 24. The primary objectives for the ESIMT were to expedite post-patrol operations, coordinate damage assessment and repair processes, and manage restoration of power.

On Thursday, October 24, SCE received a request from the San Bernardino County Fire Department for re-energization of the Calstate and Club Oaks Circuits in San Bernardino County that morning, to power additional water pumps to assist firefighting efforts. The circuits were de-energized at the request of the local fire agency at 5:33 a.m. SCE, working with field crews, meteorologists, and the SCE Incident Commander, determined that public safety concerns still existed due to sustained winds around 43 mph, wind gusts up to 58 mph, and high fire potential index in the area. Based on these real-time observations, it was determined that re-energization of the Calstate and Club Oaks Circuits posed a public safety risk, and the circuits were left de-energized. While SCE was not able to accommodate this request due to weather conditions in the area, SCE continued to coordinate closely with the county. An SCE Fire Management Officer was on scene with the San Bernardino County Fire Department personnel and maintained direct communication about their concerns with water services and water pumping facilities being offline in areas adjacent to the fire used for firefighting operations. SCE's Fire Management Officer confirmed that alternate water sources were available at the time of the request, which fire personnel utilized for their firefighting efforts. SCE remained in direct contact with firefighting authorities throughout the fire to respond quickly to any additional emergent needs.

SCE's Liaison Officer and Business Resiliency Duty Manager worked with Kern, Los Angeles, San Bernardino, and Ventura County emergency management officials to identify locations and mobilize four Community Crew Vehicles (CCVs) to serve their communities beginning on Thursday, October 24. The Kern County CCV was deployed to the Stallion Springs Community Center (27800 Stallion Springs Dr, Tehachapi, CA 93561) from 9:00 a.m. to 5:00 p.m. Thursday, October 24 and 9:00 a.m. to 4:00 p.m. on Friday, October 25. The Los Angeles County CCV was deployed to the Acton Agua Dulce County Library (33792 Crown Valley Rd, Acton, CA 93510) from 9:00 a.m. to 5:00 p.m. Thursday, October 24 and 9:00 a.m. to 4:00 p.m. on Friday, October 25. The San Bernardino County CCV was deployed to the North End University Area Ecclesia Christian Fellowship (1314 E Date, San Bernardino, CA 92404) from 9:00 a.m. to 5:00 p.m.

Thursday, October 24 and 9:00 a.m. to 4:00 p.m. on Friday, October 25. The Ventura County CCV was deployed to The Rancho Santa Susanna Community Resource Center (5005 East Los Angeles Ave, Simi Valley, CA, 93063) from 9:00 a.m. to 5:00 p.m. Thursday, October 24 and 9:00 a.m. to 4:00 p.m. on Friday, October 25. The CCVs were equipped with mobile charging capabilities so customers could charge personal mobile devices and continue to receive updates about the outage. The CCV was also stocked with water and snacks to help mitigate the impact to customers. SCE subject matter experts were onsite throughout the duration of the event to provide information and answer questions.

Seven circuits experienced interruptions unrelated to PSPS with 865 affected customers. Two circuits were interrupted due to equipment failure (one each in Ventura and Los Angeles counties), one circuit was interrupted due to a car striking a pole in Orange County, and four circuits were de-energized due to fire activity in the area in San Bernardino County. Several circuits were previously under consideration for PSPS and required patrols before re-energization. A summary of de-energization activity through Thursday, October 24 is below:

Total number of circuits pro-actively de-energized	37
Total number of circuits interrupted due to reasons other than PSPS and left de-energized	7
Total number of customers de-energized	30,263
Number of counties with de-energized circuits	6

Based on improved conditions and updated forecasting, re-energization protocols, including post-patrols, were initiated for five circuits in portions of Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties beginning around 1:00 p.m. on Thursday, October 24. All 2,439 customers previously de-energized on those circuits were re-energized by 10:40 p.m. By the end of the day, there were 40 de-energized circuits and 28,532 affected customers. SCE provided all required notifications to Public Safety Partners, local government agencies, state executives, and affected customers regarding the de-energization of circuits on Thursday, October 24.

On Friday, October 25, Red Flag Warnings, Heat Advisories, High Wind Warnings, and Wind Advisories remained in effect for portions of Kern, Los Angeles, Orange, Riverside, San Bernardino, Tulare, and Ventura counties, and were expected to expire at 10:00 p.m. The NWS issued a Fire Weather Watch for portions of Los Angeles, Orange, San Bernardino, and Ventura counties from 2:00 p.m. on Sunday, October 27 to 6:00 p.m. on Monday, October 28. Wind gusts between 15 and 25 mph were expected with relative humidity levels as low as two percent. Based on updated forecast analysis on the morning of Friday, October 25, 140 circuits and 132,679 potentially affected customers (including 548 critical care) across Fresno, Inyo, Kern, Los Angeles, Mono, Riverside, San Bernardino, Santa Barbara, and Ventura counties were under consideration for PSP, and the Period of Concern was extended through Monday,

October 28. Operating restrictions were initiated for Fresno County, and remained in place for portions of Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, Santa Barbara, Tulare and Ventura counties.

The PSPS IMT continued closely monitoring weather models and making real-time weather observations throughout the day to determine if there was a need to initiate de-energization protocols. Based on real-time weather observations, the IC initiated de-energization protocol on a portion of the DeMille Circuit in Los Angeles County, and at 5:28 p.m., a section of the circuit was de-energized affecting 249 customers. SCE provided updated notifications to Public Safety Partners, local government agencies, state executives, and potentially affected customers.

Based on improved conditions and updated forecasting, re-energization protocols were initiated on 35 circuits in Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties throughout the day Friday, October 25, and crews performed post-patrols on de-energized circuits before re-energization to ensure safe operating conditions. SCE completed repairs before safely restoring power, and re-energized 35 circuits in Kern, Los Angeles, Riverside, San Bernardino, and Ventura counties on Friday, October 25. Customers were re-energized throughout the day with 6,168 customers restored by 12:00 p.m., 13,316 additional customers restored by 3:00 p.m., and another 2,676 customers restored by 9:00 p.m. A summary of all wind-related damage from this PSPS event found during the post-patrol process is below:

Circuit	Damage
Maciel	Broken pole
Petit	Failed transformer
Davenport	Crooked pole
Python	Wire slapped together
Python	Tarp in line
Vegetation Related Findings	
Python	Tree on communication line

By the end of the day Friday, October 25, portions of five circuits and 235 customers remained de-energized due to fire activity or damaged infrastructure associated with fire activity in the area. Public Safety Partners, local government agencies, state executives, and affected customers were provided updated notifications when the circuits were re-energized.

On Saturday, October 26, SCE meteorologists forecasted a brief break in the weather, with the next elevated fire weather forecasted to begin Sunday, October 27. Operating restrictions were initiated for Fresno County, and remained in place for portions of Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, Santa Barbara, Tulare and Ventura counties. The

NWS issued multiple Advisories, Watches, and Warnings for Sunday, October 27, which are summarized in the table below:

Type	Location	Start Date	Start Time	End Date	End Time
Red Flag Warning	Fresno Co.	10/27/19	12:00 p.m.	10/28/19	2:00 a.m.
Red Flag Warning	Kern Co. Los Angeles Co. Ventura Co.	10/27/19	8:00 a.m.	10/28/19	6:00 p.m.
Fire Weather Watch	Kern Co.	10/27/19	8:00 a.m.	10/28/19	6:00 p.m.
High Wind Watch	Orange Co. Riverside Co. San Bernardino Co.	10/27/19	10:00 p.m.	10/28/19	12:00 p.m.
Wind Advisory	Fresno Co. Kern Co. Tulare Co.	10/27/19	7:00 a.m.	10/27/19	12:00 p.m.
Wind Advisory	Riverside Co. San Bernardino Co.	10/26/19	11:00 p.m.	10/27/19	6:00 p.m.

The PSPS IMT continued to monitor real-time weather data Saturday, October 26, and after observing winds approaching thresholds, a portion of the Shovel Circuit in Los Angeles County was pro-actively de-energized at 4:54 p.m., affecting 9 customers.

Five circuits and 244 customers remained de-energized by the end of Saturday, October 26. The PSPS IMT concluded the PSPS event that began on October 21 for reporting purposes and began a new PSPS event on October 27. SCE provided updated notifications to emergency and public safety partners, critical infrastructure providers and potentially affected customers, including notification to all parties that were under consideration for PSPS beginning Sunday, October 27. Restoration efforts on the remaining de-energized customers was transferred to the incoming PSPS IMT, which continued operations at the EOC on Sunday, October 27, and all circuit's de-energized during this event were restored by 7:02 p.m. on Monday, October 28. The details of the PSPS event that began on Sunday, October 27 will be detailed in a subsequent Post-Event Report.

Response to ESRB-8 Requirements

The following material addresses Resolution ESRB-8 requirements in each category associated with notifications. Each category is addressed in a separate section.

1. The local communities' representatives contacted prior to de-energization, the date on which they were contacted, and whether the areas affected by the de-energization are classified as Zone 1, Tier 2, or Tier 3 as per the definition in General Order 95, Rule 21.2-D⁵

SCE maintained ongoing communications with both unincorporated and incorporated communities affected throughout the duration of the weather event ending October 26, 2019, including the local community representatives. Appendix B, "Public Safety Partners," includes samples of notifications sent to local community representatives during this event. The notifications were sent via SCE's mass notification system to a comprehensive list of community contacts within each county and PDF maps and electronic mapping files for affected areas were available at www.sce.com/maps. While SCE also provides the CalOES Public Safety Power Shutoff Notification Form to the State Warning Center as conditions changed, there were delays in submittal due to formatting requirements of the form, the number of circuits in scope for the event and training of new EOC staff. Initial contact to public safety partners and critical infrastructure providers is included in Appendix D.

Media Communications

SCE's public information officers issued 11 messaging documents providing public updates during the activation. These updates are used by all customer-facing company sources including customer service, corporate communications, government, agency representatives, and postings on various social media sources. Communications posted to the SCE website are provided in five additional languages. SCE provided customers and the public with information on the potential PSPS via regular updates on sce.com (specifically <https://www.sce.com/safety/wildfire/pmps>) and via posts on the public-facing online publication, Energized by Edison.

Through SCE's social media channels, including Facebook, Twitter, and Instagram, customers were given safety tips and guidelines for managing PSPS events. During this incident we saw about 2,776 items in our inbound social media queue related to PSPS. This included people sharing news articles, comments, and retweets with comments. Less than ten percent of those warranted a response because most of the time, people were just sharing an article headline, making a rhetorical comment, or engaging in discussions with one another. The social media team is equipped to respond to customer inquiries in Spanish, but there were very few Spanish-language comments about this event.

⁵ Notification reports for Public Safety Partners and local government agencies are maintained in the Everbridge Notification system.

On our outbound channels (Facebook, Instagram and Twitter), PSPS paid-promoted ads in English and Spanish were launched letting customers know how to prepare for emergencies and Public Safety Power Shutoffs, and shared updates on where to find the latest PSPS information. On Facebook, we shared information on preparation, where to find the latest PSPS updates and locations of our Community Crew Vehicles and Resource Centers, with 15 updates (both paid and organic). On Instagram, we posted two updates focused on preparedness and signing up for outage alerts prompting customers to visit the link in our bio to learn more. On Twitter, we shared 28 outbound tweets during this event (paid and organic), including where to find the latest PSPS information, how to sign up for alerts, outage/emergency preparedness tips, safety tips and information about our Community Crew Vehicles (CCVs).

Since early May, SCE has placed radio and digital ads educating customers about PSPS in Spanish, Chinese, Korean, Vietnamese and Tagalog. These ads educate customers about what a PSPS is, what factors cause us to shut off power, how to prepare and urge customers to sign up for outage alerts. The corresponding pages on sce.com (e.g., PSPS, preparedness) are also translated in all these languages.

SCE PIOs also responded to over 132 media requests from television, radio and print media from myriad local news outlets and requests from national news outlets like KNX, KTLA, CBS, NBC, ABC, Univision, Associated Press, Bloomberg News, the New York Times and the L.A. Times.

2. If unable to provide customers with notice at least 2 hours prior to the de-energization event, provide an explanation in its report.

There were no circuits pro-actively de-energized during this event on which customers did not receive at least 2 hours' notice . Eight circuits (Fresno-1, Los Angeles-2, San Bernardino-5) did not receive notification that they were under consideration for PSPS. The updated weather forecast resulted in adding the circuits to the monitoring list without time to provide notifications before the 48-hour window for notifications had elapsed.

3. Summarize the number and nature of complaints received as the result of the de-energization event and include claims that are filed due to de-energization.

As of November 1, SCE received 12 complaints/concerns lodged with Consumer Affairs related to the PSPS event that took place October 21-26, 2019:

Complaint Subject	Number
General Inquiries	4
Inaccuracy of SCE.com Website	1
Complaint of drones in the area	1
Concern about maintenance	1
Looking for an ETA on power restoration	3
Calling for end to PSPS and release of detailed plan related to PSPS	1
Stated they are not receiving advanced notice before PSPS event	1

- One with General Inquiries asking for a call back
- One with General Inquiry worried about medical patient in the home;
- One with General Inquiry having problems signing up for PSPS notifications;
- One with General Inquiry asking why their neighbor two blocks away was with power and they were not;
- Three looking for an ETA for power restoration;
- One regarding the inaccuracy of the SCE.com website
- One complaining of the drones
- One concern about maintenance. If SCE had kept maintenance up, would PSPS be necessary;
- One demanding an end to PSPS and the release of detailed plans related to PSPS (received from local government)
- One stating they are not receiving advanced notice of a PSPS event (received from a water company)

As of the submission date of this report, 40 claims have been processed due to de-energization during this event, and many more claims are still going through the intake process. Of the 40 claims processed for this event, all are for food loss and/or generator reimbursement. The breakdown by city is outlined below:

- Simi Valley – 6 claims
- Tehachapi – 4 claims
- Camarillo – 4 claims
- Canyon Country – 13 claims
- Chatsworth – 1 claim
- Fontana – 6 claims
- San Bernardino – 6 claims

Any complaints or claims received after submission of this report will be added to subsequent reports, as they are received and processed.

4. Provide a detailed description of the steps taken to restore power.

Once the elevated fire conditions (high winds and low relative humidity levels) subsided and were not expected to escalate for the next 48 hours, SCE immediately initiated post-patrols on de-energized circuits. As part of the re-energization protocol, circuits were patrolled end-to-end to identify hazards or damage, and confirm it is safe to re-energize. For circuits in areas inaccessible by foot, SCE utilized helicopters to perform these post-patrols. Once

the post-patrols were completed, any damage was repaired, and the circuits were deemed clear of hazards, the circuits were individually re-energized. This protocol is standard for each individual circuit as part of the re-energization process.

5. Identify the address of each community assistance location during a de-energization event, describe the location (in a building, a trailer, etc.), and describe the assistance available at each location, and give the days and hours that it was open.

Community Assistance Locations				
Type	County	Dates/Times	Address	Services
CCV	Kern	10/24 – 9:00 a.m. to 5:00 p.m. 10/25 – 9:00 a.m. to 4:00 p.m.	Stallion Springs Community Center 27800 Stallion Springs Dr, Tehachapi, CA 93561	Water, snacks, device chargers, PSPS information
CCV	Los Angeles	10/24 – 9:00 a.m. to 5:00 p.m. 10/25 – 9:00 a.m. to 4:00 p.m.	Acton Agua Dulce County Library 33792 Crown Valley Rd, Acton, CA 93510	Water, snacks, device chargers, PSPS information
CCV	San Bernardino	10/24 – 9:00 a.m. to 5:00 p.m. 10/25 – 9:00 a.m. to 4:00 p.m.	North End University Area Ecclesia Christian Fellowship 1314 E Date San Bernardino, CA 92404	Water, snacks, device chargers, PSPS information
CCV	Ventura	10/24 – 9:00 a.m. to 5:00 p.m. 10/25 – 9:00 a.m. to 4:00 p.m.	Berylwood Park Center, 1955 Bridget Ave Simi Valley, CA	Water, snacks, device chargers, PSPS information

6. Provide a description of wind-related damage(s) to SCE’s overhead equipment in the areas where circuits were pro-actively de-energized.

Circuit	Damage
Maciel	Broken pole
Petit	Failed transformer
Davenport	Crooked pole
Python	Wire slapped together
Python	Tarp in line
Vegetation Related Findings	
Python	Tree on communication line

Response to Decision (D.) 19-05-042 Requirements

1. Decision criteria leading to de-energization.

SCE meteorologists forecasted FPI and wind speed conditions to exceed PSPS criteria on Wednesday, October 23, with both gusty winds and low relative humidity. Winds speeds were forecasted to reach up to 50 mph, and SCE's FPI for multiple circuits were forecasted to exceed thresholds. The NWS Red Flag Warnings, Fire Weather Watches, High Wind Warnings and Wind Advisories across nine counties, and real-time weather station data provided SCE personnel with specific information about conditions surrounding the circuits in areas under consideration for PSPS. Once the forecasted weather conditions and real-time weather station data indicated that a risk to public safety existed, SCE's PSPS IMT IC initiated de-energization protocols for the affected circuits. A total of 46 circuits and 31,386 customers were affected during this event: 39 circuits and 30,521 customers were pro-actively de-energized due to PSPS, and seven circuits and 865 customers were interrupted or de-energized unrelated to PSPS but remained de-energized due to weather or fire activity in the area.

2. A copy of all notifications, the timing of notifications, the methods of notifications and who made the notifications (the utility or local public safety partners).

A sample of all notifications, the timing of notifications and the methods of notifications can be found in Appendix C, "Customer Notifications" of this report. SCE was the primary provider of customer notifications. The respective counties shared the primary messaging executed by SCE with public safety partners for situational awareness.

3. An explanation of the circumstances that resulted in failure to communicate a potential pro-active de-energization event, if any.

There were no circuits pro-actively de-energized during this event on which customers did not receive at least 2 hours' notice . Eight circuits (Fresno-1, Los Angeles-2, San Bernardino-5) did not receive notification that they were under consideration for PSPS. The updated weather forecast resulted in adding the circuits to the monitoring list without time to provide notifications before the 48-hour window for notifications had elapsed.

4. A description and evaluation of engagement with local and state public safety partners in providing advanced education and outreach during the de-energization event.

Advanced notification of this Public Safety Power Shutoff event was communicated to all affected counties, CalOES, and the CPUC approximately 72 hours before any forecasted weather was scheduled to impact the SCE service territory. Regular updates were provided

throughout the event using the CalOES PSPS Notification Form, daily situational awareness and coordination calls and individual contact with Public Safety Partners in the affected jurisdictions. SCE appreciates that de-energization poses challenges for our customers and our public safety partners who provide vital services to the communities across the State, and are committed to continuously improving our processes and welcome input from our public safety partners on how we can work together to improve communications, enhance current processes, and minimize the impact of de-energization on them and the services they provide. SCE will continue to collaborate with our state and local public safety partners to streamline the notification process and minimize delays in sharing information.

- 5. For those customers where positive or affirmative notification was attempted, an accounting of the customers (which tariff and/or access and functional needs population designation), the number of notification attempts made, the timing of attempts, who made the notification attempt (utility or public safety partner) and the number of customers for whom positive notification was achieved.**

Customer notification details are documented in Appendix C, "Customer Notifications," and a summary of the notifications is outlined below:

Total Customer Notifications Sent Throughout Event	1,235,219
Total Critical Care Customer Notifications Sent Throughout Event	4,762
Total Medical Baseline Customer Notifications Sent Throughout Event	22,693

A total of 127 critical care customer notifications initially came back as undelivered. In 42 of those instances, SCE succeeded in subsequent notification attempts. Field Service Representatives (FSRs) were dispatched to perform door knocks for the remaining 85 critical care customers with undelivered notifications and were able to successfully contact all 85.

- 6. A description of how sectionalization, i.e., separating loads within a circuit, was considered and implemented and the extent to which it impacted the size and scope of the de-energization event.**

All circuits were in HFRAs and were forecasted to meet or exceed established thresholds. Sectionalizing was considered for all circuits that met the criteria for pro-active de-energization. When the areas of concern included the entire circuit span, the entire circuit was de-energized, which was the case for 24 circuits. In 22 cases, only a portion of the circuit was de-energized to isolate the area of concern and minimize the impact to customers.

7. An explanation of how the utility determined that the benefit of de-energization outweighed potential public safety risks.

Both SCE meteorologists and NWS forecasted Extreme Fire Weather and Santa Ana Wind conditions for portions of Fresno, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, Santa Barbara, Tulare, and Ventura Counties areas. The NWS Red Flag Warnings issued during this event included language that identified the risk for rapid spread of wildfire and extreme fire behavior that would lead to a threat to life and property if an ignition occurred.

SCE coordinated closely with local fire authorities and emergency management personnel to identify any potential public safety risks associated with de-energization, and none were noted. Based on the extreme fire risk, SCE determined that the benefit of de-energization outweighed potential public safety risks associated with pro-active de-energization. SCE continuously monitored weather forecast models and real-time weather data to quickly identify changes in conditions, including sustained wind speeds, wind gusts, and FPI. SCE evaluated requests for re-energization as we received them, and in one case, found re-energization would not be possible for the Calstate and Club Oaks Circuits in San Bernardino due to high wind conditions in the area.

8. The timeline for power restoration (re-energization), in addition to the steps taken to restore power as required in Resolution ESRB-8.

Once the elevated fire conditions (high winds and low relative humidity levels) subsided and were not expected to escalate for the next 48 hours, SCE immediately initiated re-energization protocols on de-energized circuits. As part of the re-energization protocol, circuits were patrolled end-to-end (post-patrols) to identify hazards or damage, and confirm it was safe to re-energize the circuits. For circuits in areas inaccessible by ground, SCE utilized helicopters to perform these post-patrols. Once the post-patrols were completed, any damage was repaired, and the circuits were deemed to be clear of hazards, the circuits were individually re-energized. This protocol is standard for each individual circuit as part of the re-energization process. By the end of the day Saturday, October 26, 244 customers on five circuits remained without power, and all were restored by 7:02 p.m. on Monday, October 28. As mentioned, 46 circuits were de-energized during this PSPS event. The following is a breakdown of re-energizations by day:

Date	Number of Circuits Re-Energized
Thursday, October 24	8
Friday, October 25	32
Saturday, October 26	1
Sunday, October 27	3
Monday, October 28	2

9. Lessons learned from the de-energization events

During this PSPS de-energization event, SCE received a request from the San Bernardino County Fire Department for re-energization of the Calstate and Club Oaks Circuits in San Bernardino County, which were de-energized at 5:33 a.m. that morning due to fire activity in the area to power additional water pumps to assist firefighting efforts. SCE, working with field crews, meteorologists, and the Incident Commander, determined that public safety concerns still existed due to sustained winds around 43 mph, wind gusts up to 58 mph, and high fire potential index in the area. Based on these real-time observations, it was determined that re-energization of the Calstate and Club Oaks Circuits posed a public safety risk, and the circuits were left de-energized. While SCE was not able to accommodate this request due to weather conditions in the area, SCE continued to coordinate closely with the county. An SCE Fire Management Officer was on scene with the San Bernardino County Fire Department personnel and maintained direct communication about their concerns with water services and water pumping facilities being offline in areas adjacent to the fire used for firefighting operations. SCE's Fire Management Officer confirmed that alternate water sources were available at the time of the request, which fire personnel utilized for their firefighting efforts. SCE remained in direct contact with firefighting authorities throughout the fire to respond quickly to any additional emergent needs. Situations such as the one described above reinforce the necessity for SCE to continue coordination efforts with Public Safety Partners ahead of a PSPS event, and it highlights the need for SCE to engage the telecommunications and water agency providers through groups like the California Utilities Emergency Management Association to identify critical infrastructure locations and incorporate those locations into the SCE REST Service⁶ that is accessed by our Public Safety Partners.

10. Any recommended updates to the guidelines adopted in Resolution ESRB-8 and Decision (D.) 19-05-042

No recommended updates to the guidelines have been identified from this event.

⁶ Representational State Transfer (REST) is a web-based tool that provides either open or password-protected access to information stored in an ArcGIS Online system. The SCE REST is password protected, allowing only pre-enrolled users access to PSPS-related maps and GIS layers, as well as sensitive, critical information relating to Public Safety Power Shutoff (PSPS) events in our service territory.

Appendix A

Period of Concern

Amended SCE PSPS Post Event Report
October 21 to October 26, 2019

				Period of Concern Report 10/22/2019 08:15														
				Tuesday			Wednesday			Thursday			Friday			Saturday		
				10/22/19 6:00	10/22/19 9:00	10/22/19 12:00	10/23/19 6:00	10/23/19 9:00	10/23/19 12:00	10/24/19 6:00	10/24/19 9:00	10/24/19 12:00	10/25/19 6:00	10/25/19 9:00	10/25/19 12:00	10/26/19 6:00	10/26/19 9:00	10/26/19 12:00
Circuit	Switching Center	Substation	County	10/22/19 6:00	10/22/19 9:00	10/22/19 12:00	10/23/19 6:00	10/23/19 9:00	10/23/19 12:00	10/24/19 6:00	10/24/19 9:00	10/24/19 12:00	10/25/19 6:00	10/25/19 9:00	10/25/19 12:00	10/26/19 6:00	10/26/19 9:00	10/26/19 12:00
ACOSTA	VISTA	RANDALL	San Bernardino															
AMETHYST	VISTA	ARCHLINE	San Bernardino															
ANGUS	VENTURA	FILLMORE	Ventura															
ANTON	VENTURA	MOORPARK	Ventura															
ATENTO	ANGE COL	VIEJO	Orange;Riverside															
AVANTI	VISTA	SHANDIN	San Bernardino															
BADGER	VISTA	SHANDIN	San Bernardino															
BALCOM	VENTURA	FILLMORE	Ventura															
BARRINGTON	VENTURA	FILLMORE	Ventura															
BAZOOKA	VALLEY	BUNKER	Riverside															
BENCH	VISTA	YUCAIPA	Riverside;San Bernardino															
BLUE CUT	VISTA	BLUE CUT P. T.	San Bernardino															
BONANZA	RECTOR	KERNVILLE	Kern															
BONNEVILLE	VALLEY	LAKEVIEW	Riverside															
BOOTLEGGGER	VINCENT	ACTON	Los Angeles															
BOUQUET	VINCENT	SOLEMINT	Los Angeles															
CALIENTE	VINCENT	CUMMINGS	Kern															
CALSTATE	VISTA	SHANDIN	San Bernardino															
CANEBRAKE	RECTOR	WELDON	Kern															
CARMELITA	VISTA	SHANDIN	San Bernardino															
CASMALIA	VISTA	ALDER	San Bernardino															
CASTRO	VENTURA	WAKEFIELD	Ventura															
CHAWA	VALLEY	PECHANGA	Riverside;San Diego															
CITY OF BANNING #	DEVERS	BANNING	Riverside															
CLARINET	VINCENT	ELIZABETH LAKE	Los Angeles															
CLUB OAKS	VISTA	CARDIFF	San Bernardino															
COACHELLA	DEVERS	GARNET	Riverside;San Bernardino															
CONDOR	VINCENT	BANDUCCI	Kern															
CUDDEBACK	VINCENT	CUMMINGS	Kern															
DAVENPORT	VINCENT	SOLEMINT	Los Angeles															
DINELY	VINCENT	CORRECTION	Kern															
DYSART	DEVERS	DYSART P. T.	Riverside															
EASTER	VALLEY	NELSON	Riverside															
ECHO	VISTA	DEL ROSA	San Bernardino															
ENCHANTED	VENTURA	ROYAL	Ventura															
ENERGY	VENTURA	CHATSWORTH	Los Angeles;Ventura															
ESTABAN	VENTURA	SOMIS	Ventura															
FAYE	RECTOR	WELDON	Kern															
FINGAL	DEVERS	CABAZON	Riverside															
FROZEN	VINCENT	TEJON (PG&E)	Kern															
GABBERT	VENTURA	MOORPARK	Ventura															
GILMAN	VALLEY	RIDGEVIEW P. T.	Riverside															
GRAPEVINE PEAK	VINCENT	GRAPEVINE PEAK P.	Kern															
GREAT SALT	VALLEY	LAKEVIEW	Riverside															
GUNSITE	DEVERS	GUNSITE P. T.	Riverside;San Bernardino															
GUST	VINCENT	NORTHWIND	Kern															
HARRIER	VALLEY	BUNKER	Riverside															
HELICOPTER	VALLEY	BUNKER	Riverside															
HERD	VALLEY	BUNKER	Riverside															
HUCKLEBERRY	VINCENT	RITTER RANCH	Los Angeles															
HUGHES LAKE	VINCENT	DEL SUR	Los Angeles															
JARVIS	MESA	DALTON	Los Angeles															
KINSEY	VINCENT	GORMAN	Los Angeles															

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

				Period of Concern Report 10/23/2019 17:30													
Circuit	Switching Center	Substation	County	Wednesday		Thursday		Friday		Saturday		Sunday		Monday			
				10/23/19 9:00	10/23/19 12:00	10/23/19 9:00	10/23/19 12:00	10/23/19 9:00	10/23/19 12:00	10/23/19 9:00	10/23/19 12:00	10/23/19 9:00	10/23/19 12:00	10/23/19 9:00	10/23/19 12:00		
ABACUS	VISTA	HIGHLAND	San Bernardino														
ACCENT	VALLEY	MORENO	Riverside														
ACOSTA	VISTA	RANDALL	San Bernardino														
AMETHYST	VISTA	ARCHLINE	San Bernardino														
ANGUS	VENTURA	FILLMORE	Ventura														
ANTON	VENTURA	MOORPARK	Ventura														
ARABIA	ORANGE COUNT	MODENA	Orange														
ARLENE	VINCENT	SOLEMINT	Los Angeles														
ATENTO	ORANGE COUNT	VIEJO	Orange;Riverside														
ATLANTA	ORANGE COUNT	LAS LOMAS	Orange														
ATMORE	VENTURA	WAKEFIELD	Ventura														
AVANTI	VISTA	SHANDIN	San Bernardino														
BADGER	VISTA	SHANDIN	San Bernardino														
BALCOM	VENTURA	FILLMORE	Ventura														
BARRINGTON	VENTURA	FILLMORE	Ventura														
BASIL	VALLEY	MORENO	Riverside														
BIANCO	MIRA LOMA	PADUA	San Bernardino														
BIG ROCK	VENTURA	CHATSWORTH	Los Angeles;Ventura														
BING	VISTA	MARASCHINO	Riverside														
BLUE CUT	VISTA	BLUE CUT P. T.	San Bernardino														
BONNEVILLE	VALLEY	LAKEVIEW	Riverside														
BOOTLEGGER	VINCENT	ACTON	Los Angeles														
BOUQUET	VINCENT	SOLEMINT	Los Angeles														
BRENNAN	VENTURA	MOORPARK	Ventura														
BROADCAST	MESA	GOULD	Los Angeles														
BUCKHORN	VENTURA	FILLMORE	Ventura														
BUFFER	VENTURA	CHATSWORTH	Los Angeles;Ventura														
BUTTERFIELD	MIRA LOMA	SOQUEL	Riverside;San Bernardino														
CADWAY	VENTURA	WAKEFIELD	Ventura														
CAESAR	VINCENT	HASKELL	Los Angeles														
CALGROVE	VINCENT	NEWHALL	Los Angeles														
CALSTATE	VISTA	SHANDIN	San Bernardino														
CAMP	RECTOR	KERN RIVER 1	Kern														
CANAL	VALLEY	NELSON	Riverside														
CANET	VENTURA	CASITAS	Ventura														
CARMELITA	VISTA	SHANDIN	San Bernardino														
CASMALIA	VISTA	ALDER	San Bernardino														
CASSIDY	VENTURA	SANTA SUSANA	Ventura														
CASTRO	VENTURA	WAKEFIELD	Ventura														
CHARIOT	VINCENT	HASKELL	Los Angeles														
CHAWA	VALLEY	PECHANCA	Riverside;San Diego														
CHOLLA	DEVERS	MESCALERO P.T.	San Bernardino														
CITY OF BANNING #	DEVERS	BANNING	Riverside														
CLUB OAKS	VISTA	CARDIFF	San Bernardino														
COACHELLA	DEVERS	GARNET	Riverside;San Bernardino														
COLLINS	VENTURA	MOORPARK	Ventura														
CONDOR	VINCENT	BANDUCCI	Kern														
COOLER	ORANGE COUNT	CHIGUITA	Orange														
CORSAIR	VALLEY	STETSON	Riverside														
CRAM	VISTA	HIGHLAND	San Bernardino														
CRESCENTA	MESA	GOULD	Los Angeles														
CUDEBACK	VINCENT	CUMMINGS	Kern														
DARTMOUTH	VALLEY	MAYBERRY	Riverside														
DAVENPORT	VINCENT	SOLEMINT	Los Angeles														
DE MILLE	VINCENT	KAGLE CANYON P. T.	Los Angeles														
DIAMONDBACK	VINCENT	NORTH OAKS	Los Angeles														
DILL	VALLEY	MORENO	Riverside														
DINELY	VINCENT	CORRECTION	Kern														
DOBLE	LUGO	COTTONWOOD	San Bernardino														
DONLON	VENTURA	SOMIS	Ventura														
DREYER	ORANGE COUNT	BRYAN	Orange														
DUKE	VISTA	MARASCHINO	Riverside														
DYSART	DEVERS	DYSART P.T.	Riverside														
EASTER	VALLEY	NELSON	Riverside														
ECHO	VISTA	DEL ROSA	San Bernardino														
ENCHANTED	VENTURA	ROYAL	Ventura														
ENERGY	VENTURA	CHATSWORTH	Los Angeles;Ventura														
ESCONDIDO	VINCENT	ESCONDIDO P.T.	Los Angeles														
ESTABAN	VENTURA	SOMIS	Ventura														
EVERETT	VENTURA	MOORPARK	Ventura														
EVITA	VENTURA	CAMARILLO	Ventura														
FERRARA	MIRA LOMA	PADUA	Los Angeles;San Bernardino														
FINCAL	DEVERS	CABAZON	Riverside														
FLAKE	VALLEY	MAXWELL	Riverside														
FLYING D	RECTOR	HAVILAH	Kern														
FROZEN	VINCENT	TEJON (PSAE)	Kern														

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

Customer Name	County	Address	City	Service Area	21	22	23	24	25	26
GABBERT	VENTURA	MOORPARK	Ventura				1	1		
GALAHAD	VENTURA	LATIGO	Los Angeles; Ventura					1	1	1
GILLIBRAND	VENTURA	SANTA SUSANA	Ventura					1		
GILMAN	VALLEY	RIDGEVIEW P. T.	Riverside				1	1		
GNATCATCHER	VINCENT	BANDUCCI	Kern							1
GRANDAD	VENTURA	CASITAS	Ventura							1
GRAPEVINE PEAK	VINCENT	GRAPEVINE PEAK P.	Kern							1
GREAT SALT	VALLEY	LAKEVIEW	Riverside				1			
GREEN RIVER	ORANGE COUNT	CANYON	Orange							1
GUJAR	VINCENT	ELIZABETH LAKE	Los Angeles; Ventura				1	1		
GUNSITE	DEVERS	GUNSITE P. T.	Riverside; San Bernardino				1	1		
HANDY	ORANGE COUNT	VILLA PARK	Orange				1	1		1
HARRIER	VALLEY	BUNKER	Riverside							1
HERO	VALLEY	BUNKER	Riverside							1
HOVATTER	VISTA	DEL ROSA	San Bernardino							1
HUCKLEBERRY	VINCENT	RITTER RANCH	Los Angeles				1	1		1
HUGHES LAKE	VINCENT	DEL SUR	Los Angeles				1	1		
IDA	VISTA	MARASCHINO	Riverside							1
IRAN	ORANGE COUNT	MODENA	Orange				1	1		1
IRVINE PARK	ORANGE COUNT	IRVINE PARK P. T.	Orange				1	1		1
JARVIS	MESA	DALTON	Los Angeles				1	1	1	1
JORDAN	RECTOR	GLENNVILLE	Kern; Tulare							1
JULIUS	VINCENT	HASKELL	Los Angeles							1
KINSEY	VINCENT	GORMAN	Los Angeles							1
KIRBY	VALLEY	NELSON	Riverside					1	1	
KOREA	ORANGE COUNT	MODENA	Orange				1	1		
KUEHNER	VENTURA	SANTA SUSANA	Ventura							1
LA GRANDE	VISTA	ARCHLINE	San Bernardino				1	1	1	1
LAUDA	VALLEY	NELSON	Riverside							1
LOCKNER	VALLEY	NELSON	Riverside				1	1	1	1
LOPEZ	VINCENT	SAN FERNANDO	Los Angeles				1	1	1	1
LOUCKS	VINCENT	LOUCKS P. T.	Los Angeles				1	1	1	1
LYONS	VINCENT	NEWHALL	Los Angeles				1	1	1	1
MALLOY	VENTURA	SATICCY	Ventura							1
MAMBA	VINCENT	NORTH OAKS	Los Angeles				1	1		1
MARCUS	VINCENT	HASKELL	Los Angeles				1	1		
MCKEVETT	VENTURA	MCKEVETT P. T.	Ventura				1	1		
MEBANE	RECTOR	MEBANE P. T.	Kern							1
METTLER	VINCENT	CUMMINGS	Kern				1	1	1	1
MIDDLE ROAD	VENTURA	SATICCY	Ventura				1	1		
MODJESKA	ORANGE COUNT	ONEILL	Orange							1
MONARCH	VENTURA	ROYAL	Ventura							1
MORA	VISTA	RANDALL	San Bernardino				1	1	1	1
MORGANSTEIN	VENTURA	MOORPARK	Ventura				1	1	1	1
MORONCO	DEVERS	MORONCO P. T.	San Bernardino							1
MUNICH	ORANGE COUNT	LAS LOMAS	Orange				1	1		
NAPOLCON	VISTA	MARASCHINO	Riverside							1
NEARCATE	VINCENT	NEWHALL	Los Angeles				1	1		
NEPAL	ORANGE COUNT	MODENA	Orange				1	1		1
NERO	VINCENT	HASKELL	Los Angeles							1
NORTH PARK	VISTA	SHANDIN	San Bernardino				1	1	1	1
OLIVER	VALLEY	ALESSANDRO	Riverside							1
ONBORD	MIRA LOMA	JEFFERSON	Orange; Riverside; San Bernardino							1
OSLO	ORANGE COUNT	LAS LOMAS	Orange							1
PEARCE	VENTURA	PIERPONT	Ventura				1	1		1
PENSTOCK	LUGO	AQUEDUCT	San Bernardino							1
PETIT	VENTURA	WAKEFIELD	Ventura				1	1		
PICK	VINCENT	ACTON	Los Angeles				1	1		
PICKENS	MESA	LA CANADA	Los Angeles				1	1		
POPPET FLATS	DEVERS	CABAZON	Riverside							1
PRONGHORN	VINCENT	DEL SUR	Los Angeles				1	1		
PURCHASE	DEVERS	OUTLET P. T.	Riverside							1
PYLE	VENTURA	WAKEFIELD	Ventura				1	1		1
PYTHON	VINCENT	NORTH OAKS	Los Angeles				1	1		

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

Customer Name	City	County	Service Area	10/21	10/22	10/23	10/24	10/25	10/26	10/27	10/28	10/29	10/30	10/31
RACER	VINCENT	NORTH OAKS	Los Angeles											1
RAINBOW	VENTURA	SOMIS	Ventura			1	1	1						
RAMAC	VENTURA	ESTERO	Ventura			1								
RANKIN	RECTOR	WALKER BASIN	Kern										1	1
READY	VENTURA	SAN MIGUEL	Ventura											1
RED BOX	MESA	RED BOX P.T.	Los Angeles					1	1	1	1			
RED MOUNTAIN	VENTURA	CASITAS	Ventura			1								
REJADA	VENTURA	ROYAL	Ventura			1	1							
RESORT	VALLEY	NELSON	Riverside			1	1	1	2	2	1			
RICARDO	VENTURA	SAN MIGUEL	Ventura											1
RIVA	VENTURA	CASITAS	Ventura			1								
ROCKWELL	VISTA	TENNESSEE	San Bernardino			1	1						1	1
ROSA	VENTURA	CAMARILLO	Ventura			1								
RUSTIC	ORANGE COUNT	ONEILL	Orange				1							
SADDLEBACK	DEVERS	BANNING	Riverside					1	1	1				
SAN NICHOLAS	VENTURA	CASITAS	Ventura			1							1	1
SAND CANYON	VINCENT	SOLEMINT	Los Angeles			1	1	1				1	1	
SANTORINI	MIRA LOMA	PADUA	San Bernardino			1	1	1						
SAUNDERS	VALLEY	IDYLLWILD	Riverside			1				1	1			
SAVORY	VALLEY	NELSON	Riverside				1							
SAWPIT	VISTA	APPOWHEAD	San Bernardino			1	1	1						
SCHMIDT	VISTA	MARASCHINO	Riverside					1						
SEAFORTH	LUGO	HESPERIA	San Bernardino											1
SESPE	VENTURA	SESPE P.T.	Ventura			1								1
SEXTON	VENTURA	SATICOY	Ventura			1								
SHOWEL	VINCENT	ACTON	Los Angeles			1	1	1	1	1	1	1	1	1
SIAM	ORANGE COUNT	MODENA	Orange			1	1							
SKY HI	LUGO	LUCERNE	San Bernardino			1								1
SPICE	VALLEY	MORENO	Riverside											1
STEARNS	VENTURA	SANTA SUSANA	Ventura					1						
STEEL	VALLEY	PIGEONVIEW P.T.	Riverside			1	1							
STORES	DEVERS	OUTLET P.T.	Riverside					1	1					
STRATHERN	VENTURA	MOORPARK	Ventura			1								
STUBBY	DEVERS	BANNING	Riverside			1	1			1				
SUTT	VISTA	DEL ROSA	San Bernardino			1	1	1	1	1	1	1		
SWEETWATER	VISTA	SHANDON	San Bernardino			1	1	1	1	1	1	1		
TAHQUITZ	VALLEY	TAHQUITZ P.T.	Riverside			1	1	1		2	1	1	1	1
TAIWAN	ORANGE COUNT	MODENA	Orange			1	1	1		1	1			1
TANAGER	VINCENT	BANDUCCI	Kern			1	1							1
TAPO	VENTURA	SANTA SUSANA	Ventura			1	1							
TEE VEE	RECTOR	HAVILAH	Kern			1	1							1
TETLEY	VISTA	HUSTON	San Bernardino			1	1	1		1	1	1		
THACHER	VENTURA	OUAI	Ventura			1	1							
TICO	VENTURA	CASITAS	Ventura			1	1							
TIMBER CANYON	VENTURA	FILLMORE	Ventura			1	1							
TITAN	VINCENT	LITTLE ROCK	Los Angeles			1	1							
TOGA	VINCENT	HASKELL	Los Angeles			1	1							
TOLL	DEVERS	WHITEWATER	Riverside			1								
TRUMPET	VINCENT	ELIZABETH LAKE	Los Angeles			1	1							
TWIN LAKES	VENTURA	SANTA SUSANA	Ventura			1								
TWIN PEAKS	VISTA	BURN MILL	San Bernardino							1	1	1		
VARGAS	VISTA	SHANDON	San Bernardino			1	1	1	1	1	1	1		
VASQUEZ	VINCENT	SOLEMINT	Los Angeles			1								1
VERDE MONT	VISTA	CALECTRIC	San Bernardino			1	1	1	1	1	1	1	1	1
VERDUGO	MESA	LA CANADA	Los Angeles			1								
VETERANS	VINCENT	SAN FERNANDO	Los Angeles			1	1	1						
VIENTO	VINCENT	MONOLITH	Kern			1	2							1
WINERY	VALLEY	PAUBA	Riverside						1					
YOSEMITE	VALLEY	LAKEVIEW	Riverside											1
YOSEMITE	VENTURA	SANTA SUSANA	Ventura			1	1							
ZENDA	RECTOR	LORRAINE	Kern			1	1							
ZONE	VENTURA	MOORPARK	Ventura			1								

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

				Period of Concern Report 10/25/2019 06:00																			
				Friday			Saturday			Sunday			Monday			Tuesday							
				10/25/19 6:00	10/25/19 12:00	10/25/19 18:00	10/26/19 0:00	10/26/19 6:00	10/26/19 12:00	10/26/19 18:00	10/27/19 0:00	10/27/19 6:00	10/27/19 12:00	10/27/19 18:00	10/28/19 0:00	10/28/19 6:00	10/28/19 12:00	10/28/19 18:00	10/29/19 0:00	10/29/19 6:00	10/29/19 12:00	10/29/19 18:00	
Circuit	Switching Center	Substation	County	10/25/19 9:00	10/25/19 15:00	10/25/19 21:00	10/26/19 3:00	10/26/19 9:00	10/26/19 15:00	10/26/19 21:00	10/27/19 3:00	10/27/19 9:00	10/27/19 15:00	10/27/19 21:00	10/28/19 3:00	10/28/19 9:00	10/28/19 15:00	10/28/19 21:00	10/29/19 3:00	10/29/19 9:00	10/29/19 15:00	10/29/19 21:00	
ACOSTA	VISTA	RANDALL	San Bernardino	1	1										1	1	1						
ANGUS	VENTURA	FILLMORE	Ventura	1																			
ARLENE	VINCENT	SOLEMINT	Los Angeles	1																			
AVANTI	VISTA	SHANDIN	San Bernardino	1	1																		
BADGER	VISTA	SHANDIN	San Bernardino	1	1																		
BIG ROCK	VENTURA	CHATSWORTH	Los Angeles; Ventura	1																			
BIRCHIM	CONTROL	MT. TOM	Inyo; Mono								1	1	1										
BLUE CUT	VISTA	BLUE CUT P. T.	San Bernardino																				
BLUE RIDGE	LUGO	BLUE RIDGE P. T.	Los Angeles																				
BOOTLEGGER	VINCENT	ACTON	Los Angeles	1	1	1																	
BOUQUET	VINCENT	SOLEMINT	Los Angeles	1	1																		
BROADCAST	MESA	GOULD	Los Angeles	1																			
CAL STATE	VISTA	SHANDIN	San Bernardino	1	1																		
CARMELITA	VISTA	SHANDIN	San Bernardino	2	1																		
CASMALIA	VISTA	ALDER	San Bernardino	1	1																		
CENTURION	VINCENT	HASKELL	Los Angeles	1																			
CHAWA	VALLEY	PECHANGA	Riverside; San Diego	1																			
CLUB OAKS	VISTA	CARDIFF	San Bernardino	1	1																		
CRAM	VISTA	HIGHLAND	San Bernardino	1																			
CROSBY	MESA	FAIR OAKS	Los Angeles	1																			
CUSHENBURY	LUGO	COTTONWOOD	San Bernardino																				
DAVENPORT	VINCENT	SOLEMINT	Los Angeles	1	1	1																	
DE MILLE	VINCENT	AGLE CANYON P.	Los Angeles	1																			
DEALER	LUGO	PHELAN	Los Angeles; San Bernardino																				
DOBLE	LUGO	COTTONWOOD	San Bernardino																				
ECHO	VISTA	DEL ROSA	San Bernardino	1	1																		
ENERGY	VENTURA	CHATSWORTH	Los Angeles; Ventura	1	1																		
ESCONDIDO	VINCENT	ESCONDIDO P. T.	Los Angeles	1	1																		
FERRARA	MIRALOMA	PADUA	Los Angeles; San Bernardino																				
GLINSITE	DEVERS	GLINSITE P. T.	Riverside; San Bernardino																				
HUCKLEBERRY	VINCENT	RITTER RANCH	Los Angeles																				
JARVIS	MESA	DALTON	Los Angeles	1																			
LOPEZ	VINCENT	SAN FERNANDO	Los Angeles	1	1																		
LOUCKS	VINCENT	LOUCKS P. T.	Los Angeles	1	1	1																	
MONTREAL	VISTA	CANADIAN	San Bernardino																				
MORA	VISTA	RANDALL	San Bernardino	1	1																		
MORITZ	VISTA	HUSTON	San Bernardino																				
NORTH BAY	VISTA	NORTH BAY P. T.	San Bernardino																				
NORTHPARK	VISTA	SHANDIN	San Bernardino	1	1																		
ORION	VINCENT	LOCKHEED	Los Angeles	1																			
PENSTOCK	LUGO	AQUEDUCT	San Bernardino																				
PICK	VINCENT	ACTON	Los Angeles	1	1	1																	
PUFF	VINCENT	MIDWIND	Kern																				
QUIXOTE	VINCENT	SOUTHWIND	Kern																				
RED BOX	MESA	RED BOX P. T.	Los Angeles	1																			
RESORT	VALLEY	NELSON	Riverside	1	1																		
REVERSE PEAK	CONTROL	JUNE LAKE	Mono																				
ROMANUS	VINCENT	HASKELL	Los Angeles	1																			
SAND CANYON	VINCENT	SOLEMINT	Los Angeles	1	1	1																	
SAWPIT	VISTA	APPOWHEAD	San Bernardino																				
SEABOARD	VENTURA	TAPIA	Los Angeles	1																			
SEAFORTH	LUGO	HESPERIA	San Bernardino																				
SHOVEL	VINCENT	ACTON	Los Angeles	1	1	1																	
SHOWDOWN	VINCENT	RITTER RANCH	Los Angeles																				
SINKER	CONTROL	SINKER P. T.	Inyo																				
SKY HI	LUGO	LUCERNE	San Bernardino																				
STUBBY	DEVERS	BANNING	Riverside																				
SUN VILLAGE	VINCENT	LITTLE ROCK	Los Angeles																				
SUTT	VISTA	DEL ROSA	San Bernardino	2	1																		
SWEETWATER	VISTA	SHANDIN	San Bernardino	1	1																		
TAGGERT	VISTA	RUNNING SPRINGS	San Bernardino																				
TAHQUITZ	VALLEY	TAHQUITZ P. T.	Riverside	1	1	1																	
TETLEY	VISTA	HUSTON	San Bernardino	1	1	1	1	1	1														
TIMBER CANYON	VENTURA	FILLMORE	Ventura	1																			
TITAN	VINCENT	LITTLE ROCK	Los Angeles																				
TUBA	VINCENT	ELIZABETH LAKE	Los Angeles																				
TUFA	CONTROL	LUNDY	Mono																				
TUNA	VENTURA	TAPIA	Los Angeles	1																			
TWIN PEAKS	VISTA	BURNT MILL	San Bernardino																				
VARGAS	VISTA	SHANDIN	San Bernardino	1	1																		
VERDEMONT	VISTA	CALECTRIC	San Bernardino	1	1																		
VERBUIGO	MESA	LA CANADA	Los Angeles	1																			
VETERANS	VINCENT	SAN FERNANDO	Los Angeles	1																			
CONTROL-PLANT 3-PLANT 4			Inyo																				
IDLE CALECTRIC-VICTOR NO. 2			San Bernardino																				

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

Customer Name	City	Address	County	10/21	10/22	10/23	10/24	10/25	10/26	10/27	10/28	10/29	10/30	10/31
LAUDA	VALLEY	NELSON	Riverside											1 1
LOCKNER	VALLEY	NELSON	Riverside											1 1
LOPEZ	VINCENT	SAN FERNANDO	Los Angeles											1 1 1 1
LOUCKS	VINCENT	LOUCKS P. T.	Los Angeles				1 1							1 1 1 1
MAMBA	VINCENT	NORTH OAKS	Los Angeles											1 1 1 1
MCKEVETT	VENTURA	MCKEVETT P. T.	Ventura											1 1 1 1
METTLER	VINCENT	CUMMINGS	Kern											1 1 1 1
MIDDLE ROAD	VENTURA	SATICOY	Ventura											1 1 1 1
MORA	VISTA	RANDALL	San Bernardino											1 1 1 1 1 1
MORONGO	DEVERS	MORONGO P. T.	San Bernardino											1 1 1 1 1 1
MUSTANG	RECTOR	ISABELLA	Kern											1 1 1 1 1 1
NAPOLEON	VISTA	MARASCHINO	Riverside											1 1 1 1
NORTHPARK	VISTA	SHANDIN	San Bernardino											1 1 1 1 1 1
OLIVER	VALLEY	ALESSANDRO	Riverside											1 1 1 1
ONCRO	MIRA LOMA	JEFFERSON	Orange;Riverside;San Bernardino											1 1 1 1
PENSTOCK	LUGO	AQUEDUCT	San Bernardino											1 1 1 1
PETIT	VENTURA	WAKEFIELD	Ventura											1 1 1 1
PHEASANT	DEVERS	PHEASANT P. T.	Riverside											1 1 1 1
PICK	VINCENT	ACTON	Los Angeles											1 1 1 1
PICKENS	MESA	LA CANADA	Los Angeles											1 1 1 1
PINWHEEL	VINCENT	NORTHWIND	Kern											1 1 1 1
POPPET FLATS	DEVERS	CABAZON	Riverside											1 1 1 1
PRONGHORN	VINCENT	DEL SUR	Los Angeles											1 1 1 1
PUFF	VINCENT	MIDWIND	Kern											1 1 1 1
PURCHASE	DEVERS	OUTLET P. T.	Riverside											1 1 1 1
PYLE	VENTURA	WAKEFIELD	Ventura											1 1 1 1
PYTHON	VINCENT	NORTH OAKS	Los Angeles											1 1 1 1
RAINBOW	VENTURA	SOMIS	Ventura											1 1 1 1
RANKIN	RECTOR	WALKER BASIN	Kern											1 1 1 1
RED BOX	MESA	RED BOX P. T.	Los Angeles											1 1 1 1
REJADA	VENTURA	ROYAL	Ventura											1 1 1 1
RESORT	VALLEY	NELSON	Riverside											1 1 1 1
REVERSE PEAK	CONTROL	JUNE LAKE	Mono											1 1 1 1
RHINEDOLLAR	CONTROL	POOLE	Mono											1 1 1 1
ROBINSON CREEK	CONTROL	BRIDGEPORT	Mono											1 1 1 1
SADDLEBACK	DEVERS	BANNING	Riverside											1 1 1 1
SAGINAW	RECTOR	BIG CREEK 4	Fresno;Madera											1 1 1 1
SANCHO	VINCENT	SOUTHWIND	Kern											1 1 1 1
SAND CANYON	VINCENT	SOLEMIT	Los Angeles											1 1 1 1
SAVORY	VALLEY	NELSON	Riverside											1 1 1 1
SAWPIT	VISTA	ARROWHEAD	San Bernardino											1 1 1 1
SEAFORTH	LUGO	HESPERIA	San Bernardino											1 1 1 1
SEYMOUR	VISTA	SANTA ANA RIVER 1	San Bernardino											1 1 1 1
SHOVEL	VINCENT	ACTON	Los Angeles											1 1 1 1
SINKER	CONTROL	SINKER P. T.	Inyo											1 1 1 1
SKY HI	LUGO	LUCERNE	San Bernardino											1 1 1 1
STEARNS	VENTURA	SANTA SUSANA	Ventura											1 1 1 1
STEEL	VALLEY	RIDGEVIEW P. T.	Riverside											1 1 1 1
STORES	DEVERS	OUTLET P. T.	Riverside											1 1 1 1
STRATHERN	VENTURA	MOORPARK	Ventura											1 1 1 1
STUBBY	DEVERS	BANNING	Riverside											1 1 1 1
SUTT	VISTA	DEL ROSA	San Bernardino											1 1 1 1
SWEETWATER	VISTA	SHANDIN	San Bernardino											1 1 1 1
TAHQUITZ	VALLEY	TAHQUITZ P. T.	Riverside											1 1 1 1
TAIWAN	ORANGE COUNTY	MCDENNA	Orange											1 1 1 1
TANAGER	VINCENT	BANDUCCI	Kern											1 1 1 1
TAPO	VENTURA	SANTA SUSANA	Ventura											1 1 1 1
TEMPEST	VINCENT	MIDWIND	Kern											1 1 1 1
TETLEY	VISTA	HUSTON	San Bernardino											1 1 1 1
TIMBER CANYON	VENTURA	FILLMORE	Ventura											1 1 1 1
TOLL	DEVERS	WHITEWATER	Riverside											1 1 1 1
TUFA	CONTROL	LUNDY	Mono											1 1 1 1
TWIN LAKES	VENTURA	SANTA SUSANA	Ventura											1 1 1 1
TWIN PEAKS	VISTA	BURNIT MILL	San Bernardino											1 1 1 1
LITE	LUGO	GOLDHILL	San Bernardino											1 1 1 1
VARGAS	VISTA	SHANDIN	San Bernardino											1 1 1 1
VASQUEZ	VINCENT	SOLEMIT	Los Angeles											1 1 1 1
VERDEMONTE	VISTA	CALETRIC	San Bernardino											1 1 1 1
VERDUGO	MESA	LA CANADA	Los Angeles											1 1 1 1
VETERANS	VINCENT	SAN FERNANDO	Los Angeles											1 1 1 1
VIENTO	VINCENT	MONDLITH	Kern											1 1 1 1
WINERY	VALLEY	PAUBA	Riverside											1 1 1 1
YOSEMITE	VENTURA	SANTA SUSANA	Ventura											1 1 1 1
ZENDA	RECTOR	LORRAINE	Kern											1 1 1 1
ZONE	VENTURA	MOORPARK	Ventura											1 1 1 1

Amended SCE PSPS Post Event Report
October 21 to October 26, 2019

				Period of Concern Report 10/26/2019 17:00													
				Saturday		Sunday		Monday		Tuesday		Wednesday		Thursday			
				10/26/19 9:00	10/26/19 12:00	10/27/19 0:00	10/27/19 3:00	10/28/19 0:00	10/28/19 3:00	10/29/19 0:00	10/29/19 3:00	10/30/19 0:00	10/30/19 3:00	10/31/19 0:00	10/31/19 3:00		
Circuit	Switching Center	Substation	County	10/26/19 9:00	10/26/19 12:00	10/26/19 15:00	10/26/19 18:00	10/27/19 0:00	10/27/19 3:00	10/27/19 6:00	10/27/19 9:00	10/27/19 12:00	10/27/19 15:00	10/27/19 18:00	10/28/19 0:00		
ACOSTA	VISTA	RANDALL	San Bernardino														
ALOLA #2	DEVERS	ALOLA	Riverside														
ANGUS	VENTURA	FILLMORE	Ventura														
ANTON	VENTURA	MOORPARK	Ventura														
ARLENE	VINCENT	SOLEMINT	Los Angeles														
AUTUMN	CONTROL	SKILAND	Mono														
AVANTI	VISTA	SHANDIN	San Bernardino														
BADGER	VISTA	SHANDIN	San Bernardino														
BALCOM	VENTURA	FILLMORE	Ventura														
BANTA	CONTROL	LEE VINING	Mono														
BARRINGTON	VENTURA	FILLMORE	Ventura														
BIG ROCK	VENTURA	CHATSWORTH	Los Angeles; Ventura														
BIRCHIM	CONTROL	MT. TOM	Inyo; Mono														
BLUE CUT	VISTA	BLUE CUT P. T.	San Bernardino														
BLUE RIDGE	LUGO	BLUE RIDGE P. T.	Los Angeles														
BOBSLED	CONTROL	SKILAND	Mono														
BONANZA	RECTOR	KERNVILLE	Kern														
BONNEVILLE	VALLEY	LAKEVIEW	Riverside														
BOOTLEGGER	VINCENT	ACTON	Los Angeles														
BOUQUET	VINCENT	SOLEMINT	Los Angeles														
BUCKHORN	VENTURA	FILLMORE	Ventura														
BUFFER	VENTURA	CHATSWORTH	Los Angeles; Ventura														
CAIN RANCH	CONTROL	CAIN RANCH P. T.	Mono														
CALGROVE	VINCENT	NEWHALL	Los Angeles														
CALBER	VINCENT	PALMDALE	Los Angeles														
CALSTATE	VISTA	SHANDIN	San Bernardino														
CANEBRAKE	RECTOR	WELDON	Kern														
CARMELITA	VISTA	SHANDIN	San Bernardino														
CASMALIA	VISTA	ALDER	San Bernardino														
CHATEAU	CONTROL	CASA DIABLO	Mono														
CITY OF BANNING #1	DEVERS	BANNING	Riverside														
CLUB OAKS	VISTA	CARDIFF	San Bernardino														
COACHELLA	DEVERS	GARNET	Riverside; San Bernardino														
CONWAY	CONTROL	LUNDY	Mono														
CRAM	VISTA	HIGHLAND	San Bernardino														
CRAWFORD	CONTROL	CRAWFORD P. T.	Mono														
CUDEBACK	VINCENT	CUMMINGS	Kern														
CUSHENBURY	LUGO	COTTONWOOD	San Bernardino														
DARTMOUTH	VALLEY	MAYBERRY	Riverside														
DAVENPORT	VINCENT	SOLEMINT	Los Angeles														
DEALER	LUGO	PHELAN	Los Angeles; San Bernardino														
DIAMONDBACK	VINCENT	NORTH OAKS	Los Angeles														
DOBLE	LUGO	COTTONWOOD	San Bernardino														
DONLON	VENTURA	SOMIS	Ventura														
DUKE	VISTA	MARASCHINO	Riverside														
DYNAMO	CONTROL	LUNDY	Mono														
DYSART	DEVERS	DYSART P. T.	Riverside														
ECHO	VISTA	DEL ROSA	San Bernardino														
ENCHANTED	VENTURA	ROYAL	Ventura														
ENERGY	VENTURA	CHATSWORTH	Los Angeles; Ventura														
ERSKINE	RECTOR	ISABELLA	Kern														
ESCONDIDO	VINCENT	ESCONDIDO P. T.	Los Angeles														
FAYE	RECTOR	WELDON	Kern														
FERRARA	MIRA LOMA	PADUA	Los Angeles; San Bernardino														
FINGAL	DEVERS	CABAZON	Riverside														
FLYCATCHER	RECTOR	ISABELLA	Kern														
FLYING D	RECTOR	HAVILAH	Kern														
FROZEN	VINCENT	TEJON (PGA)	Kern														
GABBERT	VENTURA	MOORPARK	Ventura														
GILMAN	VALLEY	RIDGEVIEW P. T.	Riverside														
GREAT SALT	VALLEY	LAKEVIEW	Riverside														
GUIFAR	VINCENT	ELIZABETH LAKE	Los Angeles; Ventura														
HILLFIELD	VINCENT	SOLEMINT	Los Angeles														
HUCKLEBERRY	VINCENT	RITTER RANCH	Los Angeles														
HUGHES LAKE	VINCENT	DEL SUR	Los Angeles														
HURLEY	CONTROL	CASA DIABLO	Mono														
JULIUS	VINCENT	HASKELL	Los Angeles														
KEENE	VINCENT	MONOLITH	Kern														
KINSEY	VINCENT	GORMAN	Los Angeles														
LAUDA	VALLEY	NELSON	Riverside														
LOCKNER	VALLEY	NELSON	Riverside														
LOPEZ	VINCENT	SAN FERNANDO	Los Angeles														
LOUCKS	VINCENT	LOUCKS P. T.	Los Angeles														
LYONS	VINCENT	NEWHALL	Los Angeles														

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

Customer Name	Service Area	City	County	21	22	23	24	25	26	27	28	29	30	31		
MAMBA	VINCENT	NORTH OAKS	Los Angeles											1	1	1
MANIFOLD	RECTOR	BIG CREEK 3	Fresno													
MARCUS	VINCENT	HASKELL	Los Angeles													
METTLER	VINCENT	CUMMINGS	Kern													
MORA	VISTA	RANDALL	San Bernardino													
MORGANSTEIN	VENTURA	MOORPARK	Ventura													
MORITZ	VISTA	HUSTON	San Bernardino													
NAPOLEON	VISTA	MARASCHINO	Riverside													
NEARGATE	VINCENT	NEWHALL	Los Angeles													
NORTH PARK	VISTA	SHANDIN	San Bernardino													
OLIVER	VALLEY	ALESSANDRO	Riverside													
PENISTOCK	LUGO	AQUEDUCT	San Bernardino													
PETIT	VENTURA	WAKEFIELD	Ventura													
PHEASANT	DEVERS	PHEASANT P.T.	Riverside													
PICK	VINCENT	ACTON	Los Angeles													
PICKLEMEADOWS	CONTROL	BRIDGEPORT	Mono													
PINWHEEL	VINCENT	NORTHWIND	Kern													
POPPET FLATS	DEVERS	CABAZON	Riverside													
PRONGHORN	VINCENT	DEL SUR	Los Angeles													
PUFF	VINCENT	MIDWIND	Kern													
PYLE	VENTURA	WAKEFIELD	Ventura													
PYTHON	VINCENT	NORTH OAKS	Los Angeles													
RAINBOW	VENTURA	SOMS	Ventura													
RANKIN	RECTOR	WALKER BASIN	Kern													
RED BOX	MESA	RED BOX P.T.	Los Angeles													
REJADA	VENTURA	ROYAL	Ventura													
REVERSE PEAK	CONTROL	JUNE LAKE	Mono													
RHINEDOLLAR	CONTROL	POOLE	Mono													
ROBINSON CREEK	CONTROL	BRIDGEPORT	Mono													
SABRINA	CONTROL	BISHOP CREEK NO.2	Inyo													
SADLEBACK	DEVERS	BANNING	Riverside													
SAGEHEN	CONTROL	ZACK	Mono													
SAGINAW	RECTOR	BIG CREEK 4	Fresno,Madera													
SANCHO	VINCENT	SOUTHWIND	Kern													
SAND CANYON	VINCENT	SOLEMINT	Los Angeles													
SAVOIR	VALLEY	NELSON	Riverside													
SAVIT	VISTA	ARROWHEAD	San Bernardino													
SEAFORTH	LUGO	HESPERIA	San Bernardino													
SHOVEL	VINCENT	ACTON	Los Angeles													
SINKER	CONTROL	SINKER P.T.	Inyo													
SITZMARK	CONTROL	SKILAND	Mono													
SKI	CONTROL	CASA DIABLO	Mono													
SKY HI	LUGO	LUCERNE	San Bernardino													
SLALOM	CONTROL	SKILAND	Mono													
SLOPE	CONTROL	MINARET	Mono													
SNOWDRIFT	CONTROL	MINARET	Mono													
STEEL	VALLEY	RIDGEVIEW P.T.	Riverside													
STEVENSON	RECTOR	BIG CREEK 2	Fresno,Madera													
STORES	DEVERS	OUTLET P.T.	Riverside													
STRATHERN	VENTURA	MOORPARK	Ventura													
STUBBY	DEVERS	BANNING	Riverside													
SUTT	VISTA	DEL ROSA	San Bernardino													
SWEETWATER	VISTA	SHANDIN	San Bernardino													
TAHQUITZ	VALLEY	TAHQUITZ P.T.	Riverside													
TAPO	VENTURA	SANTA SUSANA	Ventura													
TEMPEST	VINCENT	MIDWIND	Kern													
TETLEY	VISTA	HUSTON	San Bernardino													
TIMBER CANYON	VENTURA	FILLMORE	Ventura													
TITAN	VINCENT	LITTLE ROCK	Los Angeles													
TOLL	DEVERS	WHITEWATER	Riverside													
TROUT	CONTROL	CASA DIABLO	Mono													
TRUMPET	VINCENT	ELIZABETH LAKE	Los Angeles													
TUFA	CONTROL	LUNDY	Mono													
TWIN PEAKS	VISTA	BURN MILL	San Bernardino													
VARGAS	VISTA	SHANDIN	San Bernardino													
VASQUEZ	VINCENT	SOLEMINT	Los Angeles													
VERDEMONT	VISTA	CALECTRIC	San Bernardino													
VETERANS	VINCENT	SAN FERNANDO	Los Angeles													
VIENTO	VINCENT	MONOLITH	Kern													
YOSEMITE	VENTURA	SANTA SUSANA	Ventura													
ZENDA	RECTOR	LORAIN	Kern													
ZONE	VENTURA	MOORPARK	Ventura													
IDLE CALECTRIC-VICTOR NO. 2			San Bernardino													
CONTROL-PLANT 3-PLANT 4			Inyo													

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

City	County	City	County	21	22	23	24	25	26
AMETHYST	VISTA	ARCHLINE	San Bernardino						
ANACONDA	VINCENT	NORTH OAKS	Los Angeles			1	1		
APPLETON	VENTURA	ROYAL	Ventura						
ATENTO	DRANGE COUNTY	VIEJO	Orange;Riverside			1	1	1	1
ATMORE	VENTURA	WAKEFIELD	Ventura						
BEAR VALLEY	VISTA	ZANJA	San Bernardino		1	1			
BERKSHIRE	MESA	ARROYO	Los Angeles						
CAMP	RECTOR	KERN RIVER 1	Kern						
CASTRO	VENTURA	WAKEFIELD	Ventura						
CHOLLA	DEVERS	MESCALERO P. T.	San Bernardino						
COBRA	VINCENT	NORTH OAKS	Los Angeles						
CONDOR	VINCENT	BANDUCCI	Kern						
COPPERHEAD	VINCENT	NORTH OAKS	Los Angeles						
COTTONMOUTH	VINCENT	NORTH OAKS	Los Angeles						
CRESCENTA	MESA	GOULD	Los Angeles						
CROSBY	MESA	FAIR OAKS	Los Angeles						
DEVILS GATE	MESA	ARROYO	Los Angeles						
DINELY	VINCENT	CORRECTION	Kern						
DOLORES	MESA	DOLORES P. T.	Los Angeles						
ERRINGER	VENTURA	ROYAL	Ventura						
ESTABAN	VENTURA	SOMIS	Ventura						
GALAHAD	VENTURA	LATIGO	Los Angeles;Ventura						
GALCIT	MESA	ARROYO	Los Angeles						
GILLIBRAND	VENTURA	SANTA SUSANA	Ventura						
GNATCATCHER	VINCENT	BANDUCCI	Kern						
GORGE	MESA	ARROYO	Los Angeles						
GRAPEVINE PEAK	VINCENT	GRAPEVINE PEAK P. T.	Kern						
IRVINE PARK	DRANGE COUNTY	IRVINE PARK P. T.	Orange						
JARVIS	MESA	DALTON	Los Angeles						
KICKAPOO TRAIL	DEVERS	YUCCA	San Bernardino						
KINNELOA	MESA	EATON	Los Angeles						
KOHEA	DRANGE COUNTY	MODENA	Orange						
LAMANDA	MESA	EATON	Los Angeles						
MALDY	VENTURA	SATICOVY	Ventura						
MCKEVETT	VENTURA	MCKEVETT P. T.	Ventura						
MEBANE	RECTOR	MEBANE P. T.	Kern						
MCCASIN	VINCENT	NORTH OAKS	Los Angeles						
MONARCH	VENTURA	ROYAL	Ventura						
MORONGO	DEVERS	MORONGO P. T.	San Bernardino						
NEPAL	DRANGE COUNTY	MODENA	Orange						
ONBORD	MIRALOMA	JEFFERSON	Orange;Riverside;San Bernardino						
PEARCE	VENTURA	PIERPONT	Ventura						
PICKENS	MESA	LA CANADA	Los Angeles						
PURCHASE	DEVERS	OUTLET P. T.	Riverside						
RACER	VINCENT	NORTH OAKS	Los Angeles						
RAVINE	MESA	ARROYO	Los Angeles						
READY	VENTURA	SAN MIGUEL	Ventura						
RICARDO	VENTURA	SAN MIGUEL	Ventura						
ROCKCREEK	CONTROL	SHERWIN	Mono						
ROCKWELL	VISTA	TENNESSEE	San Bernardino						
ROYCE	MESA	ARROYO	Los Angeles						
RUSTIC	DRANGE COUNTY	ONEILL	Orange						
SECO	MESA	ARROYO	Los Angeles						
SEXTON	VENTURA	SATICOVY	Ventura						
SIAM	DRANGE COUNTY	MODENA	Orange						
STEARNS	VENTURA	SANTA SUSANA	Ventura						
TAIWAN	DRANGE COUNTY	MODENA	Orange						
TANAGER	VINCENT	BANDUCCI	Kern						
TEJON	VINCENT	NEENACH	Kern;Los Angeles						
THACHER	VENTURA	OJAI	Ventura						
TOLA	MESA	ARROYO	Los Angeles						
TWIN LAKES	VENTURA	SANTA SUSANA	Ventura						
VERUGO	MESA	LA CANADA	Los Angeles						
WAPELLO	MESA	FAIR OAKS	Los Angeles						

<END APPENDIX A>

Appendix B

Public Safety Partner Notifications

Sample LNO Messaging

Initial PSPS Messaging

PLEASE REPLACE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING: Subject Line:
Important Information from SCE – Possible Public Safety Power Shutoff (PSPS) in [COUNTY NAME] on [DATE]

This message is from the Southern California Edison Liaison Officer for official use by local government officials.

Due to projected weather conditions, SCE is exploring options for a potential Public Safety Power Shutoff (PSPS) of electrical circuits in High Fire Risk Areas (HFRA) serving portions of some cities and unincorporated areas in [COUNTY NAME] County as early as [DATE].

Please note that while these areas may already be experiencing weather-related outages, SCE has not proactively shut off power at this time.

PSPS LNO -- remember to attach the filtered chart for this specific county to this notification before sending.

Please refer to the attached file for the notification status for circuits in your county.

For your reference, PDF and GIS circuit maps may be found at www.sce.com/maps. Please look at the left-hand navigation links for a drop-down menu for this specific PSPS event to view maps for the circuits listed above. You may also find all HFRA maps, by County, and a list of circuits by jurisdiction to assist your planning efforts.

SCE has activated an Incident Management Team (IMT) to monitor conditions. The actual onset of weather conditions and other circumstances beyond our control may impact coordination and notification efforts. As such, there is a possibility that a PSPS event could be called sooner than anticipated, additional circuits could be impacted, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will attempt to notify you as conditions change.

SCE is also notifying customers on the impacted circuits to inform them about the potential shutoff to give them time to prepare.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, SCE crews are working safely and as quickly as possible to restore service.

Please Note: Weather forecasts on radio and television may provide differing information. SCE is relying on forecast data provided by in-house meteorologists.

If you have any questions, please call 855-683-9067 to leave a message and we will return your call shortly. This number is for government agencies only. The Incident Management Team (IMT) Liaison Officer can be reached by email at SCEliaisonOfficer@sce.com. The public should call 800-611-1911 or visit www.sce.com if they have questions.

Again, no Public Safety Power Shutoffs have been initiated by SCE at this time.

Updated Conditions Messaging

PLEASE REPLACE THE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING: Subject Line: Important Information from SCE – Possible Public Safety Power Shutoff in [XX] hours in [COUNTY NAME].

This message is from the Southern California Edison Liaison Officer for official use by local government officials.

SCE is continuing to monitor weather conditions and continues exploring options for a potential Public Safety Power Shutoff (PSPS) of electrical circuits in High Fire Risk Areas (HFRA) for cities and unincorporated areas in [COUNTY NAME].

Please note that while these areas may already be experiencing weather-related outages, SCE has not proactively shut off power at this time.

[LNO-note that you may use the UPDATE template to add and remove as well as confirm ongoing status on the PSPS Monitor list. You may also use the Update Status feature within Everbridge you you don't have to enter Update info from scratch. Ask Cathy how to use the feature if you are not familiar -- saves lots of time.]

SCE has identified the following HFRA circuits in your County that **remain on the PSPS Monitor list:**

[CIRCUIT name] Circuit

- Cities
- Unincorporated areas including the communities of [if any]

[CIRCUIT name] Circuit

- Cities
- Unincorporated areas including the communities of [if any]

For your reference, PDF and GIS circuit maps may be found at www.sce.com/maps. Please look at the left-hand navigation links for a drop-down menu for this specific PSPS event to view maps for the circuits listed above. You may also find all HFRA maps, by County, and a list of circuits by jurisdiction to assist your planning efforts.

SCE's Incident Management Team (IMT) continues to monitor conditions. The actual onset of weather conditions and other circumstances beyond our control may impact coordination and notification efforts. As such, there is a possibility that a PSPS event could be called sooner than anticipated, additional circuits could be added, or conditions could change, resulting in shutoffs no longer being considered for one or more circuits. We will attempt to notify you as conditions change.

SCE is also notifying customers on the impacted circuits to inform them about the potential shutoff.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, SCE crews are working safely and as quickly as possible to restore service.

Please Note: Weather forecasts on radio and television may provide differing information. SCE is relying on forecast data provided by in-house meteorologists.

If you have any questions, please call 855-683-9067 to leave a message and we will return your call shortly. This number is for government agencies only. The Incident Management Team (IMT) Liaison Officer can be reached by email at SCELiaisonOfficer@sce.com. The public should call 800-611-1911 or visit www.sce.com if they have questions.

Again, no Public Safety Power Shutoffs have been initiated by SCE at this time.

Imminent Shut-Down Messaging

PLEASE REPLACE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING: Subject Line: Important Information from SCE – IMMEDIATE SHUTDOWN in [COUNTY NAME].

This message is from the Southern California Edison Liaison Officer for official use by our local governments.

Due to forecasted fire weather conditions, **SCE may proactively turn off power within the next 1 to 4 hours** for a Public Safety Power Shutoff (PSPS) in your area though it may occur earlier or later depending on actual weather conditions.

- **[CIRCUIT name] Circuit**
 - City of xxx
 - Unincorporated communities including xxx

For your reference, PDF and GIS circuit maps may be found at www.sce.com/maps. Please look at the left-hand navigation links for a drop-down menu for this specific PSPS event to view maps for the circuits listed above. You may also find all High Risk Fire Area (HFRA) maps, by County, and a list of circuits by jurisdiction to assist your planning efforts.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Please note the actual onset of weather conditions and other circumstances beyond our control may impact coordination and notification efforts.

Please Note: Weather forecasts on radio and television may provide differing information. SCE is relying on forecast data provided by in-house meteorologists.

If you have any questions, please call 855-683-9067 to leave a message and we will return your call shortly. This number is for government agencies only. The IMT Liaison Officer can be reached by email at SCELiaisonOfficer@sce.com. The public should call 800-611-1911 or visit www.sce.com if they have any questions.

De-Energization Messaging

PLEASE REPLACE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING: Subject Line: Important Information from SCE – Power shut off to the [COUNTY NAME] area at [xx] time due to weather conditions

This message is from the Southern California Edison Liaison Officer for official use by our local governments.

Due to weather conditions, SCE shut off power to circuits in the [COUNTY NAME] area at [xx] time. Impacted circuits and locations are:

[NAME] Circuit

- **City Name**
- **Unincorporated communities including [list unincorporated community names, if any]**

SCE is notifying customers on the affected circuits listed above to inform them about the shutoff event.

The following circuit(s) has/have not been de-energized, but remain on SCE's PSPS watch list:

[NAME] Circuit

- **City Name**
- **Unincorporated communities including [list unincorporated community names, if any]**

For your reference, PDF and GIS circuit maps may be found at www.sce.com/maps. Please look at the left-hand navigation links for a drop-down menu for this specific PSPS event to view maps for the circuits listed above. You may also find all High Risk Fire Area (HFRA) maps, by County, and a list of circuits by jurisdiction to assist your planning efforts.

SCE has an Incident Management Team (IMT) in place to monitor conditions, coordinate with government agencies, and oversee re-energization once conditions are safe. SCE will provide an update to your agency as conditions change. Please note the actual onset of weather conditions and other circumstances beyond our control may impact coordination and notification efforts.

SCE understands the inconvenience of shutting off electric service. This Public Safety Power Shutoff (PSPS) action was taken due to safety concerns for customers and the public in the region. The company's first priority is to protect public safety and the integrity of the electric system serving customers.

At this time, SCE cannot provide an estimate of restoration time. Power will be restored as conditions improve, crews conduct inspections, and determine it is safe to re-energize lines.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, SCE crews are working safely and as quickly as possible to restore service.

Please Note: Weather forecasts on radio and television may provide differing information. SCE is relying on forecast data provided by in-house meteorologists.

If you have any questions, please call 855-683-9067 to leave a message and we will return your call shortly. This number is for government agencies only. The IMT Liaison Officer can be reached by email at SCELiaisonOfficer@sce.com. The public should call 800-611-1911 or visit www.sce.com if they have any questions.

Re-Energization Messaging

PLEASE REPLACE THE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING: Subject Line: Important SCE information – PSPS power Re-Energization in progress in [COUNTY NAME]

This message is from the Southern California Edison Liaison Officer for official use by local government officials.

On [DATE and TIME], SCE initiated a Public Safety Power Shutoff (PSPS) for a [portion] of the XXX and XXX circuit(s) in the xxxxx area in [COUNTY NAME] due to weather conditions in High Fire Risk Areas.

[Remember to group and send messages by County and list each Circuit still in play, separated into those being re-energized and those remaining out - delete this reminder before sending!]

SCE crews have inspected the lines and determined it was safe to **RE-ENERGIZE** the following circuit(s). SCE will notify customers that power has been turned back on.

[NAME] Circuit

- **City Name**
- **Unincorporated communities including [list unincorporated community names, if any]**

The following circuit(s) remain **DE-ENERGIZED**.

[NAME] Circuit

- **City Name**
- **Unincorporated communities including [list unincorporated community names, if any]**

The following circuit(s) **REMAIN** on SCE's PSPS watch list:

[NAME] Circuit

- **City Name**
- **Unincorporated communities including [list unincorporated community names, if any]**

For your reference, PDF and GIS circuit maps may be found at www.sce.com/maps. Please look at the left-hand navigation links for a drop-down menu for this specific PSPS event to view maps for the circuits listed above. You may also find all High Risk Fire Area (HFRA) maps, by County, and a list of circuits by jurisdiction to assist your planning efforts.

SCE's Incident Management Team (IMT) continues to monitor conditions and coordinate with government agencies. We will continue to update your agency as conditions change.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, SCE crews are working safely and as quickly as possible to restore service.

Please Note: Weather forecasts on radio and television may provide differing information. SCE is relying on forecast data provided by in-house meteorologists.

If you have any questions, please call 855-683-9067 to leave a message and we will return your call shortly. This number is for government agencies only. The IMT Liaison Officer can be reached by email SCELiaisonOfficer@sce.com. The public should call 800-611-1911 or visit www.sce.com if they have questions.

Averted Messaging

PLEASE REPLACE "TITLE" ABOVE WITH THE FOLLOWING PRIOR TO SENDING: Subject Line: Important Information from SCE – Public Safety Power Shutoff (PSPS) AVERTED in **[COUNTY NAME]** County

This message is from the Southern California Edison Liaison Officer for official use by local government officials.

As you may be aware, Public Safety Power Shutoff (PSPS) was considered for circuit(s) in your county. Due to improved weather conditions, PSPS has been **AVERTED**.

Please refer to the attached file for a list of circuit status.

SCE has also begun notifying customers of the PSPS cancellation.

For your reference, PDF and GIS circuit maps may be found at www.sce.com/maps. Please look at the left-hand navigation links for a drop-down menu for this specific PSPS event to view maps for the circuits listed above. You may also find all HFRA maps, by county, and a list of circuits, by jurisdiction, to assist your planning efforts.

For customers in these areas who are experiencing a weather-related or other unplanned repair outage not related to PSPS, SCE crews are working safely and as quickly as possible to restore service.

Please note: Weather forecasts on radio and television may provide differing information. SCE is relying on forecast data provided by in-house meteorologists.

If you have any questions, please call 855-683-9067 to leave a message and we will return your call shortly. This number is for government agencies only. The Incident Management Team (IMT) Liaison Officer can be reached by email at SCELiaisonOfficer@sce.com. The public should call 800-611-1911 or visit www.sce.com if they have questions.

<END APPENDIX B>

Appendix C

Customer Notifications

Notification Events, Number and Type of Customers

Communications for Monday 10/21/19												
CUSTOMER MESSAGING										CRITICAL CARE CUSTOMERS		
DATE	TIME SENT	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baseline	Critical	TOTALS	Delivered	Undelivered	Grand Total
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	ATENTO	2,283	3	94	46	7	2,433	7		7
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	CALSTATE	572		42	2	1	617	1		1
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	CARMELITA	2,156		35	47	9	2,247	9		9
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	CLARINET	1,642	2	88	24	6	1,762	6		6
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	CONCEPCION	201	1	38			240			0
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	COPY	14					14			0
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	ELAINE	33					33			0
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	ENCHANTED	313		48	12	2	375	2		2
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	RED MOUNTAIN	296	1	55			352			0
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	RINCON	62		1			63			0
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	SEACLIFF	1,099		87	3	1	1,190	1		1
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	SHEFFIELD	1,668		43	13	1	1,725	1		1
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	TAPO	1,280		49	24	5	1,358	5		5
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	TICO	1,872		80	30	8	1,990	8		8
10/21/2019	12:25	10/12/19_ALLCLEAR_10/21_15circuits	VARGAS	1,560		35	37	12	1,644	12		12
Totals				15,051	7	695	238	52	16,043	52	-	52

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

Communications for Tuesday 10/22/19												
CUSTOMER MESSAGING										CRITICAL CARE CUSTOMERS		
DATE	TIME SENT	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baseline	Critical	TOTALS	Delivered	Undelivered	Grand Total
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ACOSTA	1139	1	63	36	4	1243	4		4
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ALEXANDER	586		9	10	3	608	3		3
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	AMETHYST	1441		24	50	8	1523	8		8
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ANGUS	1508	1	57	17	3	1586	3		3
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ANTON	237		46	1	1	285	1		1
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ARAPAHO	1035		17	17	5	1074	5		5
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	AVANTI	1413	1	99	42	10	1565	10		10
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BADGER	1958		63	40	12	2073	12		12
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BALCOM	1476	1	45	12	2	1536	2		2
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BARRINGTON	573		48	8	2	631	2		2
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BAZOOKA	988		54	17	9	1068	9		9
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BENCH	1502		62	52	11	1627	11		11
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BERKLEY	757		10	15	2	784	2		2
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BLACKFOOT	1143		37	15	4	1199	4		4
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BLUE CUT	225		64	4		293			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BONANZA	1142	12	63	21	5	1243	5		5
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BONNEVILLE	314		25	3		342			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BOOTLEGGER	1398		61	28	10	1497	10		10
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	BOUQUET	681	7	24	20	2	734	2		2
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CALIENTE	1627		18	45	9	1699	8	1	9
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CALSTATE	572		42	2	1	617	1		1
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CANEBRAKE	751		12	25	9	797	9		9
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CARMELITA	2155		35	47	9	2246	9		9
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CASMALIA	1846		126	42	7	2021	7		7
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CASTRO	2304	5	49	20	4	2382	4		4
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CHAWA	1895		56	60	17	2028	17		17
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CHILLON	551		6	8	1	566	1		1
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CLARINET	1643	2	88	23	6	1762	6		6
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CLUB OAKS			2			2			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	COACHELLA			1	2		3			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	COLA	702		7	12	4	725	4		4
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CONDOR	1374		48	34	8	1464	8		8
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CRESTLINE	725		10	7		742			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	CUDDEBACK	315		6	3		324			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	DAVENPORT	1384	1	37	23	13	1458	12	1	13
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	DINELY			1	1		2			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	DYSART	72		2	2		76			
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	EASTER	1516		71	42	12	1641	12		12
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ECHO	1688		13	59	10	1770	10		10
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ENCHANTED	313		48	12	2	375	2		2
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ENERGY	1699	4	83	16	5	1807	5		5
10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	ESTABAN	1978		89	53	9	2129	9		9

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
57	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	FAYE	715		3	19	13	750	13		13
58	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	FINGAL	774	1	20	25	8	828	8		8
59	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	FROZEN			1			1			
70	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	GABBERT	2242		79	23	2	2346	2		2
71	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	GILMAN	5		10			15			
72	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	GOODNER	845		24	6	2	877	2		2
73	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	GREAT SALT	484		24	11	1	520	1		1
74	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	GUNSITE	2		3			5			
75	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	GUST	890		20	19	2	931	2		2
76	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	HARRIER	1980	4	58	20	9	2071	9		9
77	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	HELICOPTER	2586		31	47	12	2676	12		12
78	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	HERO	1300		110	33	9	1452	9		9
				HORSE MOUNTAIN			1			1			
79	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	HUCKLEBERRY	157	2	7	4		170			
30	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	HUGHES LAKE	1118	4	53	19	4	1198	4		4
31	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	JARVIS	824		46	15	2	887	2		2
32	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	JOB	315		6	4		325			
33	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	KIMBERLY	44		6			50			
34	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	KINSEY	61	4	54			119			
35	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	LA GRANDE	1495		55	70	9	1629	9		9
36	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	LAUDA			1			1			
37	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	LEBER	175		4	3	1	183	1		1
38	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	LOCKNER	1448		23	42	9	1522	9		9
39	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	LOPEZ	1395	2	56	13	1	1467	1		1
40	10/22/2019	12:50	10/21/19 Activation_48HR_67 Circuits [A-L]_10/22/19	LOUCKS	56					56			
41	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MACY	665		6	4	2	677	2		2
42	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MAMBA	2017	1	116	22	2	2158	2		2
43	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MCKEVETT	282		4	1	2	289	2		2
44	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	METTLER	487		9	15	3	514	3		3
45	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MIDDLE ROAD	377		33			410			
46	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MORA	2342	1	67	45	5	2460	5		5
47	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MORITZ	1901		48	43	2	1994	2		2
48	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MOUNTAIN	245		1	13	2	261	2		2
49	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MUFFIN	1459		79	10	3	1551	3		3
50	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	NAPA	1078		40	34	5	1157	5		5
51	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	NAPOLEON	978	3	29	48	14	1072	14		14
52	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	NATIONS	489		10	10	5	514	5		5
53	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	NORTH PARK	2066	3	58	46	6	2179	6		6
54	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	OAK GLEN	1436	4	38	40	7	1525	7		7
55	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	OLIVER	5		2			7			
56	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PAWNEE	2125	2	40	43	23	2233	23		23
57	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PERRIS	563		22	11	3	599	3		3
58	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PERSHING	619		8	20	3	650	3		3
59	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PETIT	1002	1	64	6	1	1074	1		1
60	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PHEASANT	168		3	2	2	175	2		2
61	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PICK	921	2	34	27	3	987	3		3

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
13	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	POPPET FLATS	582		45	21	4	652	4		4
14	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	POTATO	1527		43	35	8	1613	8		8
15	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	POWER	783		14	11	5	813	4	1	5
16	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PURCHASE	147		90	1		238			
17	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PYLE	335		29	2		366			
18	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	PYTHON	1342	3	45	28	7	1425	7		7
19	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	RAINBOW	349		44	6		399			
20	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	RANKIN	89		1			90			
21	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	RED BOX	21	1	7			29			
22	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	REJADA	970	1	54	7	3	1035	3		3
23	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	RESORT	1		6			7			
24	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	RYE	1003		41	26	5	1075	5		5
25	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SADDLEBACK	7		2			9			
26	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SAGE	400		8	5	1	414	1		1
27	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SAND CANYON	2072	2	73	52	8	2207	8		8
28	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SANTORINI	1282		32	58	7	1379	7		7
29	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SAVORY	1536		55	50	7	1648	7		7
30	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SCALP	227		18	5	1	251	1		1
31	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SEELEY	710		8	14	3	735	3		3
32	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SESPE	18					18			
33	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SEYMOUR			3			3			
34	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SHOVEL	734	1	25	14	2	776	2		2
35	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SKYLAND	826		6	12	3	847	3		3
36	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SOGGY	898		21	26	7	952	7		7
37	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SONOMA	1698	2	39	50	11	1800	11		11
38	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	STEEL	11	1	22			34			
39	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	STORES	467		69	4	1	541	1		1
40	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	STRATHERN	2539		82	34	3	2658	3		3
41	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	STUBBY	1		5			6			
42	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SUTT	1705	1	45	51	5	1807	5		5
43	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	SWEETWATER	2148		85	41	11	2285	11		11
44	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	TAHQUITZ	121		9	2	1	133	1		1
45	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	TAIWAN	564	1	112	18		695			
46	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	TANAGER	1469		10	46	13	1538	13		13
47	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	TETLEY	788		54	16	3	861	3		3
48	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	THACHER	2050	1	71	18	4	2144	4		4
49	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	TIMBER CANYON	665		24	5	1	695	1		1
50	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	TWIN PEAKS	1		1			2			
				VALLEY OF THE MOON	609		5	10		624			
51	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	MOON									
52	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	VARGAS	1560		35	37	12	1644	12		12
53	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	VERDEMONT			10			10			
54	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	VETERANS	1923	2	24	18	5	1972	5		5
55	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	VIENTO	2899		114	75	18	3106	18		18
56	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	WILSON CREEK	1881		25	54	14	1974	13	1	14
57	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	WOBEGONE	1097		18	29	8	1152	8		8
58	10/22/2019	12:50	10/21/19 Activation_48HR_65 Circuits [M-Z]_10/22/19	ZENDA	309		5	8		322			

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

9	10/22/2019	15:30	10/21/19 Activation_48HR_SKYBORNE Circuits_10/22/19	SKYBORNE	209	10	1	1	221					
0					Totals	125,335	87	4,672	2,646	578	133,318	573	4	577

Communications for Tuesday 10/22/19 @ 1830

CUSTOMER MESSAGING										CRITICAL CARE CUSTOMERS		
DATE	TIME SENT	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baseline	Critical	TOTALS	Delivered	Undelivered	Grand Total
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	ARABIA	1874		38	51	6	1969	6		6
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	BUCKHORN	2274		99	22	3	2398	3		3
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	CAREY	841		8	15	7	871	7	1	6
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	CEDAR PINES	228		6	3		237	0		0
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	COWEN	643		13	18	1	675	1		1
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	DARTMOUTH	1220		62	40	12	1334	12		12
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	ELLIOT	463		15	6	1	485	1		1
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	GARNER	873		26	11	5	915	5		5
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	GREEN VALLEY	369		1	3	7	383	3		3
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	KIRBY	1653		67	27	16	1763	16	1	15
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	OBSERVATORY	4		1			5	0		0
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	PRONGHORN	817		9	22	19	869	2		2
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	RAISIN	1688		42	39	9	1778	9		9
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	RECYCLE			1			1	0		0
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	TEJON	445		29	10	3	487	3		3
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	TIVO	20		6	34		60	0		0
10/22/2019	18:30	10/21/19 Activation_48HR_19 Circuits_10/22/19	YOSEMITE	1208		5	65	36	1318	4		4
10/22/2019	18:30	10/21/19 Activation_48HR_4 Circuits (Midnight Impact 10-25-1	BROADCAST	3		2	8		13	0		0
10/22/2019	18:30	10/21/19 Activation_48HR_4 Circuits (Midnight Impact 10-25-1	CRAM	1223		42	43	7	1315	7		7
10/22/2019	18:30	10/21/19 Activation_48HR_4 Circuits (Midnight Impact 10-25-1	RUSTIC	2941		2	88	56	3094	7	1	6
10/22/2019	18:30	10/21/19 Activation_48HR_4 Circuits (Midnight Impact 10-25-1	SEYMOUR			3			3	0		0
				Totals	18,787	25	672	403	19,973	86	3	83

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

Communications for Wednesday 10/23/19 @ 1400												
CUSTOMER MESSAGING										CRITICAL CARE CUSTOMERS		
DATE	TIME SENT	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baseline	Critical	TOTALS	Delivered	Undelivered	Grand Total
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	ABACUS	2285	1	47	56	14	2403	14		14
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	ATENTO	2284	3	94	46	7	2434	7		7
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	BEAR VALLEY	29			1		30			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	BIG FALLS	135		9	3		147			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	BIG ROCK	2826		47	48	9	2930	9		9
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CAESAR	2307		47	47	7	2408	6	1	7
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CAMP ANGELUS	289		8	7		304			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CAMP BALDY	159		3	2		164			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CARLET	1729	1	50	41	8	1829	8		8
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CHARIOT	2188		90	32	7	2317	7		7
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CONCEPCION	201	1	38			240			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CONFERENCE	18		1	1		20			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CRAM	1223		42	43	7	1315	7		7
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CRESCENTA	2421		46	31	4	2502	4		4
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CROSBY	540		7	9	1	557	1		1
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	CRUMP	417	1	11	11		440			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	DE MILLE	242		3	3	1	249	1		1
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	DOBLE	1		1			2			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	FERRARA	1625	1	78	53	10	1767	8	2	10
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	GALAHAD	1850	1	135	12	4	2002	4		4
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	GUITAR	134	2	119			255			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	HANDY	1204		35	46	5	1290	5		5
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	HOVATTER	1408		52	50	14	1524	14		14
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	ICE HOUSE	11					11			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	IRAN	1533		39	34	5	1611	5		5
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	JENKS LAKE	138		10			148			0
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	JULIUS	3021	1	37	39	9	3107	9		9
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	KOREA	1553		32	32	8	1625	8		8
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	LEMONADE	1485		37	50	5	1577	5		5
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	MARCUS	1416		31	34	3	1484	3		3
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	NEPAL	983		22	27	4	1036	4		4
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	NERO	1997	1	40	45	6	2089	6		6
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	PICKENS	1426		36	10	2	1474	2		2
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	SIAM	2049	1	31	30	9	2120	9		9
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	SPANADA	1070		25	25	7	1127	7		7
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	TENNECO	4586	1	75	71	14	4747	14		14
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	TOGA	2030		33	38	6	2107	6		6
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	TWIN LAKES	2146		32	36	10	2224	10		10
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	VASQUEZ	2152	1	22	52	8	2235	8		8
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	WEESHA	52					52			0

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

A	B	C	D	E	F	G	H	I	J	K	L	M
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	YOSEMITE	1209	5	65	36	4	1319	4		4
10/23/2019	13:00	10/21/19 Activation_48HR_43 Circuits [A-Z]_10/23/19	ZONE	1149		56	23	3	1231	3		3
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ACOSTA	1139	1	63	36	4	1243	4		4
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ALEXANDER	587		9	10	3	609	3		3
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	AMETHYST	1441		24	51	8	1524	8		8
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ANGUS	1509	1	57	17	3	1587	3		3
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ANTON	237		46	1	1	285	1		1
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ARABIA	1872		38	51	6	1967	6		6
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ARAPAHO	1034		17	18	5	1074	5		5
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ARLENE	1484		36	36	6	1562	5	1	6
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	AVANTI	1413	1	99	42	10	1565	10		10
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BADGER	1959		63	40	12	2074	12		12
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BALCOM	1476	1	45	12	2	1536	2		2
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BARRINGTON	573		48	8	2	631	2		2
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BERKLEY	756		10	15	2	783	2		2
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BLACKFOOT	1144		37	15	4	1200	4		4
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BLEND	2297		35	44	10	2386	9	1	10
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BLUE CUT	225		64	4		293			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BONNEVILLE	314		25	3		342			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BOOTLEGGER	1397		61	28	10	1496	10		10
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BOUQUET	681	7	24	20	2	734	2		2
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BROADCAST	3	2	8			13			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	BUCKHORN	2274		99	22	3	2398	3		3
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CAFÉ	1906		26	48	14	1994	11	3	14
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CALIENTE	1629		18	45	9	1701	9		9
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CALSTATE	572		42	2	1	617	1		1
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CAREY	840		8	15	8	871	6	2	8
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CARMELITA	2156		35	47	9	2247	8	1	9
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CASMALIA	1847		126	42	7	2022	7		7
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CASTRO	2304	5	49	20	4	2382	3	1	4
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CEDAR PINES	228		6	3		237			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CHAWA	1896		56	60	17	2029	17		17
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CHILLON	551		6	8	1	566	1		1
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CLARINET	1643	2	88	23	6	1762	6		6
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CLUB OAKS			2			2			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	COACHELLA		1	2			3			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	COLA	702		7	12	4	725	4		4
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CONDOR	1374		48	34	8	1464	8		8
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	COWEN	643		13	18	1	675	1		1
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CRESTLINE	725		10	7		742			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	CUDEBACK	315		6	3		324			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	DARTMOUTH	1220		62	40	12	1334	12		12
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	DAVENPORT	1385	1	37	23	13	1459	12	1	13
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	DINELY		1	1			2			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	DYSART	72		2	2		76			0
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	EASTER	1514		71	42	12	1639	12		12
10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ECHO	1688		13	59	10	1770	10		10

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
79	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ELLIOT	463		15	6	1	485	1		1
80	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ENCHANTED	313		48	12	2	375	2		2
81	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ENERGY	1700	4	83	16	5	1808	5		5
82	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ESCONDIDO	0	0	0	0	0	0	0		0
83	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ESPRESSO	518		14	15	2	549	2		2
84	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	ESTABAN	1979		89	53	9	2130	9		9
85	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	FINGAL	774	1	20	25	8	828	8		8
86	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	FORTUNE	0	0	0	0	0	0	0		0
87	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	FROZEN			1			1			0
88	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GARNER	872		26	11	5	914	5		5
89	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GILMAN	5		10			15			0
90	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GOODNER	845		24	6	2	877	1	1	2
91	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GRAPEVINE PEAK	0	0	0	0	0	0	0		0
92	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GREAT SALT	484		24	11	1	520	1		1
93	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GREEN VALLEY	369	1	3	7	3	383	3		3
94	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GUNSITE	2		3			5			0
95	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	GUST	890		20	19	2	931	2		2
96	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	HARRIER	1978	4	58	20	9	2069	9		9
97	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	HILLS	0	0	0	0	0	0	0		0
98	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	HUCKLEBERRY	157	2	7	4		170			0
99	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	HUGHES LAKE	1118	4	53	19	4	1198	4		4
00	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	IRVINE PARK	0	0	0	0	0	0	0		0
01	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	JARVIS	824		46	15	2	887	2		2
02	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	JOB	315		6	4		325			0
03	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	KIMBERLY	44		6			50			0
04	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	KIRBY	1655		67	27	16	1765	15	1	16
05	10/23/2019	13:45	10/21/19 Activation_24HR_72 Circuits [A-K]_10/23/19	Kona	1560		28	34	16	1638	16		16
06	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	LA GRANDE	1495		55	70	9	1629	9		9
07	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	Latte	0	0	0	0	0	0	0		0
08	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	LAUDA			1			1			0
09	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	LEBER	175		4	3	1	183	1		1
10	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	LOCKNER	1448		23	42	9	1522	7	2	9
11	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	LOPEZ	1395	2	56	13	1	1467	1		1
12	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	LOUCKS	56					56			0
13	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MACY	665		6	4	2	677	2		2
14	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MAMBA	2019	1	116	22	2	2160	2		2
15	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	Maxim	1598		32	39	10	1679	8	2	10
16	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MCKEVETT	282		4	1	2	289	2		2
17	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	METTLER	487		9	15	3	514	2	1	3
18	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MIDDLE ROAD	377		33			410			0
19	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MORA	2341	1	67	45	5	2459	4	1	5
20	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MORITZ	1901		48	43	2	1994	2		2
21	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MOUNTAIN	245		1	13	2	261	1	1	2
22	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	MUFFIN	1458		79	10	3	1550	3		3
23	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	NAPA	1078		40	34	5	1157	5		5
24	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	NAPOLEON	977	3	29	49	14	1072	14		14
25	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	NATIONS	489		10	10	5	514	5		5

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
126	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	NORTH PARK	2067	3	58	46	6	2180	6		6
127	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	OBSERVATORY	4		1			5			0
128	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	OLIVER	5		2			7			0
129	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PAWNEE	2127	2	40	43	23	2235	18	5	23
130	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PERRIS	563		22	11	3	599	2	1	3
131	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PERSHING	619		8	20	3	650	2	1	3
132	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PETIT	1002	1	65	6	1	1075		1	1
133	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PHEASANT	168		3	2	2	175	2		2
134	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PICK	921	2	34	27	3	987	3		3
135	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	POTATO	1528		43	35	8	1614	7	1	8
136	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	POWER	783		14	11	5	813	5		5
137	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PRONGHORN	818	9	22	19	2	870	2		2
138	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PURCHASE	147		90	1		238			0
139	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PYLE	335		29	2		366			0
140	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	PYTHON	1341	3	45	28	7	1424	5	2	7
141	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RAINBOW	349		44	6		399			0
142	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RAISIN	1688		42	39	9	1778	9		9
143	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RANKIN	90		1			91			0
144	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RECYCLE			1			1			0
145	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RED BOX	21	1	7			29			0
146	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	REJADA	970	1	54	7	3	1035	2	1	3
147	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RESORT	1		6			7			0
148	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RUSTIC	2942	2	88	57	7	3096	5	2	7
149	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	RYE	1002		41	26	5	1074	5		5
150	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SADDLEBACK	7		2			9			0
151	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SAGE	400		8	5	1	414	1		1
152	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SAND CANYON	2070	2	73	52	8	2205	7	1	8
153	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SANTORINI	1282		32	57	7	1378	6	1	7
154	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SAVORY	1536		55	50	7	1648	7		7
155	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SCALP	227		18	5	1	251	1		1
156	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SEELEY	709		8	14	3	734	3		3
157	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SESPE	18					18			0
158	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SEYMOUR			3			3			0
159	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SHOVEL	735	1	25	14	2	777	2		2
160	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	Skyborne	209		10	1	1	221		1	1
161	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SKYLAND	827		6	12	3	848	2	1	3
162	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SOGGY	898		21	26	7	952	5	2	7
163	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	STEEL	11	1	22			34			0
164	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	STORES	466		69	4	1	540	1		1
165	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	STRATHERN	2540		82	34	3	2659	3		3
166	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	STUBBY	1		5			6			0
167	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SUTT	1708	1	45	51	5	1810	5		5
168	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	SWEETWATER	2146		85	41	11	2283	9	2	11
169	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	TAHQUITZ	121		9	2	1	133	1		1
170	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	TAIWAN	564	1	112	18		695			0
171	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	TANAGER	1470		10	46	13	1539	12	1	13
172	10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits (L-Z)_10/23/19	TETLEY	788		54	16	3	861	3		3

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

A	B	C	D	E	F	G	H	I	J	K	L	M	
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	THACHER	2050		1	71	18	4	2144	3	1	4
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	TIMBER CANYON	665			24	5	1	695	1		1
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	TIVO	20		6	34			60			0
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	TWIN PEAKS	1			1			2			0
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	VALLEY OF THE MOON	609			5	10		624			0
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	VARGAS	1560			35	37	12	1644	11	1	12
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	VERDEMONT				10			10			0
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	VETERANS	1922		2	24	19	5	1972	5		5
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	VIENTO	2900			114	75	18	3107	14	4	18
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	WOBEGONE	1098			18	29	8	1153	8		8
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	Yuban	1982			29	33	11	2055	11		11
10/23/2019	13:15	10/21/19 Activation_24HR_79 Circuits [L-Z]_10/23/19	ZENDA	309			5	8		322			0
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	BAZOOKA	988			54	17	9	1068	9		9
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	BENCH	1502			62	52	11	1627	11		11
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	BONANZA	1142		12	63	21	5	1243	5		5
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	CANEBRAKE	751			12	25	9	797	8	1	9
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	FAYE	715			3	19	13	750	11	2	13
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	HELICOPTER	2586			31	47	12	2676	12		12
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	HORSE MOUNTAIN				1			1			0
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	KINSEY	61		4	54			119			0
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	OAK GLEN	1436		4	38	40	7	1525	7		7
10/23/2019	14:30	10/21/19 Activation_ALL CLEAR_10 Circuits_10/23/19	WILSON CREEK	1881			25	54	14	1974	14		14
10/23/2019	16:50	10/21/19 Activation_ALL CLEAR_Lake Circuit_10/23/19	LAKE	125		3	1			129			0
10/23/2019	20:56	10/21/19 Activation_24HR_3 Circuits_10/23/19	GABBERT	2242			79	23	2	2346	2		2
10/23/2019	20:56	10/21/19 Activation_24HR_3 Circuits_10/23/19	HERO	1302			110	32	9	1453	9		9
10/23/2019	20:56	10/21/19 Activation_24HR_3 Circuits_10/23/19	DE MILLE	242			3	3	1	249	1		1
10/23/2019	21:03	10_21_19 Activation_24HR_1 Circuits (Midnight Impact 10-25-19)_102319	POPPET FLATS	584			45	21	4	654	4		4
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	BING	2261			45	35	4	2345	2	1	3
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	CANAL	2			3		0	5			0
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	CORSAIR	1500			52	54	10	1616	10	0	10
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	DUKE	1012			54	29	11	1106	11	0	11
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	GILLIBRAND	2242			79	23	2	2346	7	0	7
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	IDA	2112		1	62	48	5	2228	5		5
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	MODJESKA	1722			26	32	6	1786	6		6
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	SCHMIDT	1294			46	52	10	1402	8	0	8
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	STEARNS	2239			91	46	4	2380	4		4
10/23/2019	21:13	10_21_19 Activation_48HR_10 Circuits (Midnight Impact 10-25-19)_102319	WINERY	796		3	23	24	1	847	1		1
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	ATMORE	2802			138	13	6	2959	4	0	4
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	BIANCO	1540			36	55	13	1644	12	0	12
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	BRENNAN	2417			52	33	9	2511	8	1	9
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	BUFFER	991			18	19	6	1034	6		6
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	BUTTERFIELD	1351			46	23	2	1422	3	0	3
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	CADWAY	3405			81	34	6	3526	6		6
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	CALGROVE	1762		1	82	36	4	1885	3	1	4
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	CANET	3664			82	27	4	3777	4		4
10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits_10/23/19	CHOLLA	293			3	8	3	307	2	0	2

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
9	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	CODE	881		10	10		901			0
0	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	COLLINS	1465		63	19	4	1551	4		4
1	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	COOLER	1566		42	30	2	1640	2		2
2	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	DILL	1152	1	10	37	7	1207	6	0	6
3	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	DONLON	470		51	4	1	526	1		1
4	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	DREYER	1391		19	34	5	1449	4	0	4
5	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	ELAINE	33					33			0
6	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	EVERETT	1987		49	16	4	2056	4		4
7	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	EVITA	2539		60	79	12	2690	11	1	12
8	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	FLAKE	2012	31	58	9		2110			0
9	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	FLYING D	396	3	12	5		416			0
0	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	GRANDAD	12		11	1		24			0
1	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	HARTMAN	674		8	2	3	687	3		3
2	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	HOSPITAL	624		10	3		637			0
3	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	LEXINGTON	546		4	7	2	559	2		2
4	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	LOMA VISTA	33					33			0
5	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	LYONS	3473	1	95	26	2	3597	2		2
6	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	MALLOY	959	1	30	12	1	1003	1		1
7	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	MONARCH	1593		38	11	1	1643	1		1
8	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	MORGANSTEIN	1911		91	33	3	2038	3		3
9	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	MORONGO	869		22	17	8	916	8		8
0	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	MUNICH	2354		51	7	1	2413	1		1
1	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	NEARGATE	1523		63	28	5	1619	4	0	4
2	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	ONBORD	1234		81	27	7	1349	7		7
3	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	PANCHITO		1				1			0
4	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	PEARCE	566		7	9	1	583	1		1
5	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	PENSTOCK	1807		60	63	15	1945	15		15
6	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	PINE COVE	1295	1	48	11	5	1360	4	1	5
7	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	RAMAC	766		99	4	1	870	1		1
8	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	RED MOUNTAIN	296	1	55			352			0
9	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	RIVA	3055		58	41	4	3158	3	0	3
0	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	ROCKWELL	1478		37	59	15	1589	15		15
1	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	ROEBUCK	950		11	5	1	967	1		1
2	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	ROSA	3662	1	68	87	21	3839	19	0	19
3	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	SAN NICHOLAS	3442	1	102	16	5	3566	4	1	5
4	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	SAUNDERS	2440		27	19	7	2493	7		7
5	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	SEXTON	3182		78	34	5	3299	5		5
6	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	STEWART	462		10	8	4	484	4		4
7	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	TAPO	1280		50	24	5	1359	4	0	4
8	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	TELOMA	578		5	6		589			0
9	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	TICO	1873		80	30	8	1991	6	0	6
0	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	TITAN	1385	5	55	46	8	1499	7	0	7
1	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	TOLL	26		29			55			0
2	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	TRUMPET	2329		78	46	11	2464	10	0	10
3	10/23/2019	21:15	10/21/19 Activation_48HR_58 Circuits _10/23/19	VERDUGO	2687	1	71	15	4	2778	4		4
4	10/23/2019	21:23	10/21/19 Activation_All Clear_1 Circuits _10/23/19	GUST	890		20	19	2	931	1	0	1
5				Totals	304,345	182	9,902	5,839	1,207	321,475	1,134	60	1,194

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

Communications for Thursday 10/24/19 @ 930													CRITICAL CARE CUSTOMERS		
CUSTOMER MESSAGING													Deliver	Undeliver	Grand Tot
DATE	TIME SE	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baselin	Critical	TOTAL	Deliver	Undeliver	Grand Tot			
10/24/2019	2:30	10_21_19 Activation_SHUTDOWN_1 Circuit_102419	CASTRO	2304	5	49	20	4	2382	4	0	4			
10/24/2019	2:30	10_21_19 Activation_SHUTDOWN_1 Circuit_102419	MCKEVETT	282		4	1	2	289	2		2			
10/24/2019	3:45	10_21_19 Activation_SHUTDOWN_5 Circuits_102419	CONDOR	1374	0	48	34	8	1464	8	0	8			
10/24/2019	3:45	10_21_19 Activation_SHUTDOWN_5 Circuits_102419	CUDEBACK	314	0	6	3	0	323	0	0	0			
10/24/2019	3:45	10_21_19 Activation_SHUTDOWN_5 Circuits_102419	GNATCATCHER	1344	0	46	47	10	1447	10	0	10			
10/24/2019	3:45	10_21_19 Activation_SHUTDOWN_5 Circuits_102419	TANAGER	1470	0	10	46	13	1539	12	1	13			
10/24/2019	3:45	10_21_19 Activation_SHUTDOWN_5 Circuits_102419	METTLER	487	0	9	15	3	514	3	0	3			
10/24/2019	4:35	10_21_19 Activation_SHUTDOWN_4 Circuits_102418	TAHQUITZ	121	0	9	2	1	133	1	0	1			
10/24/2019	4:35	10_21_19 Activation_SHUTDOWN_4 Circuits_102419	MORA	2341	1	67	45	5	2459	5	0	5			
10/24/2019	4:35	10_21_19 Activation_SHUTDOWN_4 Circuits_102419	HUCKLEBERRY	158	2	8	4	0	172	0	0	0			
10/24/2019	4:35	10_21_19 Activation_SHUTDOWN_4 Circuits_102419	CASMALIA	1847	0	127	42	7	2023	7	0	7			
10/24/2019	5:25	10_21_19 Activation_SHUTDOWN_2 Circuits_102419	ACOSTA	1139	1	63	36	4	1243	4	0	4			
10/24/2019	5:25	10_21_19 Activation_SHUTDOWN_2 Circuits_102419	AMETHYST	1442	0	24	51	8	1525	8	0	8			
10/24/2019	8:15	10/21/19 Activation_SHUTDOWN_3 Circuits_10/24/19	ANTON	237	0	46	1	1	285	1	0	1			
10/24/2019	8:15	10/21/19 Activation_SHUTDOWN_3 Circuits_10/24/19	BALCOM	237	0	8	1	0	246	0	0	0			
10/24/2019	8:15	10/21/19 Activation_SHUTDOWN_3 Circuits_10/24/19	ESTABAN	310		44	2		356	0	0	0			
10/24/2019	8:40	10/21/19 Activation_48HR_Anaconda Circuit_10/24/19	ANACONDA	1597	0	34	45	15	1691	15	0	15			
10/24/2019	9:00	10/21/19 Activation_SHUTDOWN_2 Circuits_10/24/19	RAINBOW	17		2			19	0	0	0			
10/24/2019	9:00	10/21/19 Activation_SHUTDOWN_2 Circuits_10/24/19	PETIT	8		14			22	0	0	0			
10/24/2019	9:00	10/21/19 Activation_48HR_Atlanta Circuit_10/24/19	ATLANTA	877	0	58	9	2	946	2	0	2			
10/24/2019	9:25	10/21/19 Activation_SHUTDOWN_Davenport Circuit_10/24/19	DAVENPORT	1384	1	37	23	13	1458	13	0	13			
10/24/2019	9:30	10/21/19 Activation_SHUTDOWN_Arlene Circuit_10/24/19	ARLENE	1483	0	36	36	6	1561	6	2	8			
10/24/2019	9:45	10/21/19 Activation_Shutdown_Shovel-RAR0419_10/24/19	SHOVEL	394	0	9	8	2	413	2	0	2			
10/24/2019	9:45	10/21/19 Activation_SHUTDOWN_Loucks_10/24/19	LOUCKS	56					56	0	0	0			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	ARABIA	1873	0	38	51	6	1968	6	0	6			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	BIG ROCK	2826	0	47	48	9	2930	9	0	9			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	BOOTLEGGER	1398	0	61	28	10	1497	10	0	10			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	BOUQUET	681	7	24	20	2	734	2	0	2			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	DREYER	1391	0	19	34	5	1449	5	0	5			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	FINGAL	773	1	20	25	8	827	8	0	8			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	GUITAR	134	2	119	0	0	255	0	0	0			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	KOREA	1551	0	32	32	8	1623	8	0	8			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	MIDDLE ROAD	377	0	33	0	0	410	0	0	0			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	MODJESKA	1723	0	26	32	6	1787	6	0	6			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	PICK	920	2	34	27	3	986	3	0	3			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	PURCHASE	147	0	90	1	0	238	0	0	0			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	SAND CANYON	2070	2	73	52	8	2205	8	1	9			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	STUBBY	1	0	5	0	0	6	0	0	0			
10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	VERTERNS	1921	2	24	19	5	1971	5	0	5			
10/24/2019	10:15	10/21/19 Activation_Shutdown_Maciel_RAR6072_10/24/19	MACIEL	10		4			14	0	0	0			
10/24/2019	10:20	10/21/19 Activation_SHUTDOWN_Energy_10/24/19	ENERGY	1700	4	83	16	5	1808	5	0	5			
10/24/2019	10:30	10/21/19 Activation_SHUTDOWN_CalState_RAR0868_10/24/19	CALSTATE	6		4			10	0	0	0			
10/24/2019	11:00	10/21/19 Activation_SHUTDOWN_Python_10/24/19	PYTHON	1340	3	45	28	7	1423	6	1	7			
10/24/2019	11:15	10/21/19 Activation_SHUTDOWN_Bouquet_10/24/19	BOUQUET	681	7	24	20	2	734	2	0	2			

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
98	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	DREYER	1391	0	19	34	5	1449	5	0	5
99	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	FINGAL	773	1	20	25	8	827	8	0	8
100	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	GUITAR	134	2	119	0	0	255	0	0	0
101	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	KOREA	1551	0	32	32	8	1623	8	0	8
102	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	MIDDLE ROAD	377	0	33	0	0	410	0	0	0
103	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	MODJESKA	1723	0	26	32	6	1787	6	0	6
104	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	PICK	920	2	34	27	3	986	3	0	3
105	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	PURCHASE	147	0	90	1	0	238	0	0	0
106	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	SAND CANYON	2070	2	73	52	8	2205	8	1	9
107	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	STUBBY	1	0	5	0	0	6	0	0	0
108	10/24/2019	10:00	10/21/19 Activation_Imminent_15 Circuits_10/24/19	VERTERNS	1921	2	24	19	5	1971	5	0	5
109	10/24/2019	10:15	10/21/19 Activation_Shutdown_Maciel_RAR6072_10/24/19	MACIEL	10		4			14	0	0	0
110	10/24/2019	10:20	10/21/19 Activation_SHUTDOWN_Energy_10/24/19	ENERGY	1700	4	83	16	5	1808	5	0	5
111	10/24/2019	10:30	10/21/19 Activation_SHUTDOWN_CalState_RAR0868_10/24/19	CALSTATE	6		4			10	0	0	0
112	10/24/2019	11:00	10/21/19 Activation_SHUTDOWN_Python_10/24/19	PYTHON	1340	3	45	28	7	1423	6	1	7
113	10/24/2019	11:15	10/21/19 Activation_SHUTDOWN_Bouquet_10/24/19	BOUQUET	681	7	24	20	2	734	2	0	2
114	10/24/2019	11:45	10/21/19 Activation_SHUTDOWN_Guitar_RAR0402_10/24/19	GUITAR	9		29			38	0	0	0
115	10/24/2019	12:00	10/21/19 Activation_SHUTDOWN_Estaban_10/24/19 wo2RARs	ESTABAN	1668		54	51		1773	0	0	0
116	10/24/2019	12:00	10/21/19 Activation_SHUTDOWN_Sand Canyon_10/24/19	SAND CANYON	2070	2	73	52	8	2205	7	1	8
117	10/24/2019	12:15	10/21/19 Activation_SHUTDOWN_3 Circuits_10/24/19	GUNSITE	2		3			5	0	0	0
118	10/24/2019	12:15	10/21/19 Activation_SHUTDOWN_3 Circuits_10/24/19	PHEASANT	168		3	2	2	175	2	0	2
119	10/24/2019	12:15	10/21/19 Activation_SHUTDOWN_3 Circuits_10/24/19	ZONE	1149		56	23	3	1231	3	0	3
120	10/24/2019	12:45	10/21/19 Activation_SHUTDOWN_Balcom_10/24/19	BALCOM	1239	1	39	11		1290	0	0	0
121	10/24/2019	13:00	Activation_SHUTDOWN_Stubby_RAR0670_10/24/19	STUBBY	169		12	2		183	0	0	0
122	10/24/2019	13:45	10/21/19 Activation_SHUTDOWN_Tuba_RAR0225_10/24/19	TUBA	2	2	21			25	0	0	0
123	10/24/2019	14:00	10/21/19 Activation_SHUTDOWN_Lopez_PS0048_10/24/19	LOPEZ	389	2	22	4		417	0	1	1
124	10/24/2019	14:00	10/21/19 Activation_SHUTDOWN_Steel_RAR1637_10/24/19	STEEL	11	1	22			34	0	0	0
125	10/24/2019	14:30	10/21/19 Activation_SHUTDOWN_De Mille_10/24/19	DE MILLE	242		3	3	1	249	1		1
126	10/24/2019	17:20	10/21/19 Activation_SHUTDOWN_Dartmouth_10/24/19	DARTMOUTH	1221		62	40	12	1335	12	0	12
127	10/24/2019	19:00	10/21/19 Activation_ALL CLEAR_Concepcion_10/23/19	CONCEPCION	201	1	38			240	0		0
128	10/24/2019	21:35	10/21/19 Activation_SHUTDOWN_RED BOX_RAR9578_10/24/19	RED BOX	21	1	7			29	0		0
129	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	ABACUS	2320	1	52	56	15	2444	15		15
130	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	ANGUS	1509	1	57	17	3	1587	3		3
131	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	ARABIA	1873		38	51	6	1968	6		6
132	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	ATENTO	2284	3	94	46	7	2434	7		7
133	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	ATMORE	2802		138	13	6	2959	6	1	5
134	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	AVANTI	1413	1	99	42	10	1565	10	2	8
135	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BADGER	1958		63	40	12	2073	12	2	10
136	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BARRINGTON	573		48	8	2	631	2		2
137	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BEAR VALLEY	29			1		30	0		0
138	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BIANCO	1541		36	55	13	1645	13	2	11
139	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BIG FALLS	135		9	3		147	0		0
140	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BIG ROCK	2826		47	48	9	2930	9	1	8
141	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BING	2259		45	35	4	2343	4	1	3
142	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BLUE CUT	220		71	4		295	0		0
143	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BONNEVILLE	314		25	3		342	0		0
144	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BOOTLEGGER	1398		61	28	10	1497	10	1	9

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

A	B	C	D	E	F	G	H	I	J	K	L	M
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BRENNAN	2418		53	33	9	2513	9	1	8
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BROADCAST	3	2	8			13	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BUCKHORN	2276		99	22	3	2400	3		3
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BUFFER	991		18	19	6	1034	6		6
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	BUTTERFIELD	1351		46	23	2	1422	2		2
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CADWAY	3406		81	34	6	3527	6		6
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CAESAR	2307		47	47	7	2408	7	2	5
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CAFÉ	1907		26	48	14	1995	14		14
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CALGROVE	1762	1	82	36	4	1885	4	2	2
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CALIENTE	1628		18	45	9	1700	9		9
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CANAL	2		3			5	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CANET	3670		82	27	4	3783	4	1	3
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CARLET	1729	1	50	41	8	1829	8	1	7
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CARMELITA	2155		35	47	9	2246	9		9
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CHARIOT	2188		90	32	7	2317	7		7
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CHAWA	1895		56	60	17	2028	17	2	15
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CHOLLA	293		3	8	3	307	3		3
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CLARINET	1641	2	88	24	6	1761	6		6
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	COACHELLA		1	2			3	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	COLLINS	1465		64	19	4	1552	4	1	3
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CONFERENCE	18		1	1		20	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	COOLER	1566		42	30	2	1640	2		2
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CORSAIR	1673		56	56	10	1795	10		10
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CRAM	1221		42	44	7	1314	7		7
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CRESCENTA	2420		46	32	4	2502	4		4
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CROSBY	540		7	9	1	557	1		1
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	CRUMP	417	1	11	11		440	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DE MILLE	242		3	3	1	249	1		1
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DILL	1152	1	10	37	7	1207	7	1	6
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DINELY		1	1			2	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DOBLE	1		1			2	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DONLON	470		51	4	1	526	1		1
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DREYER	1391		19	34	5	1449	5	1	4
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DUKE	1012		54	29	11	1106	11	2	9
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	DYSART						0	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	EASTER	1514		71	42	12	1639	12	1	11
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	ENCHANTED	313		48	12	2	375	2		2
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	ESCONDIDO						0	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	EVERETT	1987		49	16	4	2056	4		4
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	EVITA	2543		64	80	12	2699	12	2	10
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	FERRARA	1624	1	78	55	9	1767	9	2	7
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	FINGAL	773	1	20	25	8	827	8		8
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	FLAKE	2013		31	58	9	2111	9	1	8
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	FLYING D	396		3	12	5	416	5		5
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	FROZEN			1			1	0		0
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GABBERT	2241		79	23	2	2345	2		2
10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GALAHAD	1851	1	135	12	4	2003	4		4

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
392	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GILLIBRAND	2145		37	58	7	2247	7		7
393	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GILMAN	5		10			15	0		0
394	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GRANDAD	12		11	1		24	0		0
395	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GRAPEVINE PEAK						0	0		0
396	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GREAT SALT	484		24	11	1	520	1		1
397	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	GUNSITE	2		3			5	0		0
398	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	HANDY	1205		35	46	5	1291	5	1	4
399	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	HARRIER	1979	4	58	20	9	2070	9	1	8
300	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	HERO	1302		110	32	9	1453	9		9
301	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	HOVATTER	1407		52	50	15	1524	15	1	14
302	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	HUGHES LAKE	1118	4	53	19	4	1198	4		4
303	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	IDA	2111	1	62	48	5	2227	5	2	3
304	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	IRAN	1533		39	34	5	1611	5	1	4
305	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	IRVINE PARK						0	0		0
306	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	JARVIS	824		46	15	2	887	2		2
307	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	JULIUS	3023	1	37	39	9	3109	9	1	8
308	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	KIRBY	1654		67	27	16	1764	16	3	13
309	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	KOREA	1553		32	32	8	1625	8		8
310	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	LA GRANDE	1493		55	70	9	1627	9		9
311	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	LAUDA			1			1	0		0
312	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	LEMONADE	1485		37	50	5	1577	5		5
313	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	LOCKNER	1448		23	42	9	1522	9	2	7
314	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	LOUCKS	56					56	0		0
315	10/24/2019	22:50	102119 Activation_24HR_88 Circuits [A-L]_102419	LYONS	3474	1	95	26	2	3598	2		2
316	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MALLOY	960	1	30	12	1	1004	1		1
317	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MAMBA	2019	1	115	22	2	2159	2		2
318	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MARCUS	1420		31	34	3	1488	3		3
319	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MIDDLE ROAD	377		33			410	0		0
320	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MODJESKA	1723		26	32	6	1787	6		6
321	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MONARCH	1593		38	11	1	1643	1		1
322	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MORGANSTEIN	1911		91	33	3	2038	3	1	2
323	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MORITZ	1901		48	43	2	1994	2		2
324	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MORONGO	869		22	17	8	916	8		8
325	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	MUNICH	2353		51	7	1	2412	1		1
326	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	NAPA	1078		40	34	5	1157	5		5
327	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	NAPOLEON	977	3	29	49	14	1072	14		14
328	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	NATIONS	490		10	10	5	515	5		5
329	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	NEARGATE	1524		63	28	5	1620	5	1	4
330	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	NEPAL	988		22	26	4	1040	4		4
331	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	NERO	1997	1	40	45	6	2089	6		6
332	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	NORTH PARK	2068	3	58	46	6	2181	6		6
333	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	OLIVER	5		2			7	0		0
334	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	OLYMPIAD	965		19	15	4	1003	4		4
335	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	ONBORD	1235		81	27	7	1350	7		7
336	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PASCAL	1647		38	50	4	1739	4		4
337	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PEARCE	566		7	9	1	583	1		1
338	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PENSTOCK	1806		60	63	15	1944	15		15
339	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PHEASANT	169		3	2	2	176	2		2

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
i40	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PICK	921	2	34	27	3	987	3		3
i41	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PICKENS	1426		36	10	2	1474	2		2
i42	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	POPPET FLATS	583		45	21	4	653	4		4
i43	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PRONGHORN	818	9	22	19	2	870	2		2
i44	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PURCHASE	147		90	1		238	0		0
i45	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	PYLE	335		29	2		366	0		0
i46	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	RAMAC	766		99	4	1	870	1		1
i47	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	RANKIN	90		1			91	0		0
i48	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	RED MOUNTAIN	296	1	55			352	0		0
i49	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	REJADA	972	1	54	7	3	1037	3		3
i50	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	RESORT	1		6			7	0		0
i51	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	REVERSE PEAK	498		47	3		548	0		0
i52	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	RIVA	3055		58	41	4	3158	4		4
i53	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	ROCKWELL	1478		37	59	15	1589	15		15
i54	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	ROSA	3661	1	68	87	21	3838	21		21
i55	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	RUSTIC	2941	2	87	57	7	3094	7	1	6
i56	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	RYE	1002		41	26	5	1074	5		5
i57	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SADDLEBACK	7		2			9	0		0
i58	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SAGE	400		8	5	1	414	1		1
i59	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SAN NICHOLAS	3440	1	102	16	5	3564	5	1	4
i60	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SAND CANYON	2070	2	73	52	8	2205	8	2	6
i61	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SANTORINI	1281		32	57	7	1377	7		7
i62	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SAUNDERS	2439		27	19	7	2492	7		7
i63	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SAVORY	1535		55	50	7	1647	7		7
i64	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SCHMIDT	1294		46	52	10	1402	10		10
i65	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SEABOARD	545		81	4		630	0		0
i66	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SEAFORTH	2205		41	75	32	2353	32		32
i67	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SESPE	18					18	0		0
i68	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SEXTON	3182		78	34	5	3299	5		5
i69	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SEYMOUR			3			3	0		0
i70	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SIAM	2051	1	31	29	9	2121	9		9
i71	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SKY HI	1472		29	54	29	1584	29		29
i72	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SOGGY	898		21	26	7	952	7	1	6
i73	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SONOMA	1702	2	39	50	11	1804	11		11
i74	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SPANADA	1070		25	25	7	1127	7		7
i75	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	STEARNS	2239		91	46	4	2380	4		4
i76	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	STEVENSON	32		3			35	0		0
i77	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	STORES	467		69	4	1	541	1		1
i78	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	STRATHERN	2538		82	34	3	2657	3		3
i79	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	SWEETWATER	2147		85	42	11	2285	11		11
i80	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TAPO	1280		50	24	5	1359	5		5
i81	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TEJON	445		29	10	3	487	3		3
i82	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TENNECO	4586	1	75	70	14	4746	14		14
i83	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TETLEY	789		54	16	3	862	3		3
i84	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	THACHER	2050	1	71	18	4	2144	4		4
i85	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TICO	1873		80	30	8	1991	8		8
i86	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TIMBER CANYON	665		24	5	1	695	1		1

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
683	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TETLEY	789		54	16	3	862	3		3
684	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	THACHER	2050	1	71	18	4	2144	4		4
685	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TICO	1873		80	30	8	1991	8		8
686	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TIMBER CANYON	665		24	5	1	695	1		1
687	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TITAN	1386	5	55	46	8	1500	8		8
688	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TIVO	20	6	34			60	0		0
689	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TOGA	2031		33	38	6	2108	6		6
690	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TOLL	26		29			55	0		0
691	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TRUMPET	2328		78	47	11	2464	11		11
692	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TUNA	566	1	51	1		619	0		0
693	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TWIN LAKES	2147		32	36	10	2225	10		10
694	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	TWIN PEAKS	1		1			2	0		0
695	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	VARGAS	1559		35	37	12	1643	12		12
696	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	VASQUEZ	2152	1	22	52	8	2235	8		8
697	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	VERDEMONT			10			10	0		0
698	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	VERDUGO	2686	1	71	15	4	2777	4		4
699	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	VETERANS	1923	2	24	19	5	1973	5		5
700	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	VIENTO	2899		114	75	18	3106	18	2	16
701	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	WINERY	796	3	23	25	1	848	1		1
702	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	WOBEGONE	1098		19	29	8	1154	8		8
703	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	YOSEMITE	1209	5	65	36	4	1319	4		4
704	10/24/2019	23:00	10/21/19 Activation_24HR_90 Circuits [M-Z]_10/24/19	ZENDA	307		5	8		320	0		0
705	10/24/2019	23:30	10/21/19 Activation_RESTORATION_(CUDDEBACK, METTLER CIRCUITS)_10/2	CUDDEBACK	315		6	3	1	325	1		1
706	10/24/2019	23:30	10/21/19 Activation_RESTORATION_(CUDDEBACK, METTLER CIRCUITS)_10/2	METTLER	487		9	15	3	514	3		3
707				Totals	281,826	137	9,539	5,660	1,138	298,300	1,135	58	1,091

Communications for Friday 10/25/19 @ 0500

CUSTOMER MESSAGING										CRITICAL CARE CUSTOMERS		
DATE	TIME SENT	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baseline	Critical	TOTALS	Delivered	Undelivered	Grand Total
10/25/2019	23:30	102119 Activation_Restoration_(Cuddeback, Mettler Circuits)_10/24/19	CUDDEBACK	314	0	6	3	0	323	0	0	0
10/25/2019	23:30	102119 Activation_Restoration_(Cuddeback, Mettler Circuits)_10/24/19	METTLER	487	0	9	15	3	514	2	0	2
10/25/2019	23:58	102119 Activation_Restoration_(Condor RAR 1539)_10/24/19	CONDOR	1374	0	48	34	8	1464	8	0	8
10/25/2019	2:30	102119 Activation_Restoration_(Condor 74)_10/24/19	CONDOR	61	0	13	0	0	74	0	0	0
10/25/2019	2:30	102119 Activation_RESTORATION_2 Circuits_10/25/19	GNATCATCHER	1344	0	46	47	10	1447	9	0	9
10/25/2019	2:30	102119 Activation_RESTORATION_2 Circuits_10/25/19	ZONE	1149	0	56	23	3	1231	2	0	2
10/25/2019	2:30	102119 Activation_RESTORATION_Dartmouth Circuit_10/25/19	DARTMOUTH	1221	0	62	40	12	1335	8	0	8
10/25/2019	2:30	102119 Activation_RESTORATION_Rainbow Circuit_10/25/19	RAINBOW	17	0	2	0	0	19	0	0	0
10/25/2019	2:30	102119 Activation_RESTORATION_Balcom Circuit_(PS1066)_10/25/19	BALCOM	237	0	8	1	0	246	2	0	2
10/25/2019	4:44	102119 Activation_RESTORATION_Tanager Circuit_10/25/19	TANAGER	1470	0	10	46	13	1539	13	0	13
10/25/2019	4:54	102119 Activation_RESTORATION_Tuba (RAR0225) Circuit_10/25/19	TUBA	2	2	21	0	0	25	0	0	0
									0	0		0
			Totals	7,676	2	281	209	49	8,217	44	-	44
			Grand Totals	753,020	440	#####	14,995	3,110	797,326	3,024	125	3,041

Amended SCS PPS Post Event Report
October 21 to October 26, 2019

Communications for Friday 10/25/19

CUSTOMER MESSAGING										CRITICAL CARE CUSTOMERS		
DATE	TIME SENT	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baseline	Critical	TOTALS	Delivered	Undelivered	Grand Total
10/25/2019	23:30	102119 Activation_Restoration_(Cuddeback, Mettler Circuits)_10/24/19	CUDDEBACK	314	0	6	3	0	323	0	0	0
10/25/2019	23:30	102119 Activation_Restoration_(Cuddeback, Mettler Circuits)_10/24/19	METTLER	487	0	9	15	3	514	3	0	3
10/25/2019	23:58	102119 Activation_Restoration_(Condor RAR 1539)_10/24/19	CONDOR	1374	0	48	34	8	1464	8	0	8
10/25/2019	2:30	102119 Activation_Restoration_(Condor 74)_10/24/19	CONDOR	61	0	13	0	0	74	0	0	0
10/25/2019	2:30	102119 Activation_RESTORATION_2 Circuits_10/25/19	GNATCATCHER	1344	0	48	47	10	1447	10	0	10
10/25/2019	2:30	102119 Activation_RESTORATION_2 Circuits_10/25/19	ZONE	1149	0	58	23	3	1231	3	0	3
10/25/2019	2:30	102119 Activation_RESTORATION_Dartmouth_(PS0109)_Circuit_10/25/19	DARTMOUTH	574		15	22	9	620	9	0	9
10/25/2019	2:30	102119 Activation_RESTORATION_Rainbow Circuit_10/25/19	RAINBOW	17	0	2	0	0	19	0	0	0
10/25/2019	2:30	102119 Activation_RESTORATION_Balcom Circuit_(PS1086)_10/25/19	BALCOM								0	
10/25/2019	4:44	102119 Activation_RESTORATION_Tanager Circuit_10/25/19	TANAGER	1470	0	10	46	13	1539	13	0	13
10/25/2019	4:54	102119 Activation_RESTORATION_Tuba_(RAR0225)_Circuit_10/25/19	TUBA	2	2	21	0	0	25	0	0	0
10/25/2019	13:10	10/21/19 Activation_RESTORED_Dartmouth_10/25/19	DARTMOUTH	1221	0	62	40	12	1335	12	0	12
10/25/2019	13:10	102119 Activation_RESTORATION_RAINBOW_(RAR1941 TO EOL)_Circuit_10/25/19	RAINBOW	17		2		0	19	0	0	0
10/25/2019	13:10	102119 Activation_RESTORATION_STEEL_(RAR1637)_Circuit_10/25/19	STEEL	11	1	22		0	34	0	0	0
10/25/2019	13:30	102119 Activation_RESTORATION_Castro_(not including McKevevtt PT)_Circuit_10/25/19	CASTRO	2510	1	53	20	6	2590	6	0	6
10/25/2019	15:35	102119 Activation_RESTORATION_4 Circuit_10/25/19	AMETHYST	1441		24	51	8	1524	8	0	8
10/25/2019	15:35	102119 Activation_RESTORATION_4 Circuit_10/25/19	MORA	2341	1	67	45	5	2459	5	0	5
10/25/2019	15:35	102119 Activation_RESTORATION_4 Circuit_10/25/19	PYTHON	1341	3	45	28	7	1424	7	0	7
10/25/2019	15:35	102119 Activation_RESTORATION_4 Circuit_10/25/19	TAHQUITZ	121		9	2	1	133	1	0	1
10/25/2019	16:30	102119 Activation_RESTORATION_Estaban-RAR7446_10/25/19	ESTABAN	111		26	1		138		0	
10/25/2019	16:30	102119 Activation_RESTORATION_Huckleberry_10/25/19	HUCKLEBERRY						0		0	
10/25/2019	16:40	102119 Activation_RESTORATION_Condor RAR1539_0/25/20	CONDOR	1313		35	34	8	1390	8	0	8
10/25/2019	16:40	102119 Activation_RESTORATION_Estaban RAR0569_10/25/20	ESTABAN	199		18			217		0	
10/25/2019		102119 Activation_RESTORATION_BALCOM_(PS1086)_Circuit_10/25/19	BALCOM						0	0		0
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	BIRCHIM	511	4	11	9	2	537	2		2
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	BLUE RIDGE	29		2			31			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	CHILLON	551		6	8	1	566	1		1
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	COBRA	1668		31	11	5	1715	5		5
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	CRESTLINE	725		10	7		742			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	CUSHENBURY	1		2			3			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	DEALER	1525	2	53	46	19	1645	17	2	19
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	DOBLE	1		1			2			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	FINGAL	773	1	20	25	8	827	8		8
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	MONTREAL	1023	1	41	8	1	1074	1		1
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	MORITZ	1901		48	43	2	1994	2		2
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	NORTH BAY	203		2	2		207			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	PENSTOCK	1807		60	63	15	1945	15		15
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	PUFF	20	1	4			25			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	QUIKOTE			1			1			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	SCOUT	4					4			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	SEAFORTH	2205		41	75	32	2353	32		32
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	SEELEY	711		8	14	3	736	3		3
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	SINKER	13					13			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	SKYLAND	827		6	12	3	848	3		3
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	SUN VILLAGE	1394		56	40	17	1507	17		17
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	TITAN	1386	5	55	46	8	1500	8		8
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	TUFA	107		4			111			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	TWIN PEAKS	1		1			2			
10/25/2019	18:00	10/21/19 Activation_48HR_29 Circuits_10/25/19	VALLEY OF THE MOON	609		5	10		624			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ABACUS	2320	1	52	56	15	2444	15		15
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ALEXANDER	587		9	10	3	609	3		3

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ANACONDA	1598		34	45	15	1692	15		15
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ANGUS	1509	1	57	17	3	1587	2	1	3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ARAPAHO	1034		17	18	5	1074	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ATENEA	2281	3	94	46	7	2431	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ATLANTA	877		58	9	2	946	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ATMORE	2802		138	13	6	2959	6		6
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	AVANTI	1413	1	99	42	10	1565	10		10
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BADGER	1959		64	40	12	2075	12		12
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BARLEY FLATS	1994		42	11	1	2048	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BARRINGTON	573		48	8	2	631	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BEAR VALLEY	29			1		30			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BERKLEY	756		10	16	2	784	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BIANCO	1541		36	55	13	1645	13		13
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BIG FALLS	135		9	3		147			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BIG ROCK	2827		47	48	9	2931	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BING	2260		45	35	4	2344	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BLACKFOOT	1143		37	15	4	1199	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BLEND	2300		35	44	10	2389	10		10
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BONNEVILLE	314		25	3		342			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BOUQUET	681	7	24	20	2	734	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BRENNAN	2418		53	33	9	2513	8	1	9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BROADCAST	3	2	8			13			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BUFFER	991		18	19	6	1034	6		6
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	BUTTERFIELD	1351		46	23	2	1422	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CADWAY	3406		81	34	6	3527	6		6
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CAESAR	2307		47	47	7	2408	6	1	7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CAFE	1907		26	48	14	1995	13	1	14
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CALGROVE	1762	1	82	36	4	1885	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CALIENTE	1628		18	45	9	1700	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CAMP ANGELUS	289		8	7		304			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CAMP BALDY	159		3	2		164			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CANAL	2		3			5			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CANET	3670		82	27	4	3783	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CAPANERO	270	1	1	4		276			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CARLET	1729	1	50	41	8	1829	8		8
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CARMELITA	2155		32	47	9	2243	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	GENTURION	2078		35	38	5	2156	4	1	5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CHARIOT	2188		90	32	7	2317	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CHAWA	1896		56	60	17	2029	17		17
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CHOLLA	293		3	8	3	307	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CLARINET	1641	2	88	24	6	1761	6		6
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CLUB OAKS			2			2			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	COACHELLA		1	2			3			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CODE	882		10	10		902			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	COLA	703		7	12	4	726	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	COLLINS	1465		64	19	5	1553	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CONFERENCE	18		1	1		20			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	COPPERHEAD	781		19	3		803			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CORSAIR	1673		56	56	10	1795	10		10
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	COTTONMOUTH	3279		44	52	7	3382	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CRAM	1221		42	44	7	1314	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CROSBY	540		7	9	1	557	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CRUMP	417	1	11	11		440			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	CUDEBACK	315		6	3	1	325	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	DE MILLE	242		3	3	1	249	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	DILL	1152	1	10	37	7	1207	7		7

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	DINELY		1	1			2			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	DONLON	470		51	4	1	526	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	DREYER	1391		19	34	5	1449	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	DUKE	1012		54	29	11	1106	11		11
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	DYSART	72		2	2		76			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	EASTER	1514		71	42	12	1639	12		12
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	EGAN	211		1	2	2	216	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ELAINE	33					33			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ELLIOT	463		15	8	1	485	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ENCHANTED	313		48	12	2	375	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	ESPRESSO	518		14	15	2	549	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	EVERETT	1987		49	16	4	2056	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_72 Circuits [A-E]_10/25/19	EVITA	2543		64	80	12	2699	11	1	12
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	FERRARA	1624	1	78	55	9	1767	8	1	9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	FLAKE	2013		31	58	9	2111	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	FLYING D	396		3	12	5	416	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	FROZEN			1			1			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	GABBERT	2242		79	23	2	2346	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	GALAHAD	1852	1	135	12	4	2004	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	GILMAN	5		10			15			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	GRANDAD	12		11	1		24			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	GREAT SALT	484		24	11	1	520	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	GREEN VALLEY	369	1	3	7	3	383	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	HARRIER	1979	4	58	20	9	2070	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	HARTMAN	674		8	2	3	687	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	HERO	1302		110	32	9	1453	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	HOSPITAL	629		11	3		643			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	HUCKLEBERRY	159	2	8	4		173			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	HUGHES LAKE	1118	4	53	19	4	1198	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	ICE HOUSE	11					11			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	IDA	2111	1	62	48	5	2227	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	JACK RABBIT	425		2	8	1	436	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	JARVIS	824		46	15	2	887	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	JENKS LAKE	138		10			148			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	JORDAN	988	3	46	23	3	1063	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	JUBILEE	472		12	13	1	498	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	JULIUS	3023	1	37	39	9	3109	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	KICKAPOO TRAIL	2782	1	66	61	16	2926	16		16
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	KIMBERLY	44		6			50			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	KIRBY	1653		67	27	16	1763	16		16
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	KONA	1559		28	34	16	1637	16		16
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	KOREA	1553		32	32	8	1625	8		8
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LA GRANDE	1493		55	70	9	1627	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LAUDA			1			1			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LEMONADE	1485		37	50	5	1577	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LEXINGTON	543		3	7	2	555	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LOCKNER	1448		23	42	9	1522	9		9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LOMA VISTA	33					33			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LOPEZ	1395	2	56	13	1	1467	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LOUCKS	56					56			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	LYONS	3474	1	95	26	2	3598	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MALOY	960	1	30	12	1	1004	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MAMBA	2019	1	115	22	2	2159	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MARCUS	1420		31	34	3	1488	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MAXIM	1597		32	39	10	1678	10		10
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MCCLENNY	49		1			50			

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MCKEVETT	282		4	1	2	289	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	METTLER	487		9	15	3	514	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MIDDLE ROAD	377		33			410			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MOCCASIN	1333	1	85	23	4	1446	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MONARCH	1593		38	11	1	1643	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MORELLO	55		16			71			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MORGANSTEIN	1911		91	33	3	2038	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MORONGO	869		22	17	8	916	8		8
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MOUNTAIN	245		1	13	2	261	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	MUNICH	2353		51	7	1	2412	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	NAPA	1078		40	34	5	1157	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	NAPOLEON	977	3	29	49	14	1072	14		14
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	NATIONS	490		10	10	5	515	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	NEARGATE	1524		63	28	5	1620	5		5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	NEPAL	988		22	26	4	1040	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	NERO	1997	1	40	45	6	2089	6		6
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_64 Circuits (F-N)_10/25/19	NORTHPARK	2068	3	58	46	6	2181	6		6
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	OBSERVATORY	4		1			5			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	OLIVER	5		2			7			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	ONBORD	1235		81	27	7	1350	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	OSLO	3550		132	10	1	3693	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PANCHITO		1				1			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PAWNEE	2128	2	40	43	23	2236	22	1	23
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PEARCE	566		7	9	1	583	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PERRIS	583		22	11	3	599	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PERSHING	619		8	20	3	650	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PHEASANT	169		3	2	2	176	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PICK	921	2	34	27	3	987	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PICKENS	1426		36	10	2	1474	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PINE COVE	1296	1	48	11	5	1361	4	1	5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	POPPET FLATS	583		45	21	4	653	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	POSO PARK	48					48			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PRONGHORN	818	9	22	19	2	870	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PURCHASE	147		90	1		238			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	PYLE	335		29	2		366			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RACER	700		13	7	2	722	2		2
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RAMAC	766		99	4	1	870	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RANIER	1337		25	44	8	1414	8		8
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RANKIN	90		1			91			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RECYCLE			1			1			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RED BOX	21	1	7			29			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RED MOUNTAIN	296	1	55			352			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	REJADA	972	1	54	7	3	1037	3		3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RESORT	1		6			7			
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RIVA	3055		58	41	4	3158	4		4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	ROCKWELL	1478		37	59	15	1589	14	1	15
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	ROEBUCK	950		11	5	1	967	1		1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	ROSA	3661	1	68	87	21	3838	21		21
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	RUSTIC	2941	2	87	57	7	3094	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	SAN NICHOLAS	3440	1	102	18	5	3564	4	1	5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	SANTORINI	1281		32	57	7	1377	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	SAUNDERS	2439		27	19	7	2492	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	SAVORY	1535		55	50	7	1647	7		7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	SCALP	227		18	5	1	251		1	1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	SCHMIDT	1294		46	52	10	1402	10		10
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits (O-Z)_10/25/19	SEABOARD	545		81	4		630			

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SESPE	18					18				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SEXTON	3182		78	34	5	3299	5			5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SEYMOUR			3			3				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SIAM	2051	1	31	29	9	2121	9			9
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SKYBORNE	209		10	1	1	221	1			1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SOGGY	898		21	26	7	952	7			7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SPANADA	1070		25	25	7	1127	7			7
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	STEEL	11	1	22			34				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	STEWART	462		10	8	4	484	4			4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	STORES	467		69	4	1	541	1			1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	STRATHERN	2538		82	34	3	2657	3			3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	STUBBY	1		5			6				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SUGARLOAF	118		2	1		121				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	SWEETWATER	2147		85	42	11	2285	11			11
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TAHQUITZ	121		9	2	1	133	1			1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TAPO	1280		50	24	5	1359	5			5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TEJON	445		29	10	3	487	3			3
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TELOMA	578		5	6		589				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	THACHER	2050	1	71	18	4	2144	4			4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TICO	1873		80	30	8	1991	8			8
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TIMBER CANYON	665		24	5	1	695	1			1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TIVO	20	6	34			60				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TOGA	2031		33	38	6	2108	6			6
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TOLL	26		29			55				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TRUMPET	2328		78	47	11	2464	11			11
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TUBA	1104	4	60	14	1	1183	1			1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TUNA	566	1	51	1		619				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	TWIN LAKES	2147		32	36	10	2225	10			10
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	VARGAS	1559		35	37	12	1643	12			12
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	VASQUEZ	2152	1	22	52	8	2235	8			8
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	VERDUGO	2686	1	71	15	4	2777	4			4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	VETERANS	1923	2	24	19	5	1973	5			5
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	VIENTO	2899		114	75	18	3106	18	2		18
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	WINERY	796	3	23	25	1	848	1			1
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	WOBEGONE	1098		19	29	8	1154	8			8
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	YOSEMITE	1209	5	65	36	4	1319	4			4
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	YUBAN	1984		29	33	11	2057	11			11
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	ZENDA	307		5	8		320				
10/25/2019	18:00	10/21/19 Activation_ALL CLEAR_79 Circuits {O-Z}_10/25/19	ZONE	1149		56	23	3	1231	3			3
10/25/2019	10:30	10/21/19 Activation_SHUTDOWN_CalState_RAR0868_10/24/19	CALSTATE	6		4			10	0	0		
10/25/2019	19:30	102119 Activation_RESTORED_Shovel_RAR0419_102519	SHOVEL	394		9	8	2	413	1	1		2
10/25/2019	19:30	102119 Activation_RESTORATION_Guitar_RAR0402_102519	GUITAR	9		29			38				0
10/25/2019	20:00	102119 Activation_RESTORATION_ACOSTA Circuit {PME6228-2}_102519	ACOSTA	968	1	62	35	4	1070	4			4
10/25/2019	20:15	102119 Activation_RESTORATION_CLUB OAKS/KIMBERLY PT Circuit {RAR0868}_10	CLUB OAKS	44		6			50				0
10/25/2019	20:15	102119 Activation_RESTORATION_CLUB OAKS/KIMBERLY PT Circuit {RAR0868}_10	KIMBERLY						2				0
10/25/2019	20:15	102119 Activation_RESTORATION_LOPEZ_DE MILLE PT Circuit {RAR3825}_102519	LOPEZ	128	2	16	1	0	147				0
10/25/2019	20:15	102119 Activation_RESTORATION_LOPEZ_DE MILLE PT Circuit {RAR3825}_102519	DE MILLE	242		3	3	1	249	1			1
10/25/2019	20:30	102119 Activation_RESTORATION_RED BOX CB_102519	RED BOX	21	1	7			29				0
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	BANTA	133	2	13	1		149				
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	BLUE CUT	220		71	4		295				
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	BOOTLEGGER	1398		61	28	10	1497	10			10
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	CAMPANULA	1882	1	17	71	15	1986	15			15
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	PINWHEEL	2	1	2			5				
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	REVERSE PEAK	498		47	3		548				
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	RHINEDOLLAR	4		26			30				
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	SABRINA	182		4	1		187				

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	SKY HI	1472		29	54	29	1584	27	2	29
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	SLOPE	1042		4	2		1048			
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	SNOWDRIFT	744		5			749			
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	SPORTSMAN	9		5			14			
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	TEMPEST			1			1			
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	TETLEY	789		54	16	3	862	3		3
10/25/2019	20:15	10/21/19 Activation_2 DAY_18 Circuits_10/25/19	VERDEMONT			10			10			
10/25/2019	20:30	102119 Activation_RESTORATION_CASMALIA_ANTON_102519	CASMALIA	1847		127	42	7	2023	7		7
10/25/2019	20:30	102119 Activation_RESTORATION_CASMALIA_ANTON_102519	ANTON	237	0	46	1	1	285	1		1
10/25/2019	20:30	10/21/19 Activation_RESTORATION_CalState_RAR0868_10/24/19	CALSTATE	6		4			10			
Totals				286,631	134	9,306	5,478	1,192	302,741	1,173	19	1,192
Grand Totals				1,031,975	547	34,114	19,861	4,167	1,071,877	4,067	141	4,106

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
1	Communications for Saturday 10/26/19												
2	CUSTOMER MESSAGING										CRITICAL CARE CUSTOMERS		
3	DATE	TIME SENT	Communication	Circuits	Residential Unassigned	Essential	Major	Medical Baseline	Critical	TOTALS	Delivered	Undelivered	Grand Total
4	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	AMETHYST	1444		24	51	9	1528	8	1	9
5	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	BANTA	133	2	13	1		149			
6	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	BIRCHIM	511	4	11	9	2	537	2		2
7	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	BLUE CUT	220		71	4		295			
8	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	BLUE RIDGE	29		2			31			
9	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	BOOTLEGGER	1398		61	28	10	1497	10		10
10	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CAIN RANCH	16		4			20			
11	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CALIBER	1335		68	32	12	1447	10	2	12
12	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CAREY	839		8	15	8	870	7	1	8
13	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CEDAR PINES	228		6	3		237			
14	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CHILLON	551		6	8	1	566	1		1
15	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CONWAY	22	2	4			28			
16	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	COWEN	641		13	18	1	673		1	1
17	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CRESTLINE	724		10	7		741			
18	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	CUSHENBURY	1		2			3			
19	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	DOBLE	1		1			2			
20	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	DYNAMO						0			
21	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	GARNER	873		26	11	5	915	5		5
22	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	GOODNER	845		24	6	2	877	2		2
23	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	JOB	319		6	4		329			
24	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	LEBER	175		4	3	1	183		1	1
25	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	MACY	661		6	4	2	673	2		2
26	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	MANIFOLD						0			
27	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	MORITZ	1900		48	43	2	1993	2		2
28	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	MOUNTAIN	245		1	13	2	261	2		2
29	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	MUFFIN	1462		80	10	3	1555	3		3
30	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	MUSTANG	2015		28	65	18	2126	17	1	18
31	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	PENSTOCK	1808		60	63	15	1946	13	2	15
32	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	PICKLE MEADOWS	68	1	13	1		83			
33	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	PINWHEEL	2	1	2			5			
34	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	POPPET FLATS	583		45	21	4	653	4		4
35	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	POTATO	1529		43	35	8	1615	7	1	8
36	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	POWER	792		14	11	5	822	5		5
37	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	PUFF	20	1	4			25			
38	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	RAISIN	1679		42	40	9	1770	8	1	9
39	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	REVERSE PEAK	498		47	3		548			
40	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	RHINEDOLLAR	4		26			30			
41	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	ROBINSON CREEK	250		4		1	255	1		1
42	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	RYE	1002		41	26	5	1074	4	1	5
43	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SAGINAW						0			
44	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SANCHO						0			
45	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SAWPIT						0			
46	#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SCOUT	4					4			

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

A	B	C	D	E	F	G	H	I	J	K	L	M
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SEAFORTH	2207		41	75	32	2355	32		32
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SEELEY	712		8	14	3	737	3		3
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SESPE	18					18			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SINKER	13					13			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SKY HI	1472		29	54	29	1584	27	2	29
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	SKYLAND	827		6	12	3	848	3		3
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	STROSNIDER	363	3	32	2	1	401	1		1
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	TEMPEST			1			1			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	TETLEY	789		54	16	3	862	3		3
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	TIMBER CANYON	665		24	5	1	695	1		1
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	TOLL	26		29			55			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	TUFA	107		4			111			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	TWIN PEAKS	1		1			2			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	UTE						0			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	VALLEY OF THE MOON	609		5	10		624			
#####	14:45	10/27/19 Activation_24HR_59 Circuits_10/26/19	VERDEMONT			10			10			
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	ALEXANDER	586		9	10	3	608	3		3
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	ANACONDA	1598		34	45	15	1692	14	1	15
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	ATENTO	2281	3	94	46	7	2431	7		7
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	AVANTI	1413	1	99	42	10	1565	10		10
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	BERKLEY	756		10	16	2	784	2		2
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	BROADCAST	3	2	8			13			
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CAFE	1909		26	48	14	1997	14		14
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CALSTATE	572		45	2	1	620	1		1
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CAMP BALDY	159		3	2		164			
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CARMELITA	2155		32	47	9	2243	9		9
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CASMALIA	1847		127	42	7	2023	7		7
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CASSIDY	1242		46	4	3	1295	3		3
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CASTRO	2305	5	49	20	4	2383	4		4
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CHOLLA	293		3	8	3	307	3		3
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CLUB OAKS			2			2			
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	COACHELLA		1	2			3			
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	COBRA	1668		31	11	5	1715	5		5
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	COLA	703		7	12	4	726	4		4
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CONDOR	1374		48	34	8	1464	8		8
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	COPPERHEAD	781		19	3		803			
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	COTTONMOUTH	3279		44	52	7	3382	7		7
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CRAM	1221		42	44	7	1314	7		7
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CRESCENTA	2420		46	32	4	2502	4		4
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	CUDDEBACK	315		6	3	1	325	1		1
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	ECHO	1689		13	59	10	1771	10		10
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	ELLIOT	464		15	6	1	486	1		1
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	ESPRESSO	518		14	15	2	549	2		2
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	FERRARA	1624	1	78	55	9	1767	8	1	9
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	GALAHAD	1853	1	135	12	4	2005	4		4
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	GILLIBRAND	2145		37	58	7	2247	7		7
#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	GRAPEVINE PEAK						0			0

Amended SCS PSPS Post Event Report
October 21 to October 26, 2019

	A	B	C	D	E	F	G	H	I	J	K	L	M
94	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	HILLS	0	0	0	0	0	0	0		0
95	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	JARVIS	824		46	15	2	887	2		2
96	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	KICKAPOO TRAIL	2782	1	66	61	16	2926	16		16
97	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	KIMBERLY	44		6			50			
98	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	KONA	1559		28	34	16	1637	16		16
99	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	KUEHNER	2995	1	64	54	16	3130	16		16
00	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	LATTE	0	0	0	0	0	0	0		0
01	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	MAXIM	1596		32	39	10	1677	10		10
02	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	MCKEVETT	282		4	1	2	289	2		2
03	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	METTLER	487		9	15	3	514	3		3
04	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	MIDDLE ROAD	377		33			410			
05	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	MORA	2342	1	67	45	5	2460	5		5
06	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	MORONGO	869		22	17	8	916	7	1	8
07	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	NORTH PARK	2069	3	58	45	6	2181	6		6
08	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	ONBORD	1235		81	27	7	1350	7		7
09	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	PERSHING	619		8	20	3	650	3		3
10	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	PICK	921	2	34	27	3	987	3		3
11	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	PICKENS	1426		36	10	2	1474	2		2
12	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	RED BOX	21	1	7			29			
13	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	SEYMOUR			3			3			
14	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	SHOVEL	738	1	25	14	2	780	2		2
15	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	SKYBORNE	209		10	1	1	221	1		1
16	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	STEARNS	2239		91	46	4	2380	4		4
17	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	SUTT	1709	1	45	51	5	1811	5		5
18	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	SWEETWATER	2148		85	42	11	2286	11		11
19	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	TAIWAN	561	1	112	18		692			
20	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	TANAGER	1473		10	46	13	1542	13		13
21	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	TIVO	20	6	34			60			
22	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	TWIN LAKES	2146		32	36	10	2224	10		10
23	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	VARGAS	1558		35	37	12	1642	12		12
24	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	VERDUGO	2687	1	71	15	4	2778	4		4
25	#####	14:45	10/27/19 Activation_48HR_63 Circuits_10/26/19	YUBAN	1982		29	34	11	2056	11		11
26													
27				Totals	107,727	47	3,419	2,201	516	113,910	499	17	516
28													
29				Grand Totals	107,727	47	3,419	2,201	516	113,910	499	17	516

48-Hour Notice

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecasted fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecasted fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) 2-Day Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecasted fire weather conditions, Southern California Edison is exploring a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,
Southern California Edison

24-Hour Notice

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to forecasted fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecasted fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in the ^city_variable^ area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve. For more information, please visit sce.com/psps. Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) 1-Day Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecasted fire weather conditions, Southern California Edison continues to explore a potential Public Safety Power Shutoff of electrical lines in your area. These conditions may result in SCE turning off your power. SCE anticipates that this may occur on ^Day of week^ ^morning/afternoon/evening^ though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send daily updates until conditions improve.

The following address(es) are within areas being monitored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps. Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

Imminent Notification

Voice/ Voice Mail/TTY:

This an important safety message from Southern California Edison. Due to forecasted fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit sce.com/psps.
Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to forecasted fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to the ^city_variable^ area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve. For more information, please visit sce.com/psps.
Downed power line? Stay away, call 911, and SCE at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Imminent Shutoff Notice

From: do_not_reply@scewebservices.com

Southern California Edison

Due to forecasted fire weather conditions, SCE may proactively turn off power within the next 1 to 4 hours for a Public Safety Power Shutoff to your area though it may occur earlier or later depending on actual weather conditions. We encourage you to prepare by having an outage plan and emergency kit. SCE will send updates until conditions improve.

The following address(es) may be affected:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more info such as expected duration: please visit www.sce.com/psps.
Downed power line? Stay away, Call 911, and SCE at 1-800-611-1911.

Thank You,

Southern California Edison

De-Energization Notification

Voice/ Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Southern California Edison has proactively turned off power to the ^city_variable^ area due to fire weather conditions. We will update you as conditions change. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Notification

From: do_not_reply@scewebservices.com

Southern California Edison

This is an important safety message from Southern California Edison. Southern California Edison has proactively turned off power to your area due to fire weather conditions. We will update you as conditions change.

The following address(es) may be affected:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 9 1 1, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

Re-Energization Notification

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Text/SMS:

SCE Safety Alert: Southern California Edison proactively turned off power to the ^city_variable^ area on ^date variable^ date, due to fire weather conditions. Power has now been restored. If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Restoration Notification

From: do_not_reply@scewebservices.com

Southern California Edison

Southern California Edison proactively turned off power to your area on ^date variable^ date, due to fire weather conditions. Power has now been restored.

The following address(es) have been restored:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

If your power is still off, please call 1-800-611-1911 or visit sce.com/outage.

Thank You,

Southern California Edison

All Clear Notification

Voice /Voice Mail/TTY:

This is an important safety message from Southern California Edison. Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Text/SMS:

SCE Safety Alert: Due to improved fire weather conditions, the ^city_variable^ area, has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service. For more information, please visit sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

E-Mail:

Subject: SCE Safety Alert: Public Safety Power Shutoff (PSPS) Avoided Shutoff Notice

From: do_not_reply@scewebservices.com

Southern California Edison

Due to improved fire weather conditions, your area has been removed from Public Safety Power Shutoff consideration. No electric service will be proactively turned off at this time. If a non-P S P S outage occurs, S C E will work as quickly as possible to restore your service.

The following address(es) have been removed:

13240 Riverview Dr.
Victorville, CA 92395-1234
Service Account: 3-XXX-XX45-67
Meter: 123456-654321
Rate: GS-2

For more information please visit our website at www.sce.com/psps. If you see a downed power line, stay away, call 911, and report this to S C E at 1-800-611-1911.

Thank You,

Southern California Edison

<END APPENDIX C>

Appendix D

Date of Initial Notifications to Public Safety/Local Government/ Partners and Critical Infrastructure Providers

Community/Representative	Date
FEDERAL AGENCIES	
DEPARTMENT OF AGRICULTURE	10/21/2019
FEDERAL AVIATION ADMINISTRATIO	10/21/2019
FEDERAL BUREAU OF INVSTIGATION	10/22/2019
IMMIGRATION & NATURALIZATION	10/24/2019
UNITED STATES ARMY CORP OF ENG	10/23/2019
UNITED STATES COAST GUARD	10/23/2019
UNITED STATES FOREST SERVICE	10/21/2019
UNITED STATES SECRET SERVICE	10/22/2019
STATE/REGULATORY AGENCIES	
CALIFORNIA OFFICE OF EMERGENCY SERVICES	10/21/2019
CPUC	10/21/2019
CA DEPT OF CORRECTIONS & REHAB	10/21/2019
CALIF STATE DEPT OF FORESTRY	10/24/2019
CALIFORNIA STATE HIGHWAY PATROL	10/21/2019
CALTRANS	10/21/2019
DEPARTMENT OF MOTOR VEHICLES	10/22/2019
INYO COUNTY (Tier 2/Tier 3)	
INYO COUNTY OEM	10/24/2019
FRONTIER COMMUNICATIONS CORP	10/24/2019
KERN COMMUNITY COLLEGE DISTRCT	10/24/2019
ROUND VALLEY JOINT ELEMENTARY	10/24/2019
KERN COUNTY (Tier 2/Tier 3)	
KERN COUNTY OEM	10/21/2019
AAT COMMUNICATIONS CORP	10/21/2019
AERO ENERGY LLC	10/25/2019
AMERICAN FOUNDATION TIB CAL PR	10/21/2019
AMERICAN TOWER CORPORATION	10/22/2019
AT&T	10/21/2019
AT&T CORPORATION	10/21/2019
AT&T MOBILITY	10/22/2019
AT&T WIRELESS SERVICES	10/21/2019
ATT MOBILITY	10/23/2019
BAKERSFIELD, CITY OF	10/23/2019
BEAR VALLEY SPRINGS ASSOC	10/23/2019
BNSF RAILWAY CO	10/22/2019
BOHN, ROBERT J	10/22/2019
BRYANT, JOHN T	10/21/2019
CALIENTE UNION ELEMENTARY	10/21/2019
CALWIND RESOURCES	10/25/2019
CEI, INC	10/21/2019
CINGULAR WIRELESS, LLC	10/22/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

CORAM ENERGY LLC	10/25/2019
CREIGHTON, WILLIAM D	10/22/2019
CROWN CASTLE	10/23/2019
EL TEJON UNIFIED SCHOOL DIST	10/21/2019
FRAZIER MOUNTAIN WIRELESS	10/23/2019
FRONTIER COMMUNICATIONS CORP	10/22/2019
GIRL SCOUTS OF GREATER LA	10/23/2019
GOLDEN HILLS COMMUNITY SVC DS	10/21/2019
GOLDEN HILLS SANITATION CO INC	10/21/2019
GTE MOBILENET INCORPORATED	10/21/2019
HALL AMBULANCE SVS	10/21/2019
HIGH DESERT BROADCASTING	10/22/2019
HOMENETMEN WESTERN U.S. REGION	10/23/2019
KERN COUNTY SUPT OF SCHOOLS	10/21/2019
KERN VALLEY MASONIC TEMPLE ASN	10/22/2019
KERN, COUNTY OF	10/21/2019
KERNVILLE UNION SCHOOL DIST	10/22/2019
LIBERTY AMBULANCE	10/22/2019
MIL POTRERO MUTUAL WATER CO	10/23/2019
NATIONAL FARM WORKERS SERVICE	10/21/2019
NISC/NEXTEL	10/21/2019
OAK CREEK WIND POWER, LLC	10/24/2019
ORO GRANDE SCHOOL DISTRICT	10/21/2019
PACIFIC BELL CORP	10/21/2019
PEAK TO PEAK MOUNTAIN CHARTER	10/23/2019
PINON PINES ESTATES	10/23/2019
PROPATH, INC	10/21/2019
QWEST COMMUNICATIONS CORP	10/21/2019
RACE COMMUNICATION	10/21/2019
RESOURCE II/PAJUELA PEAK	10/24/2019
RISING TREE WIND FARM LLC	10/23/2019
SO FORK WOMENS CLUB	10/22/2019
SOLEDAD ENRICHMENT ACTION INC	10/21/2019
SOUTH FORK UNION ELEMENTARY SD	10/22/2019
SOUTHERN PACIFIC CO	10/21/2019
SPRINT NEXTEL CORPORATION	10/21/2019
SRS-TEHACHAPI, LLC	10/21/2019
STALLION SPRINGS C S D	10/21/2019
T MOBILE WEST, LLC	10/21/2019
TEHACHAPI UNIFIED SCHOOL DIST	10/21/2019
TEHACHAPI, CITY OF	10/21/2019
UNION PACIFIC RAILROAD CO	10/21/2019
V F POST 9791	10/23/2019

Amended SCE PSPS Post Event Report
October 21 to October 26, 2019

VENTURA COUNTY BOY SCOUTS OF A	10/23/2019
VERIZON WIRELESS	10/21/2019
WELDON FIRE DEPT	10/22/2019
ZAYO GROUP HOLDINGS, INC.	10/25/2019
ZITO WEST HOLDINGS 619	10/23/2019
LOS ANGELES COUNTY (Zone 1/Tier 2/Tier 3)	
LA COUNTY OEM	10/21/2019
ACTON AGUA DULCE SCHOOL DIST	10/21/2019
AGUA DULCE WOMENS CLUB	10/21/2019
AIR COMMUNICATION SERVICES INC	10/22/2019
AMERESCO CHIQUITA ENERGY LLC	10/23/2019
AMERICAN BROADCASTING COMPANY	10/22/2019
AMERICAN LEGION POST 507	10/24/2019
AMERICAN MED RESPON	10/22/2019
AMERICAN MEDICAL RESPONSE	10/21/2019
AMERICAN MEDICAL RESPONSE INC	10/21/2019
AMERICAN TOWER CORPORATION	10/21/2019
ANGELS LIGHT HOSPICE	10/23/2019
ARMENIAN STRS ACADM	10/24/2019
AT&T	10/22/2019
AT&T CORPORATION	10/21/2019
AT&T MOBILITY	10/21/2019
AT&T OF CALIFORNIA	10/24/2019
AT&T WIRELESS SERVICES	10/21/2019
AZUSA UNIFIED SCHOOL DISTRICT	10/21/2019
B.P.O.E. 2379 01	10/23/2019
BAYSHORE SOLAR A, LLC	10/21/2019
BAYSHORE SOLAR C, LLC	10/21/2019
BELL HOME CARE STAFFING LLC	10/24/2019
BLUE RIDGE COMMUNICATIONS SITE	10/24/2019
BOEING COMPANY, THE	10/24/2019
BOY SCOUTS OF AMERICA	10/22/2019
BRIDGE TO HOME	10/24/2019
CACTUS RADIO CLUB INC	10/21/2019
CALIFORNIA INSTITUTE OF TECH	10/21/2019
CANYON COUNTRY DIALYSIS LLC	10/22/2019
CARE AMBULANCE SERVICE INC	10/23/2019
CASTAIC UNION SCHOOL DIST	10/24/2019
CENTRAL ANTELOPE DRY RANCH B	10/21/2019
CHANCELLOR MEDIA CORPORATION	10/22/2019
CHATSWORTH HILLS ACADEMY	10/22/2019
CINCINNATI BELL INCORPORATED	10/23/2019
CINGULAR WIRELESS	10/24/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

CINGULAR WIRELESS, LLC	10/21/2019
CITRUS COMMUNITY COLLEGE	10/21/2019
CLEAR WIRE COMMUNICATIONS LLC	10/22/2019
COLUMBIAN CLUB INC	10/23/2019
COMMUNICATIONS RELAY, LLC	10/23/2019
COMMUNITY TV OF SO CAL INC	10/22/2019
COSTA DE ORO TV INC	10/22/2019
COVINA VALLEY UNIFIED SCH DIST	10/21/2019
COX PCS ASSETS	10/24/2019
CRESCENTA CANADA YMCA	10/23/2019
CRESPO, ROMAN	10/23/2019
CROWN CASTLE NG WEST LLC	10/23/2019
CVIN, LLC	10/22/2019
DAVITA, INC	10/23/2019
DELL HOME HEALTH CARE INC	10/23/2019
DESCANSO GARDENS GUILD	10/24/2019
EDUCATION MANAGEMENT SYSTEMS	10/23/2019
ELECTRIC LIGHT WAVE	10/22/2019
ELLIS COMMUNICATIONS KDOC,LLC	10/22/2019
FOX TELEVISION STATIONS INC	10/22/2019
FRESENIUS MEDICAL CARE AG	10/21/2019
FRONTIER COMMUNICATIONS CORP	10/21/2019
FTS MASTER TENANT 2, LLC	10/24/2019
FTS PROJECT OWNER 2, LLC	10/24/2019
GEISLER, MARTIN	10/21/2019
GIRL SCOUTS OF GREATER LA	10/23/2019
GLENDALE ELECTRONIC	10/22/2019
GLENDALE UNIFIED SCHOOL DIST	10/23/2019
GLENDORA UNIFIED SCHOOL DIST	10/21/2019
GLENDORA, CITY OF	10/23/2019
GLOBAL SIGNAL INC	10/21/2019
GORMAN LEARNING CENTER, INC	10/22/2019
GORMAN SCHOOL DISTRICT	10/21/2019
GREEN VALLEY COMM CLUB	10/21/2019
HARRIS CORPORATION	10/21/2019
HUGHES ELIZABETH LAKES USD	10/21/2019
ILEAD AGUA DULCE CORP.	10/21/2019
ILEAD SCHOOL DEVELOPEMENT	10/21/2019
INSINITE CHEMICAL AND SERVICE	10/23/2019
INSITE TOWERS LLC	10/22/2019
INSPIRE CHARTER SCHOOL	10/21/2019
INTERNAL REVENUE SERVICE	10/22/2019
JET PROPULSION LAB	10/23/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

KAY, JAMES A	10/22/2019
KCBS FM	10/22/2019
KCBS/KCAL	10/22/2019
KELSEY, WILLIAM	10/23/2019
KEPPEL UNION SCHOOL DISTRICT	10/24/2019
KOCE-TV/DT	10/22/2019
KPWR RADIO	10/22/2019
KRTH RADIO	10/22/2019
KTLA INCORPORATED	10/22/2019
L A ASTRONOMICAL SOC INC	10/24/2019
LA CANADA UNIFIED SCHOOL DIST	10/23/2019
LA CANADA, CITY OF	10/23/2019
LA COUNTY SANITATION DISTRICT	10/23/2019
LA-RICS	10/21/2019
LDDS WORLDCOM	10/22/2019
LEVINE, SAUL R DBA	10/22/2019
LIBERMAN BROADCASTING, INC	10/23/2019
LODESTAR TOWERS, INC	10/22/2019
LOS ANGELES COUNTY FIRE DEPT	10/21/2019
LOS ANGELES COUNTY ISD	10/21/2019
LOS ANGELES COUNTY PUBLIC WORK	10/21/2019
LOS ANGELES DEPT OF WTR & POWR	10/22/2019
LOS ANGELES UNIFIED SCHL DIST	10/21/2019
LOS ANGELES, CITY OF	10/22/2019
MALIBU, CITY OF	10/23/2019
MASONIC BUILDING AND HOLDING	10/24/2019
MAYHUGH, ROY W.	10/22/2019
MC KAY, RICHARD W	10/22/2019
MCI GROUP	10/21/2019
METROLINK	10/21/2019
MINT CANYON MOOSE 2173	10/23/2019
MISSION VIEW PUBLIC SCHOOL	10/23/2019
MOBILE RELAY ASSOC	10/23/2019
MONTES, ABEL	10/21/2019
MOUNTAIN INVESTMENT	10/21/2019
MOUNTAIN REPEATER ASSOC, INC	10/21/2019
NBC UNIVERSAL INCORPORATED	10/22/2019
NBC UNIVERSAL, LLC	10/22/2019
NEW INSPIRATION INC	10/22/2019
NEW VISTA HEALTH SERVICES LLC	10/23/2019
NEWHALL SCHOOL DISTRICT	10/24/2019
NEXTEL COMMUNICATIONS, INC	10/22/2019
NISC/NEXTEL	10/22/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

NRG SOLAR ALPINE	10/22/2019
OAKMONT OF VALENCIA LLC	10/24/2019
OKESOLA, DOROTHY	10/23/2019
OLD WT MASONIC ASSO	10/23/2019
OUR LADY PERPETUAL HELP SCHOOL	10/24/2019
PACIFIC BELL CORP	10/21/2019
PACIFICA FOUNDATION	10/22/2019
PALMDALE SCHOOL DISTRICT	10/24/2019
PALMDALE WATER DISTRICT	10/24/2019
PENNY LANE SENIOR CARE SERVICE	10/23/2019
PORTAL RIDGE SOLAR, LLC	10/21/2019
PUBLIC SAFETY COMM DIV (PSCD)	10/22/2019
QUALITY LONG TERM CARE INC	10/21/2019
RADIANCE SOLAR 4 LLC	10/21/2019
RADIANCE SOLAR 5 LLC	10/21/2019
RODEO SOLAR C2 LLC	10/21/2019
RODEO SOLAR D2, LLC	10/21/2019
ROY BROTHERS DRILLING INC	10/24/2019
ROYALE HOME HEALTH CARE	10/23/2019
SAN GABRIEL VALLEY YMCA	10/24/2019
SANDRA ENERGY LLC	10/21/2019
SANTA CLARITA COMM COLLEGE DST	10/23/2019
SANTA CLARITA CONVELESCENT COR	10/24/2019
SANTA CLARITA DIALYSIS	10/24/2019
SANTA CLARITA HOME HEALTH	10/24/2019
SANTA CLARITA, CITY OF	10/22/2019
SANTA MONICA MALIBU UNIFIED	10/23/2019
SAUGUS UNION SCHOOL DISTRICT	10/23/2019
SERATTI, JERI L	10/21/2019
SERENE HOSPICE CARE, INC	10/23/2019
SOLAR STAR CALIFORNIA XLIV LLC	10/24/2019
SOUTHERN CALIFORNIA REGIONAL	10/21/2019
SOUTHERN PACIFIC CO	10/21/2019
SPRINT NEXTEL CORPORATION	10/21/2019
SPRINT PCS ASSETS	10/23/2019
SPRINT TELEPHONY PCS L.P	10/21/2019
SPRINT UNITED MANAGEMENT CO	10/23/2019
SULPHUR SPRINGS SCHOOL DIST	10/22/2019
T MOBILE USA	10/21/2019
T MOBILE WEST, LLC	10/21/2019
TOUCHTEL CORP	10/22/2019
TOUCHTEL INC	10/23/2019
TRINITY CHRISTIAN CNTR OF SNTA	10/22/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

U C SANTA BARBARA	10/23/2019
UNIVISION COMMUNICATIONS INC	10/22/2019
UNIVISION RADIO LOS ANGELES,INC	10/22/2019
USA BROADCASTING OF SOUTHERN C	10/22/2019
VERIZON CALIFORNIA	10/21/2019
VERIZON WIRELESS	10/21/2019
VFW POST 6885	10/21/2019
WEST ANTELOPE VALLEY HISTORICA	10/21/2019
WESTSIDE UNION SCHOOL DIST	10/21/2019
WILLIAM S HART UNION H S DIST	10/22/2019
WILLS, CATALINA	10/23/2019
WINKLER, MIKE	10/23/2019
MONO COUNTY (Tier 2/Tier 3)	
MONO COUNTY OES	10/24/2019
CA BROADBAND COOPERATIVE, INC.	10/25/2019
EASTERN SIERRA UNIFIED SCH DIS	10/25/2019
FRONTIER COMMUNICATIONS CORP	10/24/2019
JUNE LAKE FIRE DEPT	10/24/2019
JUNE LAKE PUBLIC UTILITY DIST	10/24/2019
LEE VINING FIRE DIST	10/25/2019
LOS ANGELES, CITY OF	10/25/2019
MONO CITY FIRE DEPT	10/25/2019
NATIONAL PARK SERVICE	10/25/2019
PARADISE FIRE DIST	10/24/2019
ROBERTS, FRANK	10/24/2019
T MOBILE WEST, LLC	10/24/2019
ORANGE COUNTY (Tier 2/Tier 3)	
ORANGE COUNTY OEM	10/21/2019
AMERICAN TOWER CORPORATION	10/22/2019
AT&T CORPORATION	10/21/2019
AT&T WIRELESS SERVICES	10/21/2019
BOY SCOUTS OF AMERICA	10/21/2019
CINGULAR WIRELESS	10/22/2019
CINGULAR WIRELESS, LLC	10/24/2019
CLEAR WIRE COMMUNICATIONS LLC	10/22/2019
COX CALIFORNIA PCS	10/21/2019
COX COMMUNICATIONS CALIF, LLC	10/21/2019
CREAN LUTHERAN HIGH SCHOOL	10/23/2019
CROWN CASTLE NG WEST LLC	10/24/2019
GLOBAL SIGNAL INC	10/22/2019
IRVINE RANCH WATER DISTRICT	10/21/2019
IRVINE, CITY OF	10/24/2019
KAY, JAMES A	10/23/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

KEC ENGINEERING	10/24/2019
KIERTON INC.	10/22/2019
LA PURISIMA SCHOOL	10/22/2019
LIBERMAN BROADCASTING, INC	10/22/2019
LODESTAR TOWERS, INC	10/22/2019
MOBILITIE INVESTMENTS II LLC	10/21/2019
MONTESSORI AT THE PARK	10/22/2019
NADESAN, AGANTHA	10/24/2019
NEW ORANGE HILLS INC	10/23/2019
NEXTEL COMMUNICATIONS	10/21/2019
NEXTEL COMMUNICATIONS, INC	10/21/2019
NISC/NEXTEL	10/21/2019
ORANGE COUNTY BOARD EDUCATION	10/22/2019
ORANGE COUNTY FIRE AUTHORITY	10/22/2019
ORANGE COUNTY SANITATION DIST	10/24/2019
ORANGE UNIFIED SCHOOL DISTRICT	10/22/2019
ORANGE, CITY OF	10/23/2019
ORANGE, COUNTY OF	10/21/2019
PACIFIC BELL CORP	10/22/2019
PLEASANTS PEAK FACILITY CORP	10/22/2019
PUBLIC SAFETY COMM DIV (PSCD)	10/22/2019
RANCHO SANTIAGO COLLEGE	10/21/2019
SADDLEBACK VALLEY UNIF SCH DST	10/22/2019
SANTA ANA WATERSHED PROJECT	10/23/2019
SHEPARD ACADEMICS	10/23/2019
SPECTRASITE COMMUNICATION INC.	10/22/2019
SPRINT CORPORATE	10/24/2019
SPRINT NEXTEL CORPORATION	10/21/2019
SPRINT PCS ASSETS	10/21/2019
SPRINT TELEPHONY PCS L.P	10/21/2019
ST MICHAELS ABBEY	10/22/2019
T MOBILE USA	10/21/2019
T MOBILE WEST, LLC	10/21/2019
TOUCHTEL CORP	10/22/2019
TRABUCO CANYON WATER	10/23/2019
TRANS CORRIDOR AGENCY	10/21/2019
TUSTIN UNIFIED SCHOOL DISTRICT	10/23/2019
US MOBILE WIRELESS LLC	10/22/2019
VERIZON WIRELESS	10/21/2019
VILLA PARK, CITY OF	10/23/2019
RIVERSIDE COUNTY (Tier 2/Tier 3)	
RIVERSIDE COUNTY OEM	10/21/2019
ABRAMS,M AND ABRAMS,L	10/22/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

AIR TOUCH CELLULAR	10/24/2019
ALPHA MEDIA LLC	10/22/2019
AMERICAN COMPANION & CAREGIVER	10/23/2019
AMERICAN LEGION 01	10/24/2019
AMERICAN LEGION POST 800	10/24/2019
AMERICAN MED RESPON	10/24/2019
AMERICAN TOWER CORPORATION	10/21/2019
AT&T CORPORATION	10/21/2019
AT&T WIRELESS SERVICES	10/21/2019
BANNING UNIFIED SCHOOL DIST	10/21/2019
BEAUMONT LIONS CLUB	10/23/2019
BEAUMONT MANOR LLC	10/24/2019
BEAUMONT UNIFIED SCHOOL DIST	10/24/2019
BEAUMONT, CITY OF	10/23/2019
BNSF RAILWAY CO	10/23/2019
CALIFORNIA INLAND EMPIRE BSA	10/24/2019
CINGULAR WIRELESS	10/21/2019
CINGULAR WIRELESS, LLC	10/21/2019
CORONA, CITY OF	10/23/2019
CORONA-NORCO SCHOOL DISTRICT	10/23/2019
COX CALIFORNIA PCS	10/21/2019
CROWN CASTLE NG WEST LLC	10/22/2019
DAVID KLEIS III, LLC	10/24/2019
DAVITA, INC	10/24/2019
DESERT HOT SPRINGS, CITY OF	10/22/2019
DOL OF BEAUMONT LLC	10/23/2019
EASTERN MUNICIPAL WATER DIST	10/21/2019
EDOM HILLS PROJECT 1 LLC	10/22/2019
EMPIRE TRANSPORTATION, INC	10/21/2019
ENERGY DEVELOPMENT AND CONS	10/22/2019
FRONTIER COMMUNICATIONS CORP	10/21/2019
HALEY, JAMES R	10/22/2019
HALL, SUSAN D	10/22/2019
HARRIS CORPORATION	10/24/2019
HEMET UNIFIED SCHOOL DISTRICT	10/22/2019
HEMET VALLEY ADVENTIST SCHOOL	10/24/2019
HEMET VALLEY AMBULANCE SERVICE	10/24/2019
HEMET, CITY OF	10/24/2019
HIGHLAND ACADAMEY CHARTER	10/24/2019
HRHK LLC	10/23/2019
IDYLLWILD ARTS FOUNDATION	10/24/2019
IDYLLWILD FIRE DEPT	10/24/2019
IDYLLWILD WATER DISTRICT	10/24/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

J L STONE VFW	10/22/2019
JESSICA JIMENEZ	10/21/2019
JURUPA COMMUNITY SERVICE DIST	10/24/2019
JURUPA UNIFIED SCHOOL DISTRICT	10/24/2019
KVMD TV	10/21/2019
LAUDA, BERT	10/21/2019
LAZER BROADCASTING	10/23/2019
LIVING WATERS HOSPICE	10/23/2019
LOMA LINDA UNVRSTY MEDICAL CNT	10/23/2019
MARVO HOLSTEINS DAIRY	10/21/2019
MASCARO, STEPHEN J	10/21/2019
MCI GROUP	10/24/2019
MESA WIND POWER CORPORATION	10/24/2019
METROLINK	10/21/2019
METROPCS CALIFORNIA, LLC	10/22/2019
MISSION SPRINGS WATER DISTRICT	10/22/2019
MOBILITIE LLC	10/21/2019
MORONGO BAND MISSION INDIANS	10/21/2019
NEXTEL COMMUNICATIONS	10/22/2019
NEXTEL COMMUNICATIONS, INC	10/21/2019
NUVIEW UNION SCHOOL DISTRICT	10/21/2019
OAK GROVE INSTITUTE	10/21/2019
ORANGE COUNTY TRANSPORTATION	10/23/2019
ORO GRANDE SCHOOL DISTRICT	10/22/2019
PACIFIC BELL CORP	10/24/2019
PALM GROVE HEALTHCARE	10/22/2019
PALM SPRINGS UNIFIED SCHL DIST	10/22/2019
PARKER, FRED	10/24/2019
PEDLEY COMMUTER RAIL	10/24/2019
PERRIS ELEMENTARY SCHOOL DIST	10/21/2019
PERRIS, CITY OF	10/21/2019
R CARRILLO COM ASSN	10/24/2019
R.C.T.C.	10/22/2019
RIVERSIDE COMMUNITY COLLEGE	10/22/2019
RIVERSIDE COUNTY FACILITIES MG	10/21/2019
RIVERSIDE COUNTY FIRE DEPT	10/21/2019
RIVERSIDE COUNTY OFC EDUCATION	10/21/2019
RIVERSIDE COUNTY TRANS	10/21/2019
RIVERSIDE TELEPORT CORPORATION	10/21/2019
RIVERSIDE, COUNTY OF	10/21/2019
RIVERSIDE, EDA COUNTY OF	10/21/2019
ROMOLAND SCHOOL DISTRICT	10/22/2019
RSDE CO FIRE PROTECTION	10/21/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

SAN GORGONIO GIRL SCOUTS	10/21/2019
SAN JACINTO UNIFIED SCH DIST	10/21/2019
SAN JACINTO, CITY OF	10/21/2019
SANTA ANA WATERSHED PROJECT	10/23/2019
SCOTT, JOSEPH R	10/25/2019
SHARONDALE MESA OWNERS ASSOC	10/23/2019
SOBOBA INDIAN RESERVATION	10/21/2019
SOUTH WEST PUMP& DRILLING INC	10/22/2019
SOUTHERN PACIFIC CO	10/21/2019
SPRING AMBULANCE	10/22/2019
SPRINT NEXTEL	10/24/2019
SPRINT NEXTEL CORPORATION	10/21/2019
SPRINT TELEPHONY PCS L.P	10/23/2019
SPRINT UNITED MANAGEMENT CO	10/21/2019
ST JAMES CATHOLIC CHURCH	10/21/2019
ST JAMES SCHOOL	10/21/2019
ST JUDE SCHOOL	10/21/2019
SUNE DB APNL, LLC	10/21/2019
SYMONS EMERGENCY SPECIALTIES	10/22/2019
T A RIVARD INC	10/24/2019
T MOBILE USA	10/21/2019
T MOBILE WEST, LLC	10/21/2019
TAYLOR, THOMAS L	10/24/2019
TBU INC	10/23/2019
TELAR CORP.	10/22/2019
TEMECULA VALLEY UNIF SCH DIST	10/24/2019
THE LIONS CLUB	10/24/2019
UNION PACIFIC RAILROAD CO	10/21/2019
UNIVERSITY CALIF RIVERSIDE	10/22/2019
VAL VERDE UNIFIED SCHOOL DIST	10/21/2019
VERIZON	10/21/2019
VERIZON WIRELESS	10/21/2019
VYVX, INC	10/21/2019
WESTCHEM INC	10/23/2019
WHITEWATER MAINTENANCE CORP	10/24/2019
WILMON CORPORATION	10/24/2019
WINDPOWER PARTNERS 1993	10/22/2019
YUCAIPA VALLEY WATER DISTRICT	10/25/2019
SAN BERNARDINO COUNTY (Tier 2/Tier 3)	
SAN BERNARDINO COUNTY OEM	10/21/2019
1ST STEP INDEPENDENT LIVING	10/23/2019
ALTA LOMA SCHOOL DISTRICT	10/24/2019
ALTA VISTA PUBLIC CHARTER	10/23/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

AMATURO GP LTD, THE	10/21/2019
AMERICAN LEGION POST 421	10/24/2019
AMERICAN LEGION POST 426	10/21/2019
AMERICAN LEGION POST 777	10/21/2019
AMERICAN LEGION SAN BERNARDINO	10/21/2019
AMERICAN TOWER CORPORATION	10/21/2019
ARROW BEAR PK CO WATER DIST	10/24/2019
ARROWHEAD CONVALESCENT HOME	10/21/2019
ASA CHARTER SCHOOL	10/21/2019
ASSUMPTION CATHOLIC	10/21/2019
ASTOLFO, MICHAEL	10/24/2019
AT&T	10/23/2019
AT&T CORPORATION	10/21/2019
AT&T MOBILITY	10/24/2019
AT&T WIRELESS SERVICES	10/21/2019
AVENUE H, LLC	10/21/2019
B.P.O.E. 896	10/21/2019
BERLINGTON NORTHERN	10/24/2019
BIG BEAR WATER WASTE AGENCY	10/23/2019
BNSF RAILWAY CO	10/21/2019
BOYS & GIRLS CLUB OF YUCCA VLY	10/24/2019
BRASWELL ENTERPRISES INC	10/23/2019
BURLINGTON NORTHERN SANTA FE	10/21/2019
CAL PACIFIC TOWERS LLC	10/21/2019
CAL STATE UNIV SAN BERNARDINO	10/21/2019
CALIMESA OPERATIONS, LLC	10/21/2019
CENTER FOR YOUTH & COMMNTY DEV	10/21/2019
CHINO HILLS, CITY OF	10/24/2019
CHINO VALLEY IND FIRE DEPT	10/24/2019
CHINO VALLEY USD	10/24/2019
CINGULAR WIRELESS	10/21/2019
CINGULAR WIRELESS, LLC	10/21/2019
CLEAR WIRE COMMUNICATIONS LLC	10/21/2019
COMM HOSP SAN BERNARDINO	10/21/2019
COMMUNICATIONS RELAY, LLC	10/24/2019
COX CALIFORNIA PCS	10/21/2019
CRESTLINE LAKE ARROWHEAD WATER	10/21/2019
CRESTLINE SANITATION DISTRICT	10/21/2019
CROWN CASTLE	10/21/2019
CROWN CASTLE INTERNATIONAL	10/21/2019
DAVITA, INC	10/24/2019
DVA RENAL HEALTH CARE	10/24/2019
EAST VALLEY WATER DISTRICT	10/22/2019

Amended SCE PSPS Post Event Report
October 21 to October 26, 2019

EDUCATIONAL MEDIA FOUNDATION	10/21/2019
EL-CO CONTRACTORS	10/21/2019
ENTRAVISION COMMUNICATIONS CRP	10/24/2019
ETIWANDA SCHOOL DISTRICT	10/21/2019
EXCELSIOR CHARTER SCHOOLS	10/23/2019
EXCELSIOR EDUCATION CENTER	10/24/2019
FEDEX FREIGHT WEST	10/21/2019
FRONTIER COMMUNICATIONS	10/23/2019
FRONTIER COMMUNICATIONS CORP	10/21/2019
GLENDALE ELECTRONIC	10/21/2019
GLOBAL SIGNAL INC	10/21/2019
GREEN-WHITNEY, MARTHA	10/23/2019
HERNANDEZ, JOSEPH A	10/23/2019
HOLY ROSARY SCHOOL	10/21/2019
HUGHES, DENNIS	10/24/2019
INLAND EMPIRE UTILITIES AGENCY	10/21/2019
INLAND LEADERS CHARTER SCHL	10/22/2019
JANSSON, BRYAN	10/24/2019
JOHNSON, MERLIN	10/24/2019
KAY, JAMES A	10/23/2019
KDAY RADIO LLC	10/21/2019
KNICO INCORPORATED	10/21/2019
KSGN INC	10/21/2019
L V MOOSE 2096 -	10/23/2019
L.V. CHRIST. SCH.	10/23/2019
LA YMCA	10/23/2019
LAKE ARROWHEAD C S D	10/24/2019
LC MEDIA LP	10/21/2019
LIBERMAN BROADCASTING, INC	10/21/2019
LODESTAR TOWERS, INC	10/21/2019
LOS ANGELES AREA COUNCIL	10/24/2019
LUCRN VLY LIONS CLUB	10/23/2019
MASONIC BUILDING AND HOLDING	10/21/2019
MCC EQUIPMENT RENTALS, INC	10/23/2019
METROPCS CALIFORNIA, LLC	10/21/2019
MOBIL RELAY ASSOCIA	10/24/2019
MOBILITIE LLC	10/24/2019
MOBILITIE SERVICES LLC	10/24/2019
MOOSE LODGE	10/24/2019
MORONGO UNIFIED SCHOOL DISTRCT	10/23/2019
MORONGO VALLEY CSD	10/24/2019
MT BALDY FIRE DEPT	10/23/2019
MT CALVARY LUTHERAN SCHOOL	10/24/2019

Amended SCE PSPS Post Event Report
October 21 to October 26, 2019

NEW HORIZON CARE	10/22/2019
NEXTEL COMMUNICATIONS	10/24/2019
NEXTEL COMMUNICATIONS, INC	10/21/2019
ORANGE, COUNTY OF	10/24/2019
OUR LADY OF DESERT SCHOOL	10/24/2019
PACIFIC BELL CORP	10/21/2019
PETRONE, DONALD L	10/24/2019
PIPE JACKING UNLIMITED	10/21/2019
PORTUGUESE AMER CLB	10/24/2019
REDLANDS UNIFIED SCHOOL DIST	10/24/2019
REDLANDS, CITY OF	10/24/2019
REGENTS OF THE UCLA	10/24/2019
REMOTE COMMUNICATION SYST INC	10/24/2019
RIALTO UNIFIED SCHOOL DISTRICT	10/21/2019
RIM OF THE WORLD UNIF SCH DIST	10/21/2019
RUNNING SPRINGS WATER DISTRICT	10/24/2019
S BDNA YORK RT BLDG	10/21/2019
SAN BERNARDINO CITY UNIF SCH	10/21/2019
SAN BERNARDINO COUNTY FIRE	10/21/2019
SAN BERNARDINO MTNS COMM HOSP	10/24/2019
SAN BERNARDINO WOMENS CLUB	10/21/2019
SAN BERNARDINO, CITY OF	10/21/2019
SAN BERNARDINO, COUNTY OF	10/21/2019
SAN GORGONIO GIRL SCOUTS	10/21/2019
SAN MANUEL BAND OF INDIANS	10/23/2019
SAN RIVER RADIO	10/24/2019
SIERRA CLUB	10/23/2019
SNOWLINE JOINT UNIFIED SCH DIS	10/24/2019
SOUTHERN PACIFIC CO	10/24/2019
SPECTRASITE COMMUNICATION INC.	10/21/2019
SPRINT NEXTEL	10/23/2019
SPRINT NEXTEL CORPORATION	10/21/2019
SPRINT TELEPHONY PCS L.P	10/21/2019
SPRINT UNITED MANAGEMENT CO	10/21/2019
ST ANTHONYS SCHOOL	10/21/2019
T MOBILE USA	10/21/2019
T MOBILE WEST, LLC	10/21/2019
TOUCHTEL CORP	10/21/2019
UNION PACIFIC RAILROAD CO	10/25/2019
V F W POST 5551	10/23/2019
VERIZON	10/21/2019
VERIZON WIRELESS	10/21/2019
VTRN OF FOREIGN WAR	10/21/2019

Amended SCE PSPS Post Event Report
October 21 to October 26, 2019

WAGON TRAIN ROAD LLC	10/21/2019
YOUNG MENS CHRISTIAN CENTINELA	10/23/2019
YUC VLY POST 7347	10/22/2019
YUCAIPA ELKS 2389	10/24/2019
YUCAIPA JOINT UNIFIED SCH DIST	10/21/2019
YUCAIPA WOMANS CLUB	10/21/2019
YUCAIPA, CITY OF	10/21/2019
YUCCA VALLEY ELKS 2314	10/24/2019
SANTA BARBARA COUNTY (Tier 2/Tier 3)	
SANTA BARBARA COUNTY OEM	10/23/2019
AT&T CORPORATION	10/23/2019
FRONTIER COMMUNICATIONS CORP	10/23/2019
GTE MOBILENET INCORPORATED	10/23/2019
MCI GROUP	10/23/2019
SANTA BARBARA, COUNTY OF	10/23/2019
SOUTHERN PACIFIC CO	10/23/2019
SPRINT NEXTEL CORPORATION	10/23/2019
TULARE COUNTY (Tier 2/Tier 3)	
TULARE COUNTY OEM	10/23/2019
BOY SCOUTS OF AMERICA	10/24/2019
FRONTIER COMMUNICATIONS CORP	10/24/2019
VENTURA COUNTY (Tier 2/Tier 3)	
VENTURA COUNTY OEM	10/21/2019
A-1 HOME HEALTH SERVICES INC.	10/22/2019
AAA HOME HEALTH CARE INC	10/23/2019
ADEGOKE, CECILIA A	10/23/2019
AIR TOUCH CELLULAR	10/23/2019
AMERICAN LEGION	10/22/2019
AMERICAN MEDICAL RESPONSE	10/22/2019
AMERICAN TOWER CORPORATION	10/21/2019
ANSPAUGH, BRUCE	10/21/2019
ASSOCIATION FOR COMMMTY EDUC IN	10/22/2019
ASSUMPTION CHURCH	10/23/2019
AT & T LIGHTSPEED	10/23/2019
AT&T	10/21/2019
AT&T CORPORATION	10/21/2019
AT&T MOBILITY	10/21/2019
AT&T WIRELESS SERVICES	10/21/2019
ATT MOBILITY	10/24/2019
AVETISYAN, ANGELINA	10/23/2019
BAKER PETROLITE CORPORATION	10/21/2019
BBH8 INC	10/23/2019
BOYS & GIRLS CLUB OF MOORPARK	10/22/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

BOYS & GIRLS CLUB OF SIMI VLY	10/23/2019
BOYS & GIRLS CLUB OF VENTURA	10/23/2019
BPOE LODGE 2492	10/22/2019
BRIGGS ELEMENTARY SCH DIST	10/21/2019
BUENA VENTURA CLUB	10/23/2019
CABRERA, BENJAMIN	10/23/2019
CALIFORNIA VIRTUAL ACADEMYS	10/22/2019
CALLEGUAS MUNICIPAL WATER DIST	10/23/2019
CAMROSA WATER DISTRICT	10/24/2019
CAPS TV	10/23/2019
CARE FIRST HOME HEALTH CARE IN	10/23/2019
CERTIFIED HOME HEALTHCARE INC	10/23/2019
CHILTON, SHELLEY	10/24/2019
CINGULAR WIRELESS	10/21/2019
CINGULAR WIRELESS, LLC	10/22/2019
CITY OF DREAMS HOME HEALTHCARE	10/23/2019
COMFORT CARE HOSPICE PROVIDERS	10/23/2019
COMMUNITY MEMORIAL HOSPITAL	10/23/2019
COMSAT INC	10/21/2019
COUNTY OF VENTURA	10/22/2019
COX CALIFORNIA PCS	10/21/2019
CUMULUS RADIO CORPORATION	10/23/2019
DAVITA, INC	10/21/2019
EDUCATION MANAGEMENT SYSTEMS	10/23/2019
ELLIOTT, RODNEY L	10/21/2019
ENTRAVISION COMMUNICATIONS CRP	10/23/2019
FAITHFUL HOSPICE CARE INC	10/23/2019
FILL/PIRU MEM DIST	10/21/2019
FILLMORE COUNTRY CLUB LLC	10/21/2019
FILLMORE LIONS CLUB	10/21/2019
FILLMORE SEARCH AND RESCUE	10/21/2019
FILLMORE UNIFIED SCHOOL DIST	10/21/2019
FILLMORE, CITY OF	10/21/2019
FREE SPIRIT HOSPICE, INC	10/23/2019
FRESENIUS USA INCORPORATED	10/23/2019
FRICKE, MICHAEL B	10/23/2019
FRONTIER COMMUNICATIONS CORP	10/21/2019
GLOBAL SIGNAL INC	10/23/2019
GOFF, WAYNE	10/23/2019
GOLD COAST BROADCASTING	10/21/2019
GRACE BRETHERN JR HIGH SCHOOL	10/23/2019
GREENFIELD CARECENTER OF FILMO	10/21/2019
GUMBA, ROMEO	10/23/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

H & A HOSPICE INC	10/23/2019
HANSEN WELL SERVICE	10/22/2019
HAPPY VALLEY FOUNDATION	10/22/2019
HOLY CROSS SCHOOL	10/23/2019
HORIZON HEALTH CARE SYSTEMS	10/23/2019
I O O F HALL	10/23/2019
INTELSAT CORPORATION	10/21/2019
IV TECH CHARTER SCHOOL	10/21/2019
JC HEALTHCARE SRVCS INC	10/23/2019
KNIGHTS OF COLUMBUS CA STATE	10/23/2019
LAYNE CHRISTENSEN COMPANY	10/21/2019
LAZER BROADCASTING	10/21/2019
LIBERTY MOBILE WIRELESS LLC	10/23/2019
LINDEEN, GORDON	10/23/2019
LOTUS OXNARD CORPORATION	10/23/2019
LOYAL ORDER MOOSE	10/23/2019
LOYAL ORDER OF MOOSE	10/24/2019
MAGNIFICENT HEALTH CARE SYSTEM	10/23/2019
MESA UNION ELEM SCH DIST	10/21/2019
METROLINK	10/21/2019
MONICA ROS SCHOOL	10/22/2019
MOORPARK ARTS FOUNDATION	10/21/2019
MOORPARK UNIFIED SCHOOL DIST	10/21/2019
MOORPARK, CITY OF	10/21/2019
MOTHER OF DIVINE GRACE, INC	10/22/2019
MUPU ELEMENTARY SCH DIST	10/21/2019
MV TRANSPORTATION	10/21/2019
N G C GROUP	10/23/2019
NEXTEL COMMUNICATIONS, INC	10/21/2019
NISC/NEXTEL	10/21/2019
OCEAN VIEW ELEM SCHOOL DIST	10/24/2019
OJAI AMBULANCE	10/23/2019
OJAI VALLEY SANITATION DIST	10/23/2019
OJAI VALLEY SCHOOL	10/22/2019
OJAI WOMENS CLUB	10/22/2019
OJAI, CITY OF	10/22/2019
PACIFIC BELL CORP	10/23/2019
PACIFIC TELEPHONE LLC	10/22/2019
PINECREST SCHOOLS	10/23/2019
PIRU PETRO CLUB	10/21/2019
PLEASANT VALLEY SCHOOL DIST	10/23/2019
PREMIERE CARE SIMI	10/23/2019
PRUNER HEALTH SERVICES	10/23/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

PURVES, JAMES	10/21/2019
QWEST COMMUNICATIONS CORP	10/21/2019
REMOTE COMMUNICATION SYST INC	10/21/2019
SALEM MEDIA GROUP, INC.	10/23/2019
SAN BUENAVENTURA MASONIC CTR	10/23/2019
SANTA CLARA ELEM SCH DIST	10/21/2019
SANTA CLARA WASTE WATER	10/21/2019
SANTA PAULA HOSPITAL	10/21/2019
SANTA PAULA LODGE F/AM	10/24/2019
SANTA PAULA POST ACUTE LLC	10/23/2019
SANTA PAULA UNIFIED SCH DIST	10/21/2019
SANTA PAULA, CITY OF	10/21/2019
SE VENTURA CO YMCA	10/23/2019
SEASONS SIMI VALLEY AR, LP	10/23/2019
SENIOR JOY INC.	10/21/2019
SERENITY HOSPICE CARE INC	10/23/2019
SIMI DIALYSIS CENTER LLC	10/23/2019
SIMI HILLS SUBTENANT LP	10/23/2019
SIMI PLAZA HOME CARE INC	10/23/2019
SIMI VALLEY COLUMBIAN CLUB	10/23/2019
SIMI VALLEY HOSPITAL	10/22/2019
SIMI VALLEY MASONIC TEMPLE	10/23/2019
SIMI VALLEY UNIFIED SCHOOL DIS	10/22/2019
SIMI VALLEY, CITY OF	10/21/2019
SOMARATNE, ANUSHA	10/23/2019
SOUTHERN CALIFORNIA REGIONAL	10/22/2019
SOUTHERN PACIFIC CO	10/23/2019
SPLA LODGE 291 F/AM	10/24/2019
SPRINT CORPORATE	10/23/2019
SPRINT NEXTEL CORPORATION	10/21/2019
SPRINT PCS ASSETS	10/23/2019
SPRINT TELEPHONY PCS L.P	10/21/2019
SPRINT UNITED MANAGEMENT CO	10/23/2019
ST BONAVENTURE	10/23/2019
ST JOSEPHS CONVALESCENT HOSPTL	10/22/2019
ST ROSE OF LIMA	10/23/2019
ST SEBASTIAN SCHOOL	10/24/2019
STRATEGIC COMMUNICATIONS GROUP	10/23/2019
SUMMIT HOME HEALTH, INC	10/23/2019
SUNRISE AT WOODRANCH	10/23/2019
SV POLICE OFCR ASSN	10/23/2019
SWEENEY, DEBBIE	10/23/2019
T MOBILE USA	10/21/2019

Amended SCE PSPS Post Event Report
 October 21 to October 26, 2019

T MOBILE WEST	10/22/2019
T MOBILE WEST, LLC	10/21/2019
TEXACO EXPLORATION AND PROD	10/23/2019
THACHER SCHOOL	10/22/2019
THOMAS AQUINAS COLLEGE	10/21/2019
THOUSAND OAKS, CITY OF	10/24/2019
UC REGENTS	10/23/2019
UNION PACIFIC RAILROAD CO	10/23/2019
UNITED CHEMICAL	10/21/2019
UNITED HEARTS HOSPICE HEALTH	10/23/2019
UNIV OF SOUTHERN CALIFORNIA	10/22/2019
UNIVERSAL PREV HOMEHEALTH CARE	10/23/2019
USA AG SUPPLY INC	10/21/2019
V F W	10/22/2019
VENTURA COUNTY ARTS COUNCIL	10/23/2019
VENTURA COUNTY BOY SCOUTS OF A	10/23/2019
VENTURA COUNTY COMM COLL DIST	10/21/2019
VENTURA ODDFELLOWS, THE	10/23/2019
VENTURA POST ACUTE LLC	10/23/2019
VENTURA REGIONAL SANITATION DT	10/21/2019
VENTURA UNIFIED SCHOOL DIST	10/23/2019
VENTURA, CITY OF	10/23/2019
VENTURA, COUNTY OF	10/21/2019
VEOLIA NORTH AMERICA SERV INC	10/21/2019
VERIZON WIRELESS	10/21/2019
VET MEMORIAL BLDG	10/21/2019
VETERNS OF FOREIGN01	10/23/2019
VISTA REAL CHARTER HS	10/23/2019
WESTLAKE HOSPICE CARE INC	10/23/2019
WOOD-CLAEYSSENS FOUNDATION	10/24/2019
WOULD	10/23/2019

Appendix E

De-Energization Information

Amended SCE PSPS Post Event Report
October 21 to October 26, 2019

Circuit	Isolation Device	Customers on Circuit	Date / Time De-Energized	Date/Time Re-energized All Load	Residential Unassigned	Essential	Major	Medical Baseline	Critical Care
McKevett 4kV	CB	289	10/23/19 23:47	10/24/19 14:47	282	0	4	1	2
Castro 16kV	CB	2380	10/23/19 23:47	10/25/19 12:18	2305	5	49	20	4
Gnatcatcher 12kV	CB	1447	10/24/19 2:41	10/24/19 22:36	1345	0	46	47	10
Tanager 12kV	CB	1538	10/24/19 2:41	10/25/19 1:02	1473	0	10	46	13
Condor 12kV	CB	1464	10/24/19 2:41	10/25/19 13:35	1374	0	48	34	8
Mettler 12kV	CB	514	10/24/19 2:42	10/24/19 22:36	487	0	9	15	3
Cuddeback 12kV	CB	323	10/24/19 2:43	10/24/19 22:06	315	0	6	3	1
Huckleberry 12kV	CB	172	10/24/19 3:45	10/25/19 13:07	158	2	8	4	0
Tahquitz 12kV	CB	133	10/24/19 3:45	10/25/19 14:51	121	0	9	2	1
Mora 12kV	CB	2459	10/24/19 3:49	10/25/19 14:13	2342	1	67	45	5
Taiwan 12kV	RAR0950	71	10/24/19 4:04	10/25/19 11:52					
Casmalia 12kV	CB	2021	10/24/19 4:04	10/25/19 14:41	1847	0	127	42	7
Amethyst 12kV	CB	1528	10/24/19 4:47	10/25/19 12:49	1444	0	24	51	9
Acosta 12kV	CB	1242	10/24/19 4:48	10/25/19 14:28	1139	1	63	36	4
Club Oaks 33kV	RAR0686	2	10/24/19 5:33	10/25/19 17:01	0	0	2	0	0
Sutt 12kV	RAR0825	27	10/24/19 5:35	10/25/19 17:20	19	0	8	0	0
Echo 12kV	RAR0826	87	10/24/19 5:38	10/25/19 14:58	82	0	2	2	1
Anton	CB RAR0217 RAR0621	285	10/24/19 6:08	10/25/19 15:41	237	0	47	1	1
Estaban 16kV	RAR0569 RAR7446	356	10/24/19 7:17	10/25/19 13:40	310	0	44	2	0
Trumpet 16kV	PS0167	272	10/24/19 7:51	10/24/19 10:10	10	0	2	0	0
Petit 16kV	RAR0250	22	10/24/19 8:12	10/25/19 12:29	8	0	14	0	0
Rainbow 16kV	RAR1941	19	10/24/19 8:14	10/25/19 10:18	17	0	2	0	0
Loucks 12kV	CB	56	10/24/19 8:51	10/25/19 20:49	56	0	0	0	0
Davenport 16kV	CB	1459	10/24/19 8:51	10/28/19 19:02	1386	1	37	23	13
Arlene 16kV	CB	1561	10/24/19 8:59	10/27/19 15:48	1484	0	35	36	6
Shovel 12kV	RAR0419	413	10/24/19 9:07	10/27/19 10:53	394	0	9	8	2
Maciel 12kV	RAR6072	14	10/24/19 9:27	10/25/19 6:38	10	0	4	0	0
Energy 16kV	CB	1807	10/24/19 9:41	10/25/19 17:05	1702	4	83	16	5
CalState 12kV	RAR0868	10	10/24/19 9:48	10/25/19 18:41	6	0	4	0	0
Python 16kV	CB	1423	10/24/19 10:35	10/25/19 13:31	1342	3	45	28	7
Guitar 16kV	RAR0402	43	10/24/19 10:36	10/25/19 16:48	9	0	29	0	0
Bouquet 16kV	CB	734	10/24/19 10:46	10/26/19 14:56	681	7	24	20	2
Sand Canyon 16kV	CB	2205	10/24/19 11:12	10/28/19 17:56	2071	2	73	52	8
De Mille 4kV	RAR3825	249	10/24/19 11:22	10/25/19 17:28	242	0	3	3	1
Lopez 16kV	RAR3825	147	10/24/19 11:22	10/25/19 17:28	129	1	16	1	0
Stubby 33kV	RAR0670	183	10/24/19 11:23	10/25/19 11:17	0	0	0	0	0
Gunsite 2.4kV	RAR0670	5	10/24/19 11:23	10/25/19 11:17	2	0	3	0	0
Pheasant 12kV	RAR0670	175	10/24/19 11:23	10/25/19 11:17	168	0	3	2	2
Balcom 16kV	CB	1538	10/24/19 11:33	10/25/19 11:52	1476	1	45	12	2
Steel 12kV	RAR1637	34	10/24/19 11:43	10/25/19 9:27	11	1	22	0	0
Zone 16kV	CB	1231	10/24/19 11:47	10/25/19 1:27	1149	0	56	23	3
Tuba 16kV	RAR0225	25	10/24/19 13:07	10/25/19 3:25	2	2	21	0	0
Dartmouth 12kV	CB	1335	10/24/19 17:04	10/25/19 11:35	1221	0	62	40	12
Red Box 4KV	RAR9578	29	10/24/19 21:10	10/25/19 13:50	21	1	7	0	0
Shovel 12kV	PS0621	9	10/26/19 16:54	10/27/19 10:53	2	0	7	0	0
Kimberly 2.4kV	CB	50	10/24/19 5:33	10/25/19 17:01	44	0	6	0	0

Officer Verification

I am an officer of the applicant corporation herein and am authorized to make this verification on its behalf. I am informed and believe that the matters stated in the foregoing document are true.

I declare under penalty of perjury that the foregoing is true and correct.

Executed this 26th day of November, 2019 at Rosemead, California.

DocuSigned by:

94EE3C992133489

Andrew Martinez

Vice President,

Safety, Security & Business Resiliency